

Anexo N°7

Verificación Hidráulica Red de Distribución

AÑO 0

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.13	612.33	23.204
J-26	588.78	BRISAS DE CHICUREO NORTE	0.13	612.33	23.510
J-28	588.57	BRISAS DE CHICUREO NORTE	0.13	612.33	23.711
J-18	588.00	BRISAS DE CHICUREO NORTE	0.13	612.33	24.285
J-19	587.16	BRISAS DE CHICUREO NORTE	0.13	612.33	25.119
J-17	587.03	BRISAS DE CHICUREO NORTE	0.13	612.33	25.256
J-11	586.98	BRISAS DE CHICUREO NORTE	0.13	612.34	25.305
J-48	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.63	25.577
J-47	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.63	25.578
J-76	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.65	25.594
J-79	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.66	25.607
J-43	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.67	25.623
J-46	585.94	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.63	25.636
J-42	586.00	<None>	0.00	611.72	25.670
J-62	585.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	25.672
J-27	586.55	BRISAS DE CHICUREO NORTE	0.13	612.33	25.728
J-65	585.66	<None>	0.00	611.59	25.873
J-41	585.68	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.75	26.026
J-61	585.46	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	26.072
J-36	585.36	<None>	0.00	611.84	26.426
J-16	585.62	BRISAS DE CHICUREO NORTE	0.13	612.33	26.654
J-10	585.63	BRISAS DE CHICUREO NORTE	0.13	612.34	26.654
J-66	584.89	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.59	26.655
J-40	585.05	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.79	26.691
J-56	584.75	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.59	26.782
J-80	584.72	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.64	26.868
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.65	26.919
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	27.099
J-37	584.60	<None>	0.00	611.83	27.170

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-24	584.83	BRISAS DE CHICUREO NORTE	0.13	612.33	27.447
J-1	584.67	<None>	0.00	612.38	27.657
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.63	27.725
J-2	584.49	<None>	0.00	612.38	27.836
J-9	584.37	BRISAS DE CHICUREO NORTE	0.13	612.35	27.921
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.60	28.034
J-3	584.18	<None>	0.00	612.38	28.146
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.60	28.158
J-20	584.07	BRISAS DE CHICUREO NORTE	0.13	612.33	28.210
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.64	28.247
J-300	583.11	CONDOMINIO RUKAN	0.11	611.52	28.355
J-12	583.81	BRISAS DE CHICUREO NORTE	0.13	612.33	28.461
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.64	28.486
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.64	28.692
J-15	583.58	BRISAS DE CHICUREO NORTE	0.13	612.33	28.696
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.61	28.767
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.61	28.814
J-21	583.46	BRISAS DE CHICUREO NORTE	0.13	612.34	28.816
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	7.41	611.71	28.846
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	28.932
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.32	28.972
J-405	582.65	SAN LUIS	0.49	612.01	29.305
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.32	29.331
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.63	29.346
J-101	582.72	<None>	0.00	612.38	29.607
J-14	582.64	BRISAS DE CHICUREO NORTE	0.13	612.33	29.634
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.61	29.683
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.63	29.764
J-4	582.48	<None>	0.00	612.38	29.833
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.59	29.834

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	29.883
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.58	30.325
J-13	581.92	BRISAS DE CHICUREO NORTE	0.13	612.33	30.351
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.61	30.443
J-8	581.84	BRISAS DE CHICUREO NORTE	0.13	612.35	30.456
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.59	30.539
J-5	581.70	<None>	0.00	612.37	30.604
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.32	30.640
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.62	30.704
J-23	581.37	BRISAS DE CHICUREO NORTE	0.13	612.33	30.905
J-364	580.49	CONDOMINIO RUKAN	0.11	611.52	30.971
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.32	31.209
J-85	581.00	<None>	0.00	612.31	31.246
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.33	31.299
J-299	580.15	CONDOMINIO RUKAN	0.11	611.55	31.341
J-22	580.92	BRISAS DE CHICUREO NORTE	0.13	612.34	31.350
J-88	580.83	<None>	0.00	612.33	31.437
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.61	31.591
J-89	580.51	<None>	0.00	612.33	31.759
J-84	580.42	<None>	0.00	612.30	31.821
J-87	580.27	<None>	0.00	612.31	31.982
J-97	580.31	<None>	0.00	612.38	32.004
J-39	580.14	<None>	0.00	612.23	32.021
J-81	580.00	<None>	0.00	612.24	32.177
J-82	580.00	<None>	0.00	612.26	32.196
J-86	580.00	<None>	0.00	612.31	32.248
J-93	580.00	<None>	0.00	612.35	32.285
J-94	580.00	<None>	0.00	612.35	32.285
J-91	579.93	<None>	0.00	612.34	32.340
J-83	579.67	<None>	0.00	612.29	32.555
J-98	579.66	<None>	0.00	612.38	32.657
J-29	579.64	<None>	0.00	612.38	32.677
J-54	578.81	CONDOMINIO 1 BRISAS-CHICUREO	0.23	611.59	32.717
J-72	578.80	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.61	32.750
J-301	578.67	CONDOMINIO RUKAN	0.11	611.52	32.788
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.12	611.59	32.820
J-298	578.65	CONDOMINIO RUKAN	0.11	611.58	32.864

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-92	579.33	<None>	0.00	612.35	32.954
J-90	579.31	<None>	0.00	612.33	32.955
J-112	579.30	<None>	0.00	612.39	33.019
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.33	33.097
J-102	578.94	<None>	0.00	612.38	33.376
J-6	578.90	BRISAS DE CHICUREO NORTE	0.13	612.37	33.402
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.33	33.518
J-109	578.73	<None>	0.00	612.35	33.554
J-304	577.89	CONDOMINIO RUKAN	0.11	611.55	33.595
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.75	33.677
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.75	33.681
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.75	33.686
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	612.33	33.764
J-7	578.48	BRISAS DE CHICUREO NORTE	0.13	612.37	33.813
J-253	576.00	CONDOMINIO LA SIEMBRA	0.22	609.95	33.882
J-95	578.40	<None>	0.00	612.37	33.900
J-111	578.22	<None>	0.00	612.39	34.093
J-104	578.17	<None>	0.00	612.38	34.147
J-242	575.72	CONDOMINIO LA SIEMBRA	0.22	609.95	34.157
J-291	576.00	CONDOMINIO LA TRILLA	0.21	610.31	34.240
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.07	609.74	34.350
J-277	575.74	CONDOMINIO LA TRILLA	0.21	610.32	34.505
J-96	577.74	<None>	0.00	612.38	34.570
J-100	577.57	<None>	0.00	612.38	34.739
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.07	609.66	34.848
J-105	577.42	<None>	0.00	612.39	34.891
J-99	577.36	<None>	0.00	612.38	34.947
J-35	576.93	<None>	0.00	612.27	35.265
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.07	609.74	35.273
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.07	609.74	35.276
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.07	609.74	35.428
J-173	575.06	<None>	0.00	610.56	35.437
J-267	574.77	CONDOMINIO LA TRILLA	0.21	610.30	35.465
J-287	574.68	CONDOMINIO LA TRILLA	0.21	610.31	35.562
J-258	574.89	<None>	0.00	610.52	35.565
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.07	609.66	35.588

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-245	574.28	CONDOMINIO LA SIEMBRA	0.22	609.95	35.596
J-303	575.85	CONDOMINIO RUKAN	0.11	611.52	35.599
J-254	574.24	CONDOMINIO LA SIEMBRA	0.22	609.95	35.643
J-305	575.80	CONDOMINIO RUKAN	0.11	611.55	35.679
J-292	574.50	CONDOMINIO LA TRILLA	0.21	610.30	35.730
J-363	575.69	CONDOMINIO RUKAN	0.11	611.52	35.755
J-297	575.70	CONDOMINIO RUKAN	0.11	611.60	35.830
J-259	574.54	<None>	0.00	610.48	35.873
J-233	574.00	CONDOMINIO LA SIEMBRA	0.22	609.96	35.890
J-232	574.00	CONDOMINIO LA SIEMBRA	0.22	609.96	35.890
J-231	574.00	CONDOMINIO LA SIEMBRA	0.22	609.96	35.891
J-257	574.00	CONDOMINIO LA SIEMBRA	0.22	609.97	35.894
J-264	574.31	CONDOMINIO LA TRILLA	0.21	610.33	35.948
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.07	609.76	35.955
J-289	574.20	CONDOMINIO LA TRILLA	0.21	610.33	36.057
J-290	574.15	CONDOMINIO LA TRILLA	0.21	610.30	36.083
J-268	574.09	CONDOMINIO LA TRILLA	0.21	610.30	36.138
J-283	574.00	CONDOMINIO LA TRILLA	0.21	610.30	36.232
J-274	573.93	CONDOMINIO LA TRILLA	0.21	610.33	36.333
J-284	573.82	CONDOMINIO LA TRILLA	0.21	610.30	36.412
J-106	575.90	<None>	0.00	612.39	36.413
J-237	573.42	CONDOMINIO LA SIEMBRA	0.22	609.96	36.464
J-34	575.78	<None>	0.00	612.33	36.484
J-103	575.79	<None>	0.00	612.39	36.530
J-256	573.36	CONDOMINIO LA SIEMBRA	0.22	609.97	36.537
J-263	573.68	CONDOMINIO LA TRILLA	0.21	610.35	36.593
J-33	575.65	<None>	0.00	612.36	36.637
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.07	609.74	36.775
J-230	573.06	CONDOMINIO LA SIEMBRA	0.22	609.97	36.832
J-236	572.96	CONDOMINIO LA SIEMBRA	0.22	609.96	36.927
J-273	573.20	CONDOMINIO LA TRILLA	0.21	610.32	37.046
J-235	572.84	CONDOMINIO LA SIEMBRA	0.22	609.96	37.047
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.07	609.75	37.215
J-266	572.94	CONDOMINIO LA TRILLA	0.21	610.31	37.293
J-269	572.92	CONDOMINIO LA TRILLA	0.21	610.30	37.313
J-339	574.08	CONDOMINIO RUKAN	0.11	611.50	37.347
J-286	572.84	CONDOMINIO LA TRILLA	0.21	610.30	37.388
J-255	572.50	CONDOMINIO LA SIEMBRA	0.22	609.97	37.391

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.07	609.66	37.408
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.07	609.74	37.491
J-285	572.69	CONDOMINIO LA TRILLA	0.21	610.30	37.537
J-307	573.85	CONDOMINIO RUKAN	0.11	611.51	37.584
J-234	572.29	CONDOMINIO LA SIEMBRA	0.22	609.97	37.604
J-30	574.69	<None>	0.00	612.39	37.626
J-238	572.25	CONDOMINIO LA SIEMBRA	0.22	609.97	37.644
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.07	609.75	37.702
J-275	572.54	CONDOMINIO LA TRILLA	0.21	610.32	37.709
J-107	574.43	<None>	0.00	612.39	37.880
J-229	572.00	CONDOMINIO LA SIEMBRA	0.22	609.98	37.900
J-239	571.97	CONDOMINIO LA SIEMBRA	0.22	609.96	37.910
J-240	571.92	CONDOMINIO LA SIEMBRA	0.22	609.95	37.957
J-249	571.94	CONDOMINIO LA SIEMBRA	0.22	609.97	37.961
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.15	611.51	37.962
J-262	572.35	<None>	0.00	610.40	37.975
J-365	573.40	CONDOMINIO RUKAN	0.11	611.51	38.026
J-347	573.38	CONDOMINIO RUKAN	0.11	611.50	38.041
J-407	574.27	<None>	0.00	612.45	38.096
J-349	573.30	CONDOMINIO RUKAN	0.11	611.50	38.118
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.07	609.78	38.252
J-293	572.06	<None>	0.00	610.40	38.263
J-250	571.58	CONDOMINIO LA SIEMBRA	0.22	609.96	38.296
J-174	571.62	<None>	0.00	610.08	38.378
J-228	571.51	CONDOMINIO LA SIEMBRA	0.22	609.99	38.401
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.07	609.74	38.433
J-272	571.78	CONDOMINIO LA TRILLA	0.21	610.32	38.462
J-265	571.65	CONDOMINIO LA TRILLA	0.21	610.31	38.577
J-244	571.26	CONDOMINIO LA SIEMBRA	0.22	609.95	38.611
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.07	609.66	38.626
J-260	571.62	<None>	0.00	610.43	38.735
J-247	571.03	CONDOMINIO LA SIEMBRA	0.22	609.96	38.849
J-251	570.94	CONDOMINIO LA SIEMBRA	0.22	609.96	38.944
J-246	570.92	CONDOMINIO LA SIEMBRA	0.22	609.95	38.953

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.07	609.80	38.961
J-261	571.29	<None>	0.00	610.43	39.067
J-276	571.05	CONDOMINIO LA TRILLA	0.21	610.31	39.180
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.07	609.74	39.236
J-241	570.57	CONDOMINIO LA SIEMBRA	0.22	609.95	39.306
J-175	570.44	<None>	0.00	609.83	39.309
J-406	572.89	<None>	0.00	612.40	39.432
J-32	572.86	<None>	0.00	612.39	39.444
J-31	572.85	<None>	0.00	612.40	39.474
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.15	611.65	39.565
J-279	570.60	CONDOMINIO LA TRILLA	0.21	610.31	39.631
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.07	609.66	39.676
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.15	611.66	39.701
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.07	609.66	39.701
J-271	570.38	CONDOMINIO LA TRILLA	0.21	610.31	39.852
J-243	570.00	CONDOMINIO LA SIEMBRA	0.22	609.95	39.872
J-248	570.00	CONDOMINIO LA SIEMBRA	0.22	609.96	39.882
J-252	570.00	CONDOMINIO LA SIEMBRA	0.22	609.97	39.890
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.07	609.66	39.951
J-163	571.57	CONDOMINIO LAS BRISAS 3	0.15	611.62	39.962
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.15	611.50	39.982
J-270	570.00	CONDOMINIO LA TRILLA	0.21	610.31	40.227
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.15	611.52	40.286
J-278	569.90	CONDOMINIO LA TRILLA	0.21	610.31	40.327
J-348	570.98	CONDOMINIO RUKAN	0.11	611.50	40.438
J-162	571.04	CONDOMINIO LAS BRISAS 3	0.15	611.62	40.495
J-113	571.08	<None>	0.00	611.73	40.571
J-282	569.56	CONDOMINIO LA TRILLA	0.21	610.30	40.663
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.15	611.65	40.666
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.07	609.66	40.739
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.07	609.82	40.794
J-308	570.59	CONDOMINIO RUKAN	0.11	611.50	40.825
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.15	611.62	40.881

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.07	609.77	40.952
J-360	570.45	CONDOMINIO RUKAN	0.11	611.51	40.976
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.07	609.78	41.141
J-281	569.04	CONDOMINIO LA TRILLA	0.21	610.30	41.180
J-161	570.30	CONDOMINIO LAS BRISAS 3	0.15	611.62	41.230
J-302	570.02	CONDOMINIO RUKAN	0.11	611.52	41.411
J-296	570.00	<None>	0.00	611.61	41.527
J-160	569.98	CONDOMINIO LAS BRISAS 3	0.15	611.62	41.553
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.07	609.82	41.565
J-306	569.69	CONDOMINIO RUKAN	0.11	611.52	41.744
J-280	568.45	CONDOMINIO LA TRILLA	0.21	610.30	41.768
J-294	569.53	<None>	0.00	611.61	41.994
J-343	569.39	CONDOMINIO RUKAN	0.11	611.47	41.997
J-404	567.81	REMANSO DE CHICUREO	0.25	609.91	42.018
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.07	609.66	42.022
J-295	569.50	<None>	0.00	611.61	42.026
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.07	609.66	42.052
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.15	611.53	42.053
J-366	569.22	CONDOMINIO RUKAN	0.11	611.51	42.199
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.07	609.66	42.302
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.07	609.74	42.440
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.07	609.66	42.457
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.07	609.80	42.481
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.15	611.52	42.539
J-338	568.83	CONDOMINIO RUKAN	0.11	611.47	42.554
J-341	568.69	CONDOMINIO RUKAN	0.11	611.45	42.673
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.07	609.66	42.693
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.15	611.49	42.823
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.15	611.66	42.884
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.15	611.49	42.917
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.15	611.50	42.939
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.15	611.50	43.043
J-340	568.30	CONDOMINIO RUKAN	0.11	611.45	43.063

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.15	611.49	43.105
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.07	609.74	43.217
J-115	568.13	CONDOMINIO LAS BRISAS 3	0.15	611.65	43.439
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.15	611.55	43.513
J-121	568.03	CONDOMINIO LAS BRISAS 3	0.15	611.64	43.520
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.07	609.70	43.554
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.15	611.49	43.582
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.15	611.57	43.616
J-323	567.67	CONDOMINIO RUKAN	0.11	611.46	43.699
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.15	611.53	43.752
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.07	609.76	43.808
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.15	611.51	43.813
J-359	567.58	CONDOMINIO RUKAN	0.11	611.51	43.843
J-345	567.47	CONDOMINIO RUKAN	0.11	611.47	43.906
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.07	609.74	43.907
J-370	567.56	<None>	0.00	611.56	43.911
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.15	611.49	43.941
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.07	609.69	43.953
J-367	567.48	<None>	0.00	611.57	44.000
J-335	567.32	CONDOMINIO RUKAN	0.11	611.45	44.041
J-350	567.29	<None>	0.00	611.50	44.116
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.07	609.66	44.145
J-344	567.16	CONDOMINIO RUKAN	0.11	611.47	44.219
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.15	611.50	44.225
J-123	567.29	CONDOMINIO LAS BRISAS 3	0.15	611.62	44.237
J-334	566.99	CONDOMINIO RUKAN	0.11	611.45	44.363
J-333	566.93	CONDOMINIO RUKAN	0.11	611.44	44.423
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.15	611.49	44.511
J-114	567.04	CONDOMINIO LAS BRISAS 3	0.15	611.67	44.537
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.15	611.67	44.556
J-352	566.81	CONDOMINIO RUKAN	0.11	611.50	44.597
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.15	611.52	44.611

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.15	611.53	44.677
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.14	611.10	44.756
J-336	566.58	CONDOMINIO RUKAN	0.11	611.45	44.777
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.15	611.49	44.822
J-332	566.49	CONDOMINIO RUKAN	0.11	611.44	44.865
J-322	566.48	CONDOMINIO RUKAN	0.11	611.47	44.894
J-357	566.51	CONDOMINIO RUKAN	0.11	611.50	44.904
J-325	566.45	CONDOMINIO RUKAN	0.11	611.45	44.909
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.15	611.62	44.953
J-122	566.51	CONDOMINIO LAS BRISAS 3	0.15	611.63	45.023
J-358	566.38	CONDOMINIO RUKAN	0.11	611.50	45.032
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.15	611.51	45.094
J-351	566.23	CONDOMINIO RUKAN	0.11	611.50	45.174
J-331	566.08	CONDOMINIO RUKAN	0.11	611.44	45.269
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.15	611.50	45.278
J-337	566.06	CONDOMINIO RUKAN	0.11	611.45	45.303
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.15	611.49	45.322
J-342	566.03	CONDOMINIO RUKAN	0.11	611.45	45.331
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.07	609.74	45.346
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.15	611.49	45.478
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.07	609.66	45.553
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.15	611.49	45.866
J-361	565.53	CONDOMINIO RUKAN	0.11	611.51	45.880
J-377	565.35	CONDOMINIO BORDE BLANCO 2	3.48	611.33	45.892
J-330	565.13	CONDOMINIO RUKAN	0.11	611.45	46.225
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.15	611.49	46.420
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.15	611.49	46.443
J-346	564.90	<None>	0.00	611.47	46.473
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.15	611.49	46.704
J-375	564.57	<None>	0.00	611.39	46.728
J-373	564.55	<None>	0.00	611.45	46.800
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.15	611.49	46.979
J-329	564.22	CONDOMINIO RUKAN	0.11	611.45	47.128
J-362	564.16	CONDOMINIO RUKAN	0.11	611.50	47.253
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.07	609.72	47.369


FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-371	564.00	<None>	0.00	611.50	47.405
J-324	563.73	CONDOMINIO RUKAN	0.11	611.45	47.624
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.07	609.67	47.708
J-356	563.68	CONDOMINIO RUKAN	0.11	611.50	47.724
J-355	563.53	CONDOMINIO RUKAN	0.11	611.50	47.869
J-353	563.38	CONDOMINIO RUKAN	0.11	611.50	48.015
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.07	609.74	48.097
J-354	563.26	CONDOMINIO RUKAN	0.11	611.49	48.134
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.14	611.10	48.231
J-321	563.15	CONDOMINIO RUKAN	0.11	611.48	48.236
J-309	563.07	CONDOMINIO RUKAN	0.11	611.49	48.320
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.07	609.74	48.329
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.07	609.74	48.385
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.15	611.49	48.444
J-319	562.88	CONDOMINIO RUKAN	0.11	611.49	48.510
J-328	562.51	CONDOMINIO RUKAN	0.11	611.45	48.838
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.15	611.49	48.909
J-327	562.22	CONDOMINIO RUKAN	0.11	611.45	49.123
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.15	611.63	49.137
J-326	562.20	CONDOMINIO RUKAN	0.11	611.45	49.148
J-312	562.17	CONDOMINIO RUKAN	0.11	611.49	49.223
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.07	609.67	49.430
J-310	561.96	CONDOMINIO RUKAN	0.11	611.49	49.432
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.15	611.50	49.445
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.14	611.07	49.456
J-320	561.76	CONDOMINIO RUKAN	0.11	611.48	49.621
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.07	609.74	49.637
J-313	561.70	CONDOMINIO RUKAN	0.11	611.49	49.686
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.14	611.08	49.982
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.14	611.07	50.097
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.14	611.07	50.240
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.15	611.62	50.421
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.14	611.09	50.427
J-311	560.78	CONDOMINIO RUKAN	0.11	611.49	50.610
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.15	611.62	50.661

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.14	611.09	50.668
J-314	560.46	CONDOMINIO RUKAN	0.11	611.49	50.926
J-315	560.12	CONDOMINIO RUKAN	0.11	611.48	51.259
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.14	611.09	52.196
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.14	611.08	52.219
J-317	558.84	CONDOMINIO RUKAN	0.11	611.49	52.541
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.14	611.07	52.955
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.15	611.50	53.298
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.14	611.07	53.404
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.15	611.49	53.646
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.14	611.07	54.262
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.14	611.07	54.339
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.15	611.62	54.500
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.14	611.09	54.552
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.14	611.07	54.683
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.15	611.49	54.823
J-316	556.36	CONDOMINIO RUKAN	0.11	611.49	55.016
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.15	611.62	55.029
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.14	611.12	55.047
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.14	611.20	55.278
J-318	555.89	CONDOMINIO RUKAN	0.11	611.49	55.487
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.15	611.62	55.506
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.14	611.31	56.326
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.14	611.31	56.526

New Graph



T-1 - Caudales maximos horarios año 0 - Level (Calculated)

FlexTable: Hydrant Table

Label	Hydrant Status	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
H-5	Open	587.66	0.00	619.99	32.266
H-1	Open	587.58	0.00	620.02	32.368
H-48	Open	586.10	0.00	620.00	33.827
H-52	Open	584.86	0.00	620.02	35.083
H-13	Open	583.85	0.00	619.77	35.848
H-50	Open	583.79	0.00	619.65	35.787
H-2	Open	583.53	0.00	620.02	36.415
H-4	Open	581.61	0.00	620.01	38.319
H-3	Open	581.53	0.00	620.02	38.411
H-12	Open	579.64	0.00	619.96	40.236
H-49	Open	579.63	0.16	619.64	39.932
H-51	Open	579.07	0.00	619.99	40.837
H-14	Open	578.50	0.00	619.74	41.159
H-10	Open	578.19	0.00	619.91	41.635
H-6	Open	576.17	0.00	620.02	43.757
H-9	Open	575.57	0.00	619.99	44.329
H-16	Open	575.02	0.00	619.15	44.045
H-19	Open	574.00	0.00	618.88	44.792
H-18	Open	573.71	0.00	618.89	45.097
H-40	Open	573.54	0.00	619.60	45.974
H-44	Open	573.25	0.00	619.04	45.692
H-38	Open	572.44	0.00	619.60	47.063
H-22	Open	572.25	0.00	619.08	46.740
H-20	Open	572.24	0.00	618.82	46.486
H-17	Open	572.06	0.00	618.92	46.766
H-15	Open	572.00	0.00	619.68	47.579
H-45	Open	570.59	0.00	618.87	48.191
H-26	Open	569.69	0.00	619.61	49.818
H-43	Open	569.30	0.00	619.61	50.218
H-21	Open	568.77	0.00	618.77	49.900
H-47	Open	568.48	0.00	618.73	50.154
H-25	Open	567.49	0.00	619.58	51.985
H-41	Open	567.06	0.00	619.58	52.420
H-27	Open	566.67	0.00	619.62	52.844
H-35	Open	565.34	0.00	619.69	54.241
H-29	Open	564.78	0.00	619.54	54.648
H-28	Open	564.00	0.00	619.59	55.476
H-42	Open	563.62	0.00	619.58	55.841
H-30	Open	563.44	0.00	619.52	55.968
H-39	Open	563.31	0.00	619.60	56.170
H-34	Open	562.75	0.00	619.42	56.553
H-46	Open	561.45	0.00	618.77	57.199
H-37	Open	560.40	0.00	619.40	58.884
H-36	Open	560.34	0.00	619.41	58.944
H-53	Open	560.06	0.00	619.60	59.416
H-24	Open	560.03	0.00	619.59	59.441
H-33	Open	556.11	0.00	619.42	63.182
H-32	Open	555.48	0.00	619.50	63.896
H-31	Open	554.18	0.00	619.51	65.199

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.09	619.99	30.850
J-26	588.78	BRISAS DE CHICUREO NORTE	0.09	619.99	31.155
J-28	588.57	BRISAS DE CHICUREO NORTE	0.09	619.99	31.357
J-18	588.00	BRISAS DE CHICUREO NORTE	0.09	619.99	31.930
J-19	587.16	BRISAS DE CHICUREO NORTE	0.09	619.99	32.765
J-17	587.03	BRISAS DE CHICUREO NORTE	0.09	619.99	32.902
J-11	586.98	BRISAS DE CHICUREO NORTE	0.09	620.00	32.949
J-27	586.55	BRISAS DE CHICUREO NORTE	0.09	619.99	33.374
J-48	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.66	33.594
J-47	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.66	33.594
J-76	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.67	33.602
J-79	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.68	33.608
J-43	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.68	33.616
J-42	586.00	<None>	0.00	619.71	33.638
J-46	585.94	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.66	33.651
J-62	585.86	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	33.713
J-65	585.66	<None>	0.00	619.64	33.911
J-41	585.68	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.72	33.977
J-61	585.46	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	34.114
J-10	585.63	BRISAS DE CHICUREO NORTE	0.09	620.00	34.296
J-16	585.62	BRISAS DE CHICUREO NORTE	0.09	619.99	34.301
J-36	585.36	<None>	0.00	619.76	34.332
J-40	585.05	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.74	34.623
J-66	584.89	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.65	34.690
J-56	584.75	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	34.821
J-80	584.72	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.67	34.880
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.67	34.922
J-37	584.60	<None>	0.00	619.75	35.083
J-24	584.83	BRISAS DE CHICUREO NORTE	0.09	619.99	35.092
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	35.141

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-1	584.67	<None>	0.00	620.02	35.279
J-2	584.49	<None>	0.00	620.02	35.458
J-9	584.37	BRISAS DE CHICUREO NORTE	0.09	620.00	35.560
J-75	583.85	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.66	35.740
J-3	584.18	<None>	0.00	620.02	35.768
J-20	584.07	BRISAS DE CHICUREO NORTE	0.09	619.99	35.856
J-69	583.51	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.65	36.063
J-12	583.81	BRISAS DE CHICUREO NORTE	0.09	619.99	36.107
PCP- 11	583.39	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.65	36.188
J-77	583.34	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.67	36.255
J-15	583.58	BRISAS DE CHICUREO NORTE	0.09	619.99	36.343
J-300	583.11	CONDOMINIO RUKAN	0.07	619.61	36.429
J-21	583.46	BRISAS DE CHICUREO NORTE	0.09	620.00	36.459
J-78	583.10	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.67	36.495
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	36.624
J-45	582.89	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.67	36.705
J-70	582.79	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.65	36.792
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	4.94	619.70	36.821
J-52	582.73	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.65	36.843
J-60	582.59	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.64	36.974
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	36.983
J-405	582.65	SAN LUIS	0.33	619.84	37.121
J-101	582.72	<None>	0.00	620.02	37.226
J-14	582.64	BRISAS DE CHICUREO NORTE	0.09	619.99	37.281
J-73	582.23	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.66	37.362
J-4	582.48	<None>	0.00	620.02	37.455
J-51	581.86	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.65	37.711
J-74	581.81	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.66	37.780
J-67	581.70	CONDOMINIO 2BRISAS- CHICUREO	0.08	619.64	37.870
J-64	581.64	CONDOMINIO 1 BRISAS- CHICUREO	0.16	619.64	37.926
J-13	581.92	BRISAS DE CHICUREO NORTE	0.09	619.99	37.997

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-8	581.84	BRISAS DE CHICUREO NORTE	0.09	620.00	38.090
J-5	581.70	<None>	0.00	620.01	38.232
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	38.291
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	38.366
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.65	38.469
J-23	581.37	BRISAS DE CHICUREO NORTE	0.09	620.00	38.550
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	38.577
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.66	38.725
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	38.861
J-85	581.00	<None>	0.00	619.99	38.902
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	38.945
J-22	580.92	BRISAS DE CHICUREO NORTE	0.09	620.00	38.994
J-364	580.49	CONDOMINIO RUKAN	0.07	619.61	39.044
J-88	580.83	<None>	0.00	619.99	39.086
J-299	580.15	CONDOMINIO RUKAN	0.07	619.63	39.398
J-89	580.51	<None>	0.00	619.99	39.407
J-84	580.42	<None>	0.00	619.98	39.483
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.65	39.617
J-97	580.31	<None>	0.00	620.02	39.626
J-87	580.27	<None>	0.00	619.99	39.638
J-39	580.14	<None>	0.00	619.94	39.723
J-81	580.00	<None>	0.00	619.95	39.871
J-82	580.00	<None>	0.00	619.96	39.880
J-86	580.00	<None>	0.00	619.99	39.905
J-93	580.00	<None>	0.00	620.00	39.922
J-94	580.00	<None>	0.00	620.00	39.922
J-91	579.93	<None>	0.00	620.00	39.983
J-83	579.67	<None>	0.00	619.97	40.223
J-98	579.66	<None>	0.00	620.02	40.279
J-29	579.64	<None>	0.00	620.02	40.298
J-92	579.33	<None>	0.00	620.00	40.590
J-90	579.31	<None>	0.00	619.99	40.603
J-112	579.30	<None>	0.00	620.02	40.637
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	40.743
J-54	578.81	CONDOMINIO 1 BRISAS-CHICUREO	0.16	619.64	40.755
J-72	578.80	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.65	40.776
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.08	619.64	40.856
J-301	578.67	CONDOMINIO RUKAN	0.07	619.61	40.862
J-298	578.65	CONDOMINIO RUKAN	0.07	619.64	40.906

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-102	578.94	<None>	0.00	620.02	40.995
J-6	578.90	BRISAS DE CHICUREO NORTE	0.09	620.01	41.031
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	620.00	41.163
J-109	578.73	<None>	0.00	620.00	41.192
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	619.99	41.412
J-7	578.48	BRISAS DE CHICUREO NORTE	0.09	620.01	41.442
J-95	578.40	<None>	0.00	620.01	41.529
J-304	577.89	CONDOMINIO RUKAN	0.07	619.63	41.652
J-111	578.22	<None>	0.00	620.02	41.712
J-104	578.17	<None>	0.00	620.02	41.767
J-96	577.74	<None>	0.00	620.02	42.192
J-100	577.57	<None>	0.00	620.02	42.359
J-105	577.42	<None>	0.00	620.02	42.509
J-99	577.36	<None>	0.00	620.02	42.567
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.77	42.686
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.77	42.688
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.78	42.691
J-253	576.00	CONDOMINIO LA SIEMBRA	0.15	618.87	42.783
J-35	576.93	<None>	0.00	619.96	42.947
J-291	576.00	CONDOMINIO LA TRILLA	0.14	619.04	42.952
J-242	575.72	CONDOMINIO LA SIEMBRA	0.15	618.87	43.058
J-277	575.74	CONDOMINIO LA TRILLA	0.14	619.04	43.213
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.04	618.77	43.360
J-303	575.85	CONDOMINIO RUKAN	0.07	619.61	43.674
J-305	575.80	CONDOMINIO RUKAN	0.07	619.62	43.739
J-363	575.69	CONDOMINIO RUKAN	0.07	619.61	43.828
J-297	575.70	CONDOMINIO RUKAN	0.07	619.65	43.860
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.04	618.73	43.904
J-173	575.06	<None>	0.00	619.16	44.015
J-106	575.90	<None>	0.00	620.02	44.030
J-34	575.78	<None>	0.00	619.99	44.130
J-103	575.79	<None>	0.00	620.02	44.145
J-258	574.89	<None>	0.00	619.14	44.165
J-267	574.77	CONDOMINIO LA TRILLA	0.14	619.04	44.180
J-33	575.65	<None>	0.00	620.01	44.270
J-287	574.68	CONDOMINIO LA TRILLA	0.14	619.04	44.272
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.04	618.77	44.285
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.04	618.77	44.285
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.04	618.77	44.437
J-292	574.50	CONDOMINIO LA TRILLA	0.14	619.03	44.446

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-259	574.54	<None>	0.00	619.12	44.493
J-245	574.28	CONDOMINIO LA SIEMBRA	0.15	618.87	44.496
J-254	574.24	CONDOMINIO LA SIEMBRA	0.15	618.87	44.542
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.04	618.73	44.642
J-264	574.31	CONDOMINIO LA TRILLA	0.14	619.05	44.651
J-289	574.20	CONDOMINIO LA TRILLA	0.14	619.05	44.760
J-233	574.00	CONDOMINIO LA SIEMBRA	0.15	618.87	44.784
J-232	574.00	CONDOMINIO LA SIEMBRA	0.15	618.88	44.785
J-231	574.00	CONDOMINIO LA SIEMBRA	0.15	618.88	44.785
J-257	574.00	CONDOMINIO LA SIEMBRA	0.15	618.88	44.786
J-290	574.15	CONDOMINIO LA TRILLA	0.14	619.04	44.798
J-268	574.09	CONDOMINIO LA TRILLA	0.14	619.04	44.853
J-283	574.00	CONDOMINIO LA TRILLA	0.14	619.03	44.948
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.04	618.78	44.957
J-274	573.93	CONDOMINIO LA TRILLA	0.14	619.05	45.032
J-284	573.82	CONDOMINIO LA TRILLA	0.14	619.04	45.127
J-30	574.69	<None>	0.00	620.02	45.240
J-263	573.68	CONDOMINIO LA TRILLA	0.14	619.06	45.284
J-237	573.42	CONDOMINIO LA SIEMBRA	0.15	618.87	45.359
J-256	573.36	CONDOMINIO LA SIEMBRA	0.15	618.88	45.430
J-339	574.08	CONDOMINIO RUKAN	0.07	619.60	45.432
J-107	574.43	<None>	0.00	620.02	45.496
J-307	573.85	CONDOMINIO RUKAN	0.07	619.60	45.665
J-407	574.27	<None>	0.00	620.05	45.682
J-230	573.06	CONDOMINIO LA SIEMBRA	0.15	618.88	45.724
J-273	573.20	CONDOMINIO LA TRILLA	0.14	619.05	45.750
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.04	618.77	45.787
J-236	572.96	CONDOMINIO LA SIEMBRA	0.15	618.87	45.822
J-235	572.84	CONDOMINIO LA SIEMBRA	0.15	618.88	45.941
J-266	572.94	CONDOMINIO LA TRILLA	0.14	619.04	46.007
J-269	572.92	CONDOMINIO LA TRILLA	0.14	619.04	46.028
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.10	619.61	46.039
J-286	572.84	CONDOMINIO LA TRILLA	0.14	619.04	46.103
J-365	573.40	CONDOMINIO RUKAN	0.07	619.60	46.107
J-347	573.38	CONDOMINIO RUKAN	0.07	619.60	46.126
J-349	573.30	CONDOMINIO RUKAN	0.07	619.60	46.203
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.04	618.77	46.224
J-285	572.69	CONDOMINIO LA TRILLA	0.14	619.04	46.253

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-255	572.50	CONDOMINIO LA SIEMBRA	0.15	618.88	46.282
J-275	572.54	CONDOMINIO LA TRILLA	0.14	619.04	46.414
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.04	618.73	46.462
J-234	572.29	CONDOMINIO LA SIEMBRA	0.15	618.88	46.496
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.04	618.77	46.500
J-238	572.25	CONDOMINIO LA SIEMBRA	0.15	618.88	46.536
J-262	572.35	<None>	0.00	619.08	46.641
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.04	618.78	46.706
J-229	572.00	CONDOMINIO LA SIEMBRA	0.15	618.88	46.787
J-239	571.97	CONDOMINIO LA SIEMBRA	0.15	618.87	46.809
J-249	571.94	CONDOMINIO LA SIEMBRA	0.15	618.88	46.849
J-240	571.92	CONDOMINIO LA SIEMBRA	0.15	618.87	46.858
J-293	572.06	<None>	0.00	619.08	46.928
J-406	572.89	<None>	0.00	620.03	47.040
J-32	572.86	<None>	0.00	620.02	47.061
J-31	572.85	<None>	0.00	620.03	47.085
J-272	571.78	CONDOMINIO LA TRILLA	0.14	619.04	47.168
J-250	571.58	CONDOMINIO LA SIEMBRA	0.15	618.87	47.194
J-174	571.62	<None>	0.00	618.93	47.213
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.04	618.79	47.241
J-228	571.51	CONDOMINIO LA SIEMBRA	0.15	618.89	47.283
J-265	571.65	CONDOMINIO LA TRILLA	0.14	619.04	47.289
J-260	571.62	<None>	0.00	619.10	47.380
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.04	618.77	47.446
J-244	571.26	CONDOMINIO LA SIEMBRA	0.15	618.87	47.511
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.10	619.67	47.571
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.04	618.73	47.682
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.10	619.68	47.703
J-261	571.29	<None>	0.00	619.10	47.713
J-247	571.03	CONDOMINIO LA SIEMBRA	0.15	618.87	47.747
J-251	570.94	CONDOMINIO LA SIEMBRA	0.15	618.87	47.838
J-246	570.92	CONDOMINIO LA SIEMBRA	0.15	618.87	47.853
J-276	571.05	CONDOMINIO LA TRILLA	0.14	619.04	47.892

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.04	618.80	47.940
J-163	571.57	CONDOMINIO LAS BRISAS 3	0.10	619.66	47.986
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.10	619.60	48.066
J-241	570.57	CONDOMINIO LA SIEMBRA	0.15	618.87	48.207
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.04	618.77	48.249
J-175	570.44	<None>	0.00	618.81	48.271
J-279	570.60	CONDOMINIO LA TRILLA	0.14	619.04	48.344
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.10	619.61	48.363
J-162	571.04	CONDOMINIO LAS BRISAS 3	0.10	619.66	48.519
J-348	570.98	CONDOMINIO RUKAN	0.07	619.60	48.523
J-113	571.08	<None>	0.00	619.71	48.535
J-271	570.38	CONDOMINIO LA TRILLA	0.14	619.04	48.565
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.10	619.67	48.670
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.04	618.73	48.732
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.04	618.73	48.756
J-243	570.00	CONDOMINIO LA SIEMBRA	0.15	618.87	48.772
J-248	570.00	CONDOMINIO LA SIEMBRA	0.15	618.88	48.777
J-252	570.00	CONDOMINIO LA SIEMBRA	0.15	618.88	48.780
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.10	619.66	48.905
J-308	570.59	CONDOMINIO RUKAN	0.07	619.60	48.910
J-270	570.00	CONDOMINIO LA TRILLA	0.14	619.04	48.939
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.04	618.73	49.007
J-278	569.90	CONDOMINIO LA TRILLA	0.14	619.04	49.039
J-360	570.45	CONDOMINIO RUKAN	0.07	619.61	49.054
J-161	570.30	CONDOMINIO LAS BRISAS 3	0.10	619.66	49.254
J-282	569.56	CONDOMINIO LA TRILLA	0.14	619.03	49.379
J-302	570.02	CONDOMINIO RUKAN	0.07	619.61	49.485
J-296	570.00	<None>	0.00	619.65	49.554
J-160	569.98	CONDOMINIO LAS BRISAS 3	0.10	619.66	49.577
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.04	618.81	49.762
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.04	618.73	49.793
J-306	569.69	CONDOMINIO RUKAN	0.07	619.61	49.817
J-281	569.04	CONDOMINIO LA TRILLA	0.14	619.03	49.896
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.04	618.78	49.948
J-294	569.53	<None>	0.00	619.65	50.021

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-295	569.50	<None>	0.00	619.65	50.054
J-343	569.39	CONDOMINIO RUKAN	0.07	619.59	50.098
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.10	619.62	50.122
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.04	618.79	50.129
J-366	569.22	CONDOMINIO RUKAN	0.07	619.60	50.280
J-280	568.45	CONDOMINIO LA TRILLA	0.14	619.04	50.484
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.04	618.81	50.537
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.10	619.61	50.616
J-338	568.83	CONDOMINIO RUKAN	0.07	619.59	50.654
J-341	568.69	CONDOMINIO RUKAN	0.07	619.58	50.783
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.10	619.68	50.883
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.10	619.60	50.913
J-404	567.81	REMANSO DE CHICUREO	0.16	618.85	50.938
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.10	619.60	51.007
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.10	619.60	51.026
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.04	618.73	51.077
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.04	618.73	51.108
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.10	619.60	51.126
J-340	568.30	CONDOMINIO RUKAN	0.07	619.58	51.173
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.10	619.60	51.193
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.04	618.73	51.358
J-115	568.13	CONDOMINIO LAS BRISAS 3	0.10	619.67	51.442
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.04	618.77	51.450
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.04	618.80	51.462
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.04	618.73	51.512
J-121	568.03	CONDOMINIO LAS BRISAS 3	0.10	619.67	51.531
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.10	619.62	51.573
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.10	619.63	51.666
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.10	619.60	51.671
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.04	618.73	51.745
J-323	567.67	CONDOMINIO RUKAN	0.07	619.58	51.807
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.10	619.61	51.823

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.10	619.61	51.892
J-359	567.58	CONDOMINIO RUKAN	0.07	619.61	51.921
J-370	567.56	<None>	0.00	619.63	51.966
J-345	567.47	CONDOMINIO RUKAN	0.07	619.59	52.007
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.10	619.60	52.031
J-367	567.48	<None>	0.00	619.64	52.046
J-335	567.32	CONDOMINIO RUKAN	0.07	619.58	52.154
J-350	567.29	<None>	0.00	619.60	52.202
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.04	618.77	52.229
J-123	567.29	CONDOMINIO LAS BRISAS 3	0.10	619.66	52.261
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.10	619.60	52.308
J-344	567.16	CONDOMINIO RUKAN	0.07	619.59	52.320
J-334	566.99	CONDOMINIO RUKAN	0.07	619.58	52.476
J-114	567.04	CONDOMINIO LAS BRISAS 3	0.10	619.68	52.532
J-333	566.93	CONDOMINIO RUKAN	0.07	619.57	52.537
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.10	619.68	52.551
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.04	618.75	52.587
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.10	619.60	52.599
J-352	566.81	CONDOMINIO RUKAN	0.07	619.60	52.684
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.10	619.61	52.686
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.10	619.61	52.748
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.04	618.78	52.812
J-336	566.58	CONDOMINIO RUKAN	0.07	619.58	52.891
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.10	619.60	52.911
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.04	618.77	52.920
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.10	619.66	52.977
J-332	566.49	CONDOMINIO RUKAN	0.07	619.57	52.979
J-357	566.51	CONDOMINIO RUKAN	0.07	619.60	52.988
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.04	618.74	52.993
J-322	566.48	CONDOMINIO RUKAN	0.07	619.58	52.997
J-325	566.45	CONDOMINIO RUKAN	0.07	619.58	53.020
J-122	566.51	CONDOMINIO LAS BRISAS 3	0.10	619.66	53.041
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.10	619.41	53.049
J-358	566.38	CONDOMINIO RUKAN	0.07	619.60	53.116
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.10	619.61	53.174

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.04	618.73	53.201
J-351	566.23	CONDOMINIO RUKAN	0.07	619.60	53.261
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.10	619.60	53.364
J-331	566.08	CONDOMINIO RUKAN	0.07	619.57	53.383
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.10	619.60	53.411
J-337	566.06	CONDOMINIO RUKAN	0.07	619.58	53.412
J-342	566.03	CONDOMINIO RUKAN	0.07	619.58	53.442
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.10	619.60	53.567
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.10	619.60	53.955
J-361	565.53	CONDOMINIO RUKAN	0.07	619.60	53.961
J-377	565.35	CONDOMINIO BORDE BLANCO 2	2.32	619.52	54.064
J-330	565.13	CONDOMINIO RUKAN	0.07	619.58	54.338
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.04	618.77	54.358
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.10	619.60	54.510
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.10	619.60	54.532
J-346	564.90	<None>	0.00	619.59	54.574
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.04	618.73	54.609
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.10	619.60	54.793
J-375	564.57	<None>	0.00	619.55	54.870
J-373	564.55	<None>	0.00	619.58	54.914
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.10	619.60	55.069
J-329	564.22	CONDOMINIO RUKAN	0.07	619.58	55.240
J-362	564.16	CONDOMINIO RUKAN	0.07	619.60	55.336
J-371	564.00	<None>	0.00	619.60	55.489
J-324	563.73	CONDOMINIO RUKAN	0.07	619.58	55.735
J-356	563.68	CONDOMINIO RUKAN	0.07	619.60	55.808
J-355	563.53	CONDOMINIO RUKAN	0.07	619.60	55.955
J-353	563.38	CONDOMINIO RUKAN	0.07	619.60	56.102
J-354	563.26	CONDOMINIO RUKAN	0.07	619.60	56.223
J-321	563.15	CONDOMINIO RUKAN	0.07	619.59	56.330
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.04	618.76	56.391
J-309	563.07	CONDOMINIO RUKAN	0.07	619.60	56.409
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.10	619.41	56.529
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.10	619.60	56.533
J-319	562.88	CONDOMINIO RUKAN	0.07	619.60	56.600
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.04	618.74	56.758
J-328	562.51	CONDOMINIO RUKAN	0.07	619.58	56.951
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.10	619.60	56.998

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.04	618.77	57.109
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.10	619.66	57.155
J-327	562.22	CONDOMINIO RUKAN	0.07	619.58	57.236
J-326	562.20	CONDOMINIO RUKAN	0.07	619.58	57.260
J-312	562.17	CONDOMINIO RUKAN	0.07	619.60	57.313
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.04	618.77	57.343
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.04	618.77	57.398
J-310	561.96	CONDOMINIO RUKAN	0.07	619.60	57.521
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.10	619.60	57.529
J-320	561.76	CONDOMINIO RUKAN	0.07	619.59	57.715
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.10	619.40	57.765
J-313	561.70	CONDOMINIO RUKAN	0.07	619.59	57.777
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.10	619.40	58.288
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.10	619.40	58.406
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.10	619.66	58.442
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.04	618.74	58.481
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.10	619.40	58.549
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.04	618.77	58.650
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.10	619.66	58.685
J-311	560.78	CONDOMINIO RUKAN	0.07	619.60	58.700
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.10	619.41	58.727
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.10	619.41	58.971
J-314	560.46	CONDOMINIO RUKAN	0.07	619.59	59.018
J-315	560.12	CONDOMINIO RUKAN	0.07	619.59	59.351
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.10	619.41	60.497
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.10	619.40	60.524
J-317	558.84	CONDOMINIO RUKAN	0.07	619.59	60.633
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.10	619.40	61.268
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.10	619.60	61.384
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.10	619.40	61.716
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.10	619.60	61.735
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.10	619.66	62.522

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.10	619.40	62.576
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.10	619.40	62.653
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.10	619.41	62.852
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.10	619.60	62.910
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.10	619.40	62.996
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.10	619.66	63.052
J-316	556.36	CONDOMINIO RUKAN	0.07	619.59	63.108
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.10	619.42	63.332
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.10	619.46	63.523
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.10	619.66	63.529
J-318	555.89	CONDOMINIO RUKAN	0.07	619.60	63.577
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.10	619.51	64.513
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.10	619.51	64.714

AÑO 5

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.13	613.17	24.042
J-26	588.78	BRISAS DE CHICUREO NORTE	0.13	613.15	24.328
J-28	588.57	BRISAS DE CHICUREO NORTE	3.15	613.12	24.499
J-18	588.00	BRISAS DE CHICUREO NORTE	0.13	613.23	25.180
J-19	587.16	BRISAS DE CHICUREO NORTE	0.13	613.23	26.014
J-17	587.03	BRISAS DE CHICUREO NORTE	0.13	613.20	26.117
J-11	586.98	BRISAS DE CHICUREO NORTE	0.13	613.25	26.219
J-27	586.55	BRISAS DE CHICUREO NORTE	0.13	613.14	26.529
J-48	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.84	26.791
J-47	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.85	26.791
J-76	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.86	26.807
J-79	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.87	26.820
J-43	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.89	26.836
J-46	585.94	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.85	26.849
J-42	586.00	<None>	0.00	612.94	26.883
J-62	585.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	26.886
J-65	585.66	<None>	0.00	612.81	27.087
J-36	585.36	<None>	0.84	612.59	27.173
J-41	585.68	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.97	27.238
J-16	585.62	BRISAS DE CHICUREO NORTE	3.15	612.95	27.274
J-61	585.46	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	27.286
J-10	585.63	BRISAS DE CHICUREO NORTE	0.13	613.28	27.594
J-66	584.89	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.81	27.869
J-40	585.05	CONDOMINIO 2BRISAS-CHICUREO	0.12	613.00	27.902
J-56	584.75	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	27.996
J-80	584.72	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.85	28.081
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.87	28.132
J-1	584.67	<None>	5.23	613.01	28.284
J-24	584.83	BRISAS DE CHICUREO NORTE	0.13	613.19	28.301

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	28.313
J-37	584.60	<None>	0.00	613.04	28.381
J-2	584.49	<None>	0.00	613.01	28.464
J-3	584.18	<None>	0.00	613.01	28.774
J-300	583.11	CONDOMINIO RUKAN	0.11	611.99	28.827
J-9	584.37	BRISAS DE CHICUREO NORTE	0.13	613.34	28.915
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.85	28.939
J-20	584.07	BRISAS DE CHICUREO NORTE	0.13	613.23	29.105
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.82	29.248
J-12	583.81	BRISAS DE CHICUREO NORTE	0.13	613.21	29.336
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.82	29.372
J-15	583.58	BRISAS DE CHICUREO NORTE	0.13	613.03	29.391
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.86	29.460
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.86	29.700
J-21	583.46	BRISAS DE CHICUREO NORTE	0.13	613.25	29.730
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.85	29.905
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.83	29.981
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.82	30.028
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	7.37	612.92	30.059
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.48	30.128
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	30.146
J-405	582.65	SAN LUIS	1.33	612.91	30.204
J-14	582.64	BRISAS DE CHICUREO NORTE	0.13	613.16	30.463
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.48	30.488
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.85	30.560
J-101	582.72	<None>	0.14	613.62	30.842
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.82	30.896
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.85	30.978
J-4	582.48	<None>	0.00	613.58	31.031
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.81	31.048

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	31.097
J-13	581.92	BRISAS DE CHICUREO NORTE	0.13	613.18	31.193
J-364	580.49	CONDOMINIO RUKAN	0.11	611.99	31.443
J-8	581.84	BRISAS DE CHICUREO NORTE	0.13	613.42	31.519
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	31.539
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.83	31.657
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.80	31.753
J-5	581.70	<None>	0.00	613.53	31.760
J-23	581.37	BRISAS DE CHICUREO NORTE	0.13	613.20	31.772
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.48	31.796
J-299	580.15	CONDOMINIO RUKAN	0.11	612.02	31.813
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.84	31.917
J-22	580.92	BRISAS DE CHICUREO NORTE	0.13	613.23	32.245
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.48	32.365
J-85	581.00	<None>	0.14	613.50	32.427
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.49	32.455
J-88	580.83	<None>	0.14	613.51	32.615
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.83	32.804
J-89	580.51	<None>	0.14	613.51	32.935
J-84	580.42	<None>	0.14	613.49	33.009
J-87	580.27	<None>	0.14	613.50	33.161
J-39	580.14	<None>	0.14	613.44	33.228
J-97	580.31	<None>	0.14	613.61	33.229
J-301	578.67	CONDOMINIO RUKAN	0.11	611.99	33.260
J-298	578.65	CONDOMINIO RUKAN	0.11	612.05	33.335
J-81	580.00	<None>	0.14	613.45	33.380
J-82	580.00	<None>	0.14	613.46	33.396
J-86	580.00	<None>	0.14	613.50	33.428
J-94	580.00	<None>	0.14	613.54	33.471
J-93	580.00	<None>	0.14	613.54	33.471
J-91	579.93	<None>	0.14	613.52	33.522
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.76	33.693
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.76	33.697
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.07	609.77	33.701
J-83	579.67	<None>	0.14	613.49	33.752
J-98	579.66	<None>	0.14	613.61	33.882

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-253	576.00	CONDOMINIO LA SIEMBRA	0.22	609.96	33.895
J-29	579.64	<None>	0.14	613.61	33.902
J-54	578.81	CONDOMINIO 1 BRISAS-CHICUREO	0.23	612.81	33.931
J-72	578.80	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.83	33.964
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.12	612.81	34.034
J-304	577.89	CONDOMINIO RUKAN	0.11	612.02	34.066
J-90	579.31	<None>	0.14	613.51	34.131
J-92	579.33	<None>	0.14	613.54	34.141
J-242	575.72	CONDOMINIO LA SIEMBRA	0.22	609.96	34.170
J-291	576.00	CONDOMINIO LA TRILLA	0.21	610.29	34.216
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.49	34.254
J-112	579.30	<None>	0.14	613.62	34.256
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.07	609.76	34.365
J-277	575.74	CONDOMINIO LA TRILLA	0.21	610.29	34.481
J-6	578.90	BRISAS DE CHICUREO NORTE	0.13	613.51	34.548
J-102	578.94	<None>	0.14	613.62	34.611
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.49	34.674
J-109	578.73	<None>	0.14	613.57	34.776
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.07	609.67	34.864
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.18	613.49	34.920
J-7	578.48	BRISAS DE CHICUREO NORTE	0.13	613.51	34.960
J-95	578.40	<None>	0.14	613.58	35.107
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.07	609.76	35.288
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.07	609.76	35.291
J-111	578.22	<None>	0.14	613.62	35.330
J-104	578.17	<None>	0.14	613.62	35.387
J-267	574.77	CONDOMINIO LA TRILLA	0.21	610.28	35.441
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.07	609.76	35.443
J-173	575.06	<None>	0.84	610.65	35.520
J-287	574.68	CONDOMINIO LA TRILLA	0.21	610.29	35.538
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.07	609.68	35.604
J-245	574.28	CONDOMINIO LA SIEMBRA	0.22	609.96	35.609
J-258	574.89	<None>	0.00	610.57	35.612
J-254	574.24	CONDOMINIO LA SIEMBRA	0.22	609.97	35.656
J-292	574.50	CONDOMINIO LA TRILLA	0.21	610.28	35.705

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-96	577.74	<None>	0.14	613.61	35.796
J-259	574.54	<None>	0.84	610.50	35.885
J-233	574.00	CONDOMINIO LA SIEMBRA	0.22	609.98	35.903
J-232	574.00	CONDOMINIO LA SIEMBRA	0.22	609.98	35.903
J-231	574.00	CONDOMINIO LA SIEMBRA	0.22	609.98	35.904
J-257	574.00	CONDOMINIO LA SIEMBRA	0.22	609.98	35.906
J-264	574.31	CONDOMINIO LA TRILLA	0.21	610.30	35.924
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.07	609.77	35.970
J-100	577.57	<None>	0.14	613.62	35.976
J-289	574.20	CONDOMINIO LA TRILLA	0.21	610.30	36.032
J-290	574.15	CONDOMINIO LA TRILLA	0.21	610.28	36.059
J-303	575.85	CONDOMINIO RUKAN	0.11	611.99	36.071
J-268	574.09	CONDOMINIO LA TRILLA	0.21	610.28	36.114
J-105	577.42	<None>	0.14	613.63	36.129
J-305	575.80	CONDOMINIO RUKAN	0.11	612.02	36.151
J-99	577.36	<None>	0.14	613.62	36.179
J-283	574.00	CONDOMINIO LA TRILLA	0.21	610.28	36.208
J-363	575.69	CONDOMINIO RUKAN	0.11	611.99	36.227
J-297	575.70	CONDOMINIO RUKAN	0.11	612.08	36.301
J-274	573.93	CONDOMINIO LA TRILLA	0.21	610.31	36.308
J-284	573.82	CONDOMINIO LA TRILLA	0.21	610.28	36.388
J-35	576.93	<None>	0.14	613.41	36.403
J-237	573.42	CONDOMINIO LA SIEMBRA	0.22	609.97	36.477
J-256	573.36	CONDOMINIO LA SIEMBRA	0.22	609.98	36.550
J-263	573.68	CONDOMINIO LA TRILLA	0.21	610.32	36.568
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.07	609.75	36.790
J-230	573.06	CONDOMINIO LA SIEMBRA	0.22	609.98	36.845
J-236	572.96	CONDOMINIO LA SIEMBRA	0.22	609.97	36.939
J-273	573.20	CONDOMINIO LA TRILLA	0.21	610.30	37.021
J-235	572.84	CONDOMINIO LA SIEMBRA	0.22	609.98	37.060
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.07	609.76	37.230
J-266	572.94	CONDOMINIO LA TRILLA	0.21	610.28	37.269
J-269	572.92	CONDOMINIO LA TRILLA	0.21	610.28	37.289
J-286	572.84	CONDOMINIO LA TRILLA	0.21	610.28	37.364
J-255	572.50	CONDOMINIO LA SIEMBRA	0.22	609.98	37.404
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.07	609.68	37.424
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.07	609.76	37.506
J-285	572.69	CONDOMINIO LA TRILLA	0.21	610.28	37.513

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-234	572.29	CONDOMINIO LA SIEMBRA	0.22	609.98	37.617
J-106	575.90	<None>	0.14	613.63	37.654
J-238	572.25	CONDOMINIO LA SIEMBRA	0.22	609.98	37.656
J-275	572.54	CONDOMINIO LA TRILLA	0.21	610.30	37.684
J-34	575.78	<None>	0.14	613.54	37.686
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.07	609.77	37.717
J-103	575.79	<None>	0.14	613.64	37.781
J-339	574.08	CONDOMINIO RUKAN	0.11	611.97	37.819
J-33	575.65	<None>	0.14	613.58	37.862
J-229	572.00	CONDOMINIO LA SIEMBRA	0.22	609.99	37.913
J-239	571.97	CONDOMINIO LA SIEMBRA	0.22	609.97	37.923
J-262	572.35	<None>	0.00	610.37	37.950
J-240	571.92	CONDOMINIO LA SIEMBRA	0.22	609.96	37.970
J-249	571.94	CONDOMINIO LA SIEMBRA	0.22	609.99	37.974
J-307	573.85	CONDOMINIO RUKAN	0.11	611.98	38.056
J-293	572.06	<None>	0.84	610.37	38.233
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.07	609.80	38.266
J-250	571.58	CONDOMINIO LA SIEMBRA	0.22	609.97	38.309
J-174	571.62	<None>	0.84	610.09	38.389
J-228	571.51	CONDOMINIO LA SIEMBRA	0.22	610.00	38.414
J-272	571.78	CONDOMINIO LA TRILLA	0.21	610.30	38.438
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.07	609.75	38.448
J-365	573.40	CONDOMINIO RUKAN	0.11	611.98	38.498
J-347	573.38	CONDOMINIO RUKAN	0.11	611.97	38.514
J-265	571.65	CONDOMINIO LA TRILLA	0.21	610.28	38.553
J-349	573.30	CONDOMINIO RUKAN	0.11	611.97	38.590
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.14	612.15	38.592
J-244	571.26	CONDOMINIO LA SIEMBRA	0.22	609.97	38.624
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.07	609.67	38.642
J-260	571.62	<None>	0.00	610.42	38.719
J-247	571.03	CONDOMINIO LA SIEMBRA	0.22	609.97	38.862
J-30	574.69	<None>	0.14	613.64	38.875
J-251	570.94	CONDOMINIO LA SIEMBRA	0.22	609.97	38.956
J-246	570.92	CONDOMINIO LA SIEMBRA	0.22	609.97	38.966
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.07	609.82	38.976

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-261	571.29	<None>	0.84	610.42	39.049
J-107	574.43	<None>	0.14	613.64	39.125
J-276	571.05	CONDOMINIO LA TRILLA	0.21	610.28	39.156
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.07	609.75	39.251
J-241	570.57	CONDOMINIO LA SIEMBRA	0.22	609.96	39.319
J-175	570.44	<None>	0.00	609.85	39.323
J-407	574.27	<None>	0.00	613.78	39.424
J-279	570.60	CONDOMINIO LA TRILLA	0.21	610.28	39.607
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.07	609.67	39.692
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.07	609.67	39.717
J-271	570.38	CONDOMINIO LA TRILLA	0.21	610.28	39.828
J-243	570.00	CONDOMINIO LA SIEMBRA	0.22	609.96	39.884
J-248	570.00	CONDOMINIO LA SIEMBRA	0.22	609.98	39.895
J-252	570.00	CONDOMINIO LA SIEMBRA	0.22	609.98	39.903
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.07	609.67	39.967
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.14	612.28	40.194
J-270	570.00	CONDOMINIO LA TRILLA	0.21	610.28	40.203
J-278	569.90	CONDOMINIO LA TRILLA	0.21	610.29	40.303
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.14	612.29	40.329
J-163	571.57	CONDOMINIO LAS BRISAS 3	0.14	612.25	40.591
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.14	612.13	40.612
J-282	569.56	CONDOMINIO LA TRILLA	0.21	610.28	40.638
J-32	572.86	<None>	0.14	613.64	40.697
J-406	572.89	<None>	0.00	613.68	40.703
J-31	572.85	<None>	0.14	613.66	40.736
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.07	609.68	40.755
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.07	609.84	40.808
J-348	570.98	CONDOMINIO RUKAN	0.11	611.97	40.910
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.14	612.15	40.916
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.07	609.78	40.967
J-162	571.04	CONDOMINIO LAS BRISAS 3	0.14	612.25	41.123
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.07	609.80	41.155
J-281	569.04	CONDOMINIO LA TRILLA	0.21	610.28	41.156
J-113	571.08	<None>	3.08	612.36	41.198

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.14	612.28	41.294
J-308	570.59	CONDOMINIO RUKAN	0.11	611.97	41.297
J-360	570.45	CONDOMINIO RUKAN	0.11	611.99	41.448
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.14	612.25	41.510
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.07	609.83	41.580
J-280	568.45	CONDOMINIO LA TRILLA	0.21	610.28	41.744
J-161	570.30	CONDOMINIO LAS BRISAS 3	0.14	612.25	41.858
J-302	570.02	CONDOMINIO RUKAN	0.11	611.99	41.883
J-296	570.00	<None>	0.00	612.08	41.998
J-404	567.81	REMANSO DE CHICUREO	0.24	609.93	42.032
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.07	609.67	42.038
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.07	609.67	42.069
J-160	569.98	CONDOMINIO LAS BRISAS 3	0.14	612.25	42.181
J-306	569.69	CONDOMINIO RUKAN	0.11	611.99	42.216
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.07	609.67	42.318
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.07	609.76	42.455
J-294	569.53	<None>	2.23	612.08	42.465
J-343	569.39	CONDOMINIO RUKAN	0.11	611.94	42.469
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.07	609.67	42.473
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.07	609.81	42.496
J-295	569.50	<None>	0.00	612.08	42.497
J-366	569.22	CONDOMINIO RUKAN	0.11	611.98	42.671
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.14	612.16	42.683
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.07	609.68	42.709
J-338	568.83	CONDOMINIO RUKAN	0.11	611.94	43.027
J-341	568.69	CONDOMINIO RUKAN	0.11	611.93	43.146
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.14	612.15	43.169
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.07	609.75	43.232
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.14	612.12	43.453
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.14	612.29	43.512
J-340	568.30	CONDOMINIO RUKAN	0.11	611.93	43.536
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.14	612.12	43.547
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.14	612.13	43.569

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.07	609.72	43.570
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.14	612.13	43.673
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.14	612.13	43.735
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.07	609.77	43.823
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.07	609.75	43.922
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.07	609.70	43.969
J-115	568.13	CONDOMINIO LAS BRISAS 3	0.14	612.28	44.067
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.14	612.18	44.142
J-121	568.03	CONDOMINIO LAS BRISAS 3	0.14	612.27	44.148
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.07	609.67	44.161
J-323	567.67	CONDOMINIO RUKAN	0.11	611.93	44.172
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.14	612.12	44.212
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.14	612.20	44.245
J-370	567.56	<None>	0.00	611.93	44.287
J-359	567.58	CONDOMINIO RUKAN	0.11	611.99	44.315
J-345	567.47	CONDOMINIO RUKAN	0.11	611.94	44.379
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.14	612.16	44.382
J-367	567.48	<None>	2.23	611.97	44.394
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.14	612.14	44.443
J-335	567.32	CONDOMINIO RUKAN	0.11	611.92	44.514
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.14	612.12	44.571
J-350	567.29	<None>	0.00	611.97	44.589
J-344	567.16	CONDOMINIO RUKAN	0.11	611.94	44.692
J-334	566.99	CONDOMINIO RUKAN	0.11	611.92	44.835
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.14	612.13	44.854
J-123	567.29	CONDOMINIO LAS BRISAS 3	0.14	612.25	44.865
J-333	566.93	CONDOMINIO RUKAN	0.11	611.92	44.896
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.14	611.36	45.009
J-352	566.81	CONDOMINIO RUKAN	0.11	611.97	45.069
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.14	612.12	45.141
J-114	567.04	CONDOMINIO LAS BRISAS 3	0.14	612.30	45.165
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.14	612.30	45.184

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.14	612.15	45.240
J-336	566.58	CONDOMINIO RUKAN	0.11	611.92	45.250
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.14	612.16	45.307
J-332	566.49	CONDOMINIO RUKAN	0.11	611.92	45.338
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.07	609.75	45.361
J-322	566.48	CONDOMINIO RUKAN	0.11	611.94	45.367
J-357	566.51	CONDOMINIO RUKAN	0.11	611.98	45.376
J-325	566.45	CONDOMINIO RUKAN	0.11	611.92	45.382
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.14	612.12	45.451
J-358	566.38	CONDOMINIO RUKAN	0.11	611.98	45.504
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.07	609.67	45.569
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.14	612.25	45.582
J-351	566.23	CONDOMINIO RUKAN	0.11	611.97	45.646
J-122	566.51	CONDOMINIO LAS BRISAS 3	0.14	612.26	45.651
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.14	612.14	45.724
J-331	566.08	CONDOMINIO RUKAN	0.11	611.92	45.741
J-337	566.06	CONDOMINIO RUKAN	0.11	611.93	45.776
J-342	566.03	CONDOMINIO RUKAN	0.11	611.93	45.804
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.14	612.13	45.908
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.14	612.12	45.951
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.14	612.12	46.108
J-377	565.35	CONDOMINIO BORDE BLANCO 2	3.46	611.59	46.142
J-361	565.53	CONDOMINIO RUKAN	0.11	611.98	46.352
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.14	612.12	46.496
J-330	565.13	CONDOMINIO RUKAN	0.11	611.92	46.698
J-346	564.90	<None>	0.00	611.94	46.945
J-375	564.57	<None>	1.12	611.64	46.978
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.14	612.12	47.050
J-373	564.55	<None>	1.12	611.71	47.069
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.14	612.12	47.073
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.14	612.12	47.333
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.07	609.74	47.384
J-329	564.22	CONDOMINIO RUKAN	0.11	611.92	47.600
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.14	612.12	47.609
J-371	564.00	<None>	1.12	611.81	47.715


FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.07	609.68	47.724
J-362	564.16	CONDOMINIO RUKAN	0.11	611.98	47.725
J-324	563.73	CONDOMINIO RUKAN	0.11	611.92	48.097
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.07	609.75	48.112
J-356	563.68	CONDOMINIO RUKAN	0.11	611.97	48.196
J-355	563.53	CONDOMINIO RUKAN	0.11	611.97	48.342
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.07	609.75	48.344
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.07	609.75	48.401
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.14	611.35	48.485
J-353	563.38	CONDOMINIO RUKAN	0.11	611.97	48.488
J-354	563.26	CONDOMINIO RUKAN	0.11	611.97	48.607
J-321	563.15	CONDOMINIO RUKAN	0.11	611.95	48.708
J-309	563.07	CONDOMINIO RUKAN	0.11	611.97	48.793
J-319	562.88	CONDOMINIO RUKAN	0.11	611.96	48.982
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.14	612.12	49.074
J-328	562.51	CONDOMINIO RUKAN	0.11	611.92	49.311
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.07	609.68	49.446
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.14	612.12	49.538
J-327	562.22	CONDOMINIO RUKAN	0.11	611.92	49.596
J-326	562.20	CONDOMINIO RUKAN	0.11	611.92	49.621
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.07	609.75	49.652
J-312	562.17	CONDOMINIO RUKAN	0.11	611.96	49.695
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.14	611.33	49.709
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.14	612.26	49.766
J-310	561.96	CONDOMINIO RUKAN	0.11	611.96	49.904
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.14	612.13	50.075
J-320	561.76	CONDOMINIO RUKAN	0.11	611.96	50.093
J-313	561.70	CONDOMINIO RUKAN	0.11	611.96	50.158
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.14	611.33	50.236
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.14	611.33	50.351
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.14	611.33	50.494
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.14	611.34	50.680
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.14	611.34	50.922
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.14	612.25	51.050
J-311	560.78	CONDOMINIO RUKAN	0.11	611.96	51.082

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.14	612.25	51.290
J-314	560.46	CONDOMINIO RUKAN	0.11	611.96	51.398
J-315	560.12	CONDOMINIO RUKAN	0.11	611.96	51.731
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.14	611.34	52.449
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.14	611.33	52.472
J-317	558.84	CONDOMINIO RUKAN	0.11	611.96	53.013
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.14	611.32	53.209
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.14	611.32	53.657
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.14	612.13	53.927
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.14	612.12	54.276
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.14	611.32	54.516
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.14	611.32	54.592
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.14	611.34	54.805
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.14	611.32	54.937
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.14	612.25	55.129
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.14	611.37	55.300
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.14	612.13	55.453
J-316	556.36	CONDOMINIO RUKAN	0.11	611.96	55.489
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.14	611.45	55.530
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.14	612.25	55.657
J-318	555.89	CONDOMINIO RUKAN	0.11	611.96	55.959
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.14	612.25	56.135
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.14	611.56	56.577
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.14	611.56	56.777

New Graph



T-1 - Caudales maximos horarios año 5 - Level (Calculated)

FlexTable: Hydrant Table

Label	Hydrant Status	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
H-5	Open	587.66	0.00	616.42	28.700
H-1	Open	587.58	0.00	616.43	28.786
H-48	Open	586.10	0.00	616.48	30.318
H-52	Open	584.86	0.00	616.37	31.440
H-13	Open	583.85	0.00	616.39	32.471
H-50	Open	583.79	0.00	616.27	32.412
H-2	Open	583.53	0.00	616.50	32.911
H-4	Open	581.61	0.00	616.60	34.916
H-3	Open	581.53	0.00	616.56	34.960
H-12	Open	579.64	0.00	616.57	36.859
H-49	Open	579.63	0.15	616.26	36.557
H-51	Open	579.07	0.00	616.61	37.461
H-14	Open	578.50	0.00	616.12	37.543
H-10	Open	578.19	0.00	616.44	38.175
H-6	Open	576.17	0.00	616.65	40.390
H-9	Open	575.57	0.00	616.60	40.945
H-16	Open	575.02	0.00	615.24	40.135
H-19	Open	574.00	0.00	614.93	40.850
H-18	Open	573.71	0.00	614.94	41.155
H-40	Open	573.54	0.00	615.87	42.249
H-44	Open	573.25	0.00	615.07	41.732
H-38	Open	572.44	0.00	615.87	43.337
H-22	Open	572.25	0.00	615.11	42.781
H-20	Open	572.24	0.00	614.87	42.545
H-17	Open	572.06	0.00	614.97	42.823
H-15	Open	572.00	0.00	616.02	43.927
H-45	Open	570.59	0.00	614.92	44.248
H-26	Open	569.69	0.00	615.88	46.093
H-43	Open	569.30	0.00	615.96	46.567
H-21	Open	568.77	0.00	614.82	45.959
H-47	Open	568.48	0.00	614.78	46.213
H-25	Open	567.49	0.00	615.85	48.260
H-41	Open	567.06	0.00	615.85	48.695
H-27	Open	566.67	0.00	615.84	49.066
H-35	Open	565.34	0.00	616.02	50.570
H-29	Open	564.78	0.00	615.70	50.818
H-28	Open	564.00	0.00	615.77	51.664
H-42	Open	563.62	0.00	615.84	52.116
H-30	Open	563.44	0.00	615.68	52.138
H-39	Open	563.31	0.00	615.87	52.445
H-34	Open	562.75	0.00	615.58	52.724
H-46	Open	561.45	0.00	614.82	53.258
H-37	Open	560.40	0.00	615.56	55.056
H-36	Open	560.34	0.00	615.57	55.115
H-53	Open	560.06	0.00	615.94	55.765
H-24	Open	560.03	0.00	615.86	55.715
H-33	Open	556.11	0.00	615.58	59.353
H-32	Open	555.48	0.00	615.66	60.066
H-31	Open	554.18	0.00	615.67	61.369

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.09	616.43	27.297
J-26	588.78	BRISAS DE CHICUREO NORTE	0.09	616.43	27.594
J-28	588.57	BRISAS DE CHICUREO NORTE	2.10	616.41	27.781
J-18	588.00	BRISAS DE CHICUREO NORTE	0.09	616.46	28.404
J-19	587.16	BRISAS DE CHICUREO NORTE	0.09	616.46	29.239
J-17	587.03	BRISAS DE CHICUREO NORTE	0.09	616.45	29.360
J-11	586.98	BRISAS DE CHICUREO NORTE	0.09	616.47	29.432
J-27	586.55	BRISAS DE CHICUREO NORTE	0.09	616.42	29.804
J-48	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.28	30.219
J-47	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.28	30.219
J-76	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.29	30.227
J-79	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.29	30.232
J-43	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.30	30.240
J-42	586.00	<None>	0.00	616.32	30.262
J-46	585.94	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.28	30.276
J-62	585.86	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	30.337
J-65	585.66	<None>	0.00	616.26	30.536
J-41	585.68	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.34	30.601
J-16	585.62	BRISAS DE CHICUREO NORTE	2.10	616.33	30.646
J-36	585.36	<None>	0.56	616.16	30.736
J-61	585.46	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	30.739
J-10	585.63	BRISAS DE CHICUREO NORTE	0.09	616.49	30.792
J-40	585.05	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.35	31.246
J-66	584.89	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.26	31.315
J-56	584.75	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	31.446
J-80	584.72	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.28	31.504
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.29	31.547
J-24	584.83	BRISAS DE CHICUREO NORTE	0.09	616.44	31.547
J-1	584.67	<None>	3.49	616.36	31.627
J-37	584.60	<None>	0.00	616.37	31.706

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	31.766
J-2	584.49	<None>	0.00	616.36	31.806
J-9	584.37	BRISAS DE CHICUREO NORTE	0.09	616.51	32.081
J-3	584.18	<None>	0.00	616.36	32.116
J-20	584.07	BRISAS DE CHICUREO NORTE	0.09	616.46	32.330
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.28	32.365
J-12	583.81	BRISAS DE CHICUREO NORTE	0.09	616.45	32.571
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.27	32.688
J-300	583.11	CONDOMINIO RUKAN	0.07	615.88	32.703
J-15	583.58	BRISAS DE CHICUREO NORTE	0.09	616.37	32.723
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.27	32.812
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.29	32.880
J-21	583.46	BRISAS DE CHICUREO NORTE	0.09	616.47	32.943
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.29	33.119
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	33.222
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.28	33.329
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.27	33.417
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	4.91	616.32	33.445
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.27	33.468
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	33.581
J-405	582.65	SAN LUIS	0.89	616.31	33.598
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	33.599
J-14	582.64	BRISAS DE CHICUREO NORTE	0.09	616.43	33.724
J-101	582.72	<None>	0.09	616.65	33.861
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.28	33.987
J-4	582.48	<None>	0.00	616.63	34.072
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.27	34.336
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.28	34.405
J-13	581.92	BRISAS DE CHICUREO NORTE	0.09	616.44	34.446
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.26	34.495
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	34.550

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-8	581.84	BRISAS DE CHICUREO NORTE	0.09	616.55	34.644
J-5	581.70	<None>	0.00	616.60	34.829
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	34.889
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	34.991
J-23	581.37	BRISAS DE CHICUREO NORTE	0.09	616.45	35.011
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.27	35.093
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	35.202
J-364	580.49	CONDOMINIO RUKAN	0.07	615.88	35.319
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.28	35.349
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	35.458
J-22	580.92	BRISAS DE CHICUREO NORTE	0.09	616.46	35.468
J-85	581.00	<None>	0.09	616.59	35.511
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	35.543
J-299	580.15	CONDOMINIO RUKAN	0.07	615.89	35.673
J-88	580.83	<None>	0.09	616.59	35.693
J-89	580.51	<None>	0.09	616.59	36.014
J-84	580.42	<None>	0.09	616.59	36.095
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.27	36.242
J-87	580.27	<None>	0.09	616.59	36.247
J-97	580.31	<None>	0.09	616.64	36.256
J-39	580.14	<None>	0.09	616.56	36.344
J-81	580.00	<None>	0.09	616.56	36.491
J-82	580.00	<None>	0.09	616.57	36.498
J-86	580.00	<None>	0.09	616.59	36.513
J-94	580.00	<None>	0.09	616.61	36.533
J-93	580.00	<None>	0.09	616.61	36.533
J-91	579.93	<None>	0.09	616.60	36.592
J-83	579.67	<None>	0.09	616.58	36.840
J-98	579.66	<None>	0.09	616.64	36.909
J-29	579.64	<None>	0.09	616.64	36.928
J-301	578.67	CONDOMINIO RUKAN	0.07	615.88	37.137
J-298	578.65	CONDOMINIO RUKAN	0.07	615.91	37.180
J-92	579.33	<None>	0.09	616.61	37.203
J-90	579.31	<None>	0.09	616.59	37.210
J-112	579.30	<None>	0.09	616.65	37.273
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	37.341
J-54	578.81	CONDOMINIO 1 BRISAS-CHICUREO	0.15	616.26	37.379
J-72	578.80	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.27	37.400
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.08	616.26	37.481

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-6	578.90	BRISAS DE CHICUREO NORTE	0.09	616.60	37.623
J-102	578.94	<None>	0.09	616.65	37.630
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.59	37.760
J-109	578.73	<None>	0.09	616.62	37.821
J-304	577.89	CONDOMINIO RUKAN	0.07	615.89	37.926
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.12	616.58	38.010
J-7	578.48	BRISAS DE CHICUREO NORTE	0.09	616.60	38.035
J-95	578.40	<None>	0.09	616.62	38.150
J-111	578.22	<None>	0.09	616.65	38.347
J-104	578.17	<None>	0.09	616.65	38.404
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.04	614.82	38.745
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.04	614.83	38.747
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.04	614.83	38.749
J-96	577.74	<None>	0.09	616.64	38.823
J-253	576.00	CONDOMINIO LA SIEMBRA	0.15	614.92	38.841
J-291	576.00	CONDOMINIO LA TRILLA	0.14	615.07	38.992
J-100	577.57	<None>	0.09	616.65	38.994
J-242	575.72	CONDOMINIO LA SIEMBRA	0.15	614.92	39.116
J-105	577.42	<None>	0.09	616.65	39.145
J-99	577.36	<None>	0.09	616.64	39.201
J-277	575.74	CONDOMINIO LA TRILLA	0.14	615.07	39.253
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.04	614.82	39.419
J-35	576.93	<None>	0.09	616.54	39.536
J-303	575.85	CONDOMINIO RUKAN	0.07	615.88	39.948
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.04	614.78	39.963
J-305	575.80	CONDOMINIO RUKAN	0.07	615.89	40.013
J-363	575.69	CONDOMINIO RUKAN	0.07	615.88	40.103
J-173	575.06	<None>	0.56	615.24	40.106
J-297	575.70	CONDOMINIO RUKAN	0.07	615.92	40.134
J-267	574.77	CONDOMINIO LA TRILLA	0.14	615.07	40.220
J-258	574.89	<None>	0.00	615.21	40.239
J-287	574.68	CONDOMINIO LA TRILLA	0.14	615.07	40.313
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.04	614.82	40.343
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.04	614.82	40.344
J-292	574.50	CONDOMINIO LA TRILLA	0.14	615.07	40.486
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.04	614.82	40.496
J-259	574.54	<None>	0.56	615.17	40.550
J-245	574.28	CONDOMINIO LA SIEMBRA	0.15	614.92	40.554
J-254	574.24	CONDOMINIO LA SIEMBRA	0.15	614.92	40.600

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-106	575.90	<None>	0.09	616.65	40.667
J-264	574.31	CONDOMINIO LA TRILLA	0.14	615.08	40.691
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.04	614.78	40.701
J-34	575.78	<None>	0.09	616.61	40.749
J-103	575.79	<None>	0.09	616.66	40.787
J-289	574.20	CONDOMINIO LA TRILLA	0.14	615.08	40.800
J-290	574.15	CONDOMINIO LA TRILLA	0.14	615.07	40.838
J-233	574.00	CONDOMINIO LA SIEMBRA	0.15	614.92	40.842
J-232	574.00	CONDOMINIO LA SIEMBRA	0.15	614.92	40.842
J-231	574.00	CONDOMINIO LA SIEMBRA	0.15	614.93	40.843
J-257	574.00	CONDOMINIO LA SIEMBRA	0.15	614.93	40.844
J-268	574.09	CONDOMINIO LA TRILLA	0.14	615.07	40.893
J-33	575.65	<None>	0.09	616.63	40.900
J-283	574.00	CONDOMINIO LA TRILLA	0.14	615.07	40.989
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.04	614.83	41.015
J-274	573.93	CONDOMINIO LA TRILLA	0.14	615.08	41.072
J-284	573.82	CONDOMINIO LA TRILLA	0.14	615.07	41.168
J-263	573.68	CONDOMINIO LA TRILLA	0.14	615.09	41.324
J-237	573.42	CONDOMINIO LA SIEMBRA	0.15	614.92	41.417
J-256	573.36	CONDOMINIO LA SIEMBRA	0.15	614.93	41.487
J-339	574.08	CONDOMINIO RUKAN	0.07	615.87	41.706
J-230	573.06	CONDOMINIO LA SIEMBRA	0.15	614.93	41.781
J-273	573.20	CONDOMINIO LA TRILLA	0.14	615.08	41.790
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.04	614.82	41.846
J-236	572.96	CONDOMINIO LA SIEMBRA	0.15	614.92	41.879
J-30	574.69	<None>	0.09	616.66	41.882
J-307	573.85	CONDOMINIO RUKAN	0.07	615.87	41.940
J-235	572.84	CONDOMINIO LA SIEMBRA	0.15	614.93	41.999
J-266	572.94	CONDOMINIO LA TRILLA	0.14	615.07	42.047
J-269	572.92	CONDOMINIO LA TRILLA	0.14	615.07	42.068
J-107	574.43	<None>	0.09	616.65	42.135
J-286	572.84	CONDOMINIO LA TRILLA	0.14	615.07	42.143
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.04	614.82	42.282
J-285	572.69	CONDOMINIO LA TRILLA	0.14	615.07	42.293
J-255	572.50	CONDOMINIO LA SIEMBRA	0.15	614.93	42.340
J-407	574.27	<None>	0.00	616.72	42.361
J-365	573.40	CONDOMINIO RUKAN	0.07	615.87	42.381
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.10	615.95	42.388
J-347	573.38	CONDOMINIO RUKAN	0.07	615.87	42.401

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-275	572.54	CONDOMINIO LA TRILLA	0.14	615.08	42.454
J-349	573.30	CONDOMINIO RUKAN	0.07	615.87	42.478
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.04	614.78	42.522
J-234	572.29	CONDOMINIO LA SIEMBRA	0.15	614.93	42.554
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.04	614.82	42.559
J-238	572.25	CONDOMINIO LA SIEMBRA	0.15	614.93	42.594
J-262	572.35	<None>	0.00	615.11	42.681
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.04	614.83	42.765
J-229	572.00	CONDOMINIO LA SIEMBRA	0.15	614.93	42.845
J-239	571.97	CONDOMINIO LA SIEMBRA	0.15	614.92	42.867
J-249	571.94	CONDOMINIO LA SIEMBRA	0.15	614.93	42.907
J-240	571.92	CONDOMINIO LA SIEMBRA	0.15	614.92	42.915
J-293	572.06	<None>	0.56	615.11	42.966
J-272	571.78	CONDOMINIO LA TRILLA	0.14	615.08	43.209
J-250	571.58	CONDOMINIO LA SIEMBRA	0.15	614.92	43.252
J-174	571.62	<None>	0.56	614.98	43.270
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.04	614.84	43.300
J-265	571.65	CONDOMINIO LA TRILLA	0.14	615.07	43.329
J-228	571.51	CONDOMINIO LA SIEMBRA	0.15	614.94	43.341
J-260	571.62	<None>	0.00	615.13	43.425
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.04	614.82	43.504
J-244	571.26	CONDOMINIO LA SIEMBRA	0.15	614.92	43.569
J-406	572.89	<None>	0.00	616.67	43.692
J-32	572.86	<None>	0.09	616.66	43.705
J-31	572.85	<None>	0.09	616.67	43.733
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.04	614.78	43.741
J-261	571.29	<None>	0.56	615.13	43.756
J-247	571.03	CONDOMINIO LA SIEMBRA	0.15	614.92	43.805
J-251	570.94	CONDOMINIO LA SIEMBRA	0.15	614.92	43.896
J-246	570.92	CONDOMINIO LA SIEMBRA	0.15	614.92	43.910
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.10	616.01	43.920
J-276	571.05	CONDOMINIO LA TRILLA	0.14	615.07	43.932
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.04	614.85	43.999
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.10	616.02	44.051

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-241	570.57	CONDOMINIO LA SIEMBRA	0.15	614.92	44.265
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.04	614.82	44.307
J-175	570.44	<None>	0.00	614.86	44.330
J-163	571.57	CONDOMINIO LAS BRISAS 3	0.10	616.00	44.335
J-279	570.60	CONDOMINIO LA TRILLA	0.14	615.07	44.384
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.10	615.94	44.415
J-271	570.38	CONDOMINIO LA TRILLA	0.14	615.07	44.605
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.10	615.95	44.712
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.04	614.78	44.791
J-348	570.98	CONDOMINIO RUKAN	0.07	615.87	44.797
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.04	614.78	44.815
J-243	570.00	CONDOMINIO LA SIEMBRA	0.15	614.92	44.829
J-248	570.00	CONDOMINIO LA SIEMBRA	0.15	614.92	44.834
J-252	570.00	CONDOMINIO LA SIEMBRA	0.15	614.93	44.838
J-162	571.04	CONDOMINIO LAS BRISAS 3	0.10	616.00	44.867
J-113	571.08	<None>	2.05	616.05	44.883
J-270	570.00	CONDOMINIO LA TRILLA	0.14	615.07	44.980
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.10	616.01	45.018
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.04	614.78	45.066
J-278	569.90	CONDOMINIO LA TRILLA	0.14	615.07	45.079
J-308	570.59	CONDOMINIO RUKAN	0.07	615.87	45.185
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.10	616.00	45.254
J-360	570.45	CONDOMINIO RUKAN	0.07	615.87	45.328
J-282	569.56	CONDOMINIO LA TRILLA	0.14	615.07	45.419
J-161	570.30	CONDOMINIO LAS BRISAS 3	0.10	616.00	45.602
J-302	570.02	CONDOMINIO RUKAN	0.07	615.88	45.760
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.04	614.86	45.820
J-296	570.00	<None>	0.00	615.92	45.828
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.04	614.78	45.852
J-160	569.98	CONDOMINIO LAS BRISAS 3	0.10	616.00	45.925
J-281	569.04	CONDOMINIO LA TRILLA	0.14	615.07	45.937
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.04	614.83	46.006
J-306	569.69	CONDOMINIO RUKAN	0.07	615.88	46.092
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.04	614.84	46.188
J-294	569.53	<None>	1.49	615.92	46.295

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-295	569.50	<None>	0.00	615.92	46.328
J-343	569.39	CONDOMINIO RUKAN	0.07	615.85	46.372
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.10	615.96	46.470
J-280	568.45	CONDOMINIO LA TRILLA	0.14	615.07	46.524
J-366	569.22	CONDOMINIO RUKAN	0.07	615.87	46.555
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.04	614.86	46.595
J-338	568.83	CONDOMINIO RUKAN	0.07	615.85	46.929
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.10	615.95	46.965
J-404	567.81	REMANSO DE CHICUREO	0.16	614.90	46.996
J-341	568.69	CONDOMINIO RUKAN	0.07	615.85	47.058
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.04	614.78	47.136
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.04	614.78	47.167
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.10	616.02	47.232
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.10	615.94	47.262
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.10	615.94	47.356
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.10	615.94	47.375
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.04	614.78	47.417
J-340	568.30	CONDOMINIO RUKAN	0.07	615.85	47.448
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.10	615.94	47.475
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.04	614.82	47.509
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.04	614.85	47.520
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.10	615.94	47.542
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.04	614.78	47.571
J-115	568.13	CONDOMINIO LAS BRISAS 3	0.10	616.01	47.790
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.04	614.79	47.804
J-121	568.03	CONDOMINIO LAS BRISAS 3	0.10	616.01	47.879
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.10	615.96	47.922
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.10	615.97	48.015
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.10	615.94	48.021
J-323	567.67	CONDOMINIO RUKAN	0.07	615.85	48.082
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.10	615.96	48.171
J-370	567.56	<None>	0.00	615.85	48.195
J-359	567.58	CONDOMINIO RUKAN	0.07	615.87	48.196

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.10	615.95	48.241
J-345	567.47	CONDOMINIO RUKAN	0.07	615.85	48.282
J-367	567.48	<None>	1.49	615.87	48.284
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.04	614.82	48.288
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.10	615.94	48.380
J-335	567.32	CONDOMINIO RUKAN	0.07	615.84	48.429
J-350	567.29	<None>	0.00	615.87	48.476
J-344	567.16	CONDOMINIO RUKAN	0.07	615.85	48.595
J-123	567.29	CONDOMINIO LAS BRISAS 3	0.10	616.00	48.609
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.04	614.80	48.646
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.10	615.94	48.658
J-334	566.99	CONDOMINIO RUKAN	0.07	615.84	48.751
J-333	566.93	CONDOMINIO RUKAN	0.07	615.84	48.812
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.04	614.83	48.870
J-114	567.04	CONDOMINIO LAS BRISAS 3	0.10	616.02	48.880
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.10	616.02	48.899
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.10	615.94	48.948
J-352	566.81	CONDOMINIO RUKAN	0.07	615.87	48.958
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.04	614.82	48.979
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.10	615.95	49.035
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.04	614.80	49.052
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.10	615.96	49.097
J-336	566.58	CONDOMINIO RUKAN	0.07	615.84	49.166
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.10	615.58	49.220
J-332	566.49	CONDOMINIO RUKAN	0.07	615.84	49.254
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.10	615.94	49.260
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.04	614.78	49.260
J-357	566.51	CONDOMINIO RUKAN	0.07	615.87	49.262
J-322	566.48	CONDOMINIO RUKAN	0.07	615.85	49.272
J-325	566.45	CONDOMINIO RUKAN	0.07	615.84	49.295
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.10	616.00	49.325
J-122	566.51	CONDOMINIO LAS BRISAS 3	0.10	616.00	49.389
J-358	566.38	CONDOMINIO RUKAN	0.07	615.87	49.390
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.10	615.95	49.523
J-351	566.23	CONDOMINIO RUKAN	0.07	615.87	49.535

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-331	566.08	CONDOMINIO RUKAN	0.07	615.84	49.657
J-337	566.06	CONDOMINIO RUKAN	0.07	615.85	49.687
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.10	615.94	49.713
J-342	566.03	CONDOMINIO RUKAN	0.07	615.85	49.716
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.10	615.94	49.760
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.10	615.94	49.916
J-377	565.35	CONDOMINIO BORDE BLANCO 2	2.31	615.69	50.234
J-361	565.53	CONDOMINIO RUKAN	0.07	615.87	50.236
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.10	615.94	50.304
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.04	614.82	50.417
J-330	565.13	CONDOMINIO RUKAN	0.07	615.84	50.612
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.04	614.78	50.668
J-346	564.90	<None>	0.00	615.85	50.849
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.10	615.94	50.859
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.10	615.94	50.882
J-375	564.57	<None>	0.75	615.71	51.040
J-373	564.55	<None>	0.75	615.75	51.092
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.10	615.94	51.142
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.10	615.94	51.418
J-329	564.22	CONDOMINIO RUKAN	0.07	615.84	51.515
J-362	564.16	CONDOMINIO RUKAN	0.07	615.87	51.610
J-371	564.00	<None>	0.75	615.79	51.687
J-324	563.73	CONDOMINIO RUKAN	0.07	615.84	52.010
J-356	563.68	CONDOMINIO RUKAN	0.07	615.87	52.083
J-355	563.53	CONDOMINIO RUKAN	0.07	615.87	52.230
J-353	563.38	CONDOMINIO RUKAN	0.07	615.87	52.377
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.04	614.81	52.450
J-354	563.26	CONDOMINIO RUKAN	0.07	615.86	52.498
J-321	563.15	CONDOMINIO RUKAN	0.07	615.86	52.605
J-309	563.07	CONDOMINIO RUKAN	0.07	615.86	52.684
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.10	615.57	52.700
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.04	614.79	52.817
J-319	562.88	CONDOMINIO RUKAN	0.07	615.86	52.875
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.10	615.94	52.882
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.04	614.82	53.168
J-328	562.51	CONDOMINIO RUKAN	0.07	615.84	53.226
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.10	615.94	53.347

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.04	614.82	53.402
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.04	614.82	53.456
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.10	616.00	53.504
J-327	562.22	CONDOMINIO RUKAN	0.07	615.84	53.510
J-326	562.20	CONDOMINIO RUKAN	0.07	615.84	53.535
J-312	562.17	CONDOMINIO RUKAN	0.07	615.86	53.587
J-310	561.96	CONDOMINIO RUKAN	0.07	615.86	53.796
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.10	615.94	53.878
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.10	615.56	53.936
J-320	561.76	CONDOMINIO RUKAN	0.07	615.86	53.990
J-313	561.70	CONDOMINIO RUKAN	0.07	615.86	54.052
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.10	615.57	54.460
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.04	614.79	54.540
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.10	615.56	54.577
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.04	614.82	54.709
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.10	615.56	54.721
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.10	616.00	54.791
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.10	615.57	54.898
J-311	560.78	CONDOMINIO RUKAN	0.07	615.86	54.974
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.10	616.00	55.033
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.10	615.57	55.142
J-314	560.46	CONDOMINIO RUKAN	0.07	615.86	55.293
J-315	560.12	CONDOMINIO RUKAN	0.07	615.86	55.626
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.10	615.57	56.668
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.10	615.57	56.695
J-317	558.84	CONDOMINIO RUKAN	0.07	615.86	56.907
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.10	615.56	57.440
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.10	615.94	57.733
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.10	615.56	57.888
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.10	615.94	58.084
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.10	615.56	58.747
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.10	615.56	58.824

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.10	616.00	58.870
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.10	615.57	59.023
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.10	615.56	59.168
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.10	615.94	59.260
J-316	556.36	CONDOMINIO RUKAN	0.07	615.86	59.383
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.10	616.00	59.400
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.10	615.59	59.503
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.10	615.62	59.694
J-318	555.89	CONDOMINIO RUKAN	0.07	615.86	59.852
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.10	616.00	59.877
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.10	615.67	60.683
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.10	615.67	60.884

AÑO 10

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.13	610.31	21.187
J-26	588.78	BRISAS DE CHICUREO NORTE	0.13	610.29	21.475
J-28	588.57	BRISAS DE CHICUREO NORTE	3.06	610.26	21.647
J-18	588.00	BRISAS DE CHICUREO NORTE	0.13	610.37	22.322
J-19	587.16	BRISAS DE CHICUREO NORTE	0.13	610.37	23.157
J-17	587.03	BRISAS DE CHICUREO NORTE	0.13	610.33	23.261
J-36	585.36	<None>	2.18	608.73	23.319
J-11	586.98	BRISAS DE CHICUREO NORTE	0.13	610.39	23.360
J-27	586.55	BRISAS DE CHICUREO NORTE	0.13	610.28	23.676
J-1	584.67	<None>	7.00	608.50	23.785
J-2	584.49	<None>	1.91	608.50	23.967
J-48	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.23	610.03	23.978
J-47	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.23	610.03	23.978
J-76	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.04	23.993
J-79	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.05	24.005
J-43	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.07	24.020
J-46	585.94	CONDOMINIO 1 BRISAS- CHICUREO	0.23	610.03	24.036
J-42	586.00	<None>	0.00	610.11	24.065
J-62	585.86	CONDOMINIO 1 BRISAS- CHICUREO	0.23	609.98	24.075
J-65	585.66	<None>	0.00	609.99	24.276
J-3	584.18	<None>	1.91	608.50	24.276
J-41	585.68	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.14	24.419
J-16	585.62	BRISAS DE CHICUREO NORTE	3.06	610.10	24.430
J-61	585.46	CONDOMINIO 1 BRISAS- CHICUREO	0.23	609.98	24.475
J-300	583.11	CONDOMINIO RUKAN	0.10	607.72	24.566
J-10	585.63	BRISAS DE CHICUREO NORTE	0.13	610.42	24.734
J-66	584.89	CONDOMINIO 2BRISAS- CHICUREO	0.11	609.99	25.057
J-40	585.05	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.18	25.081
J-56	584.75	CONDOMINIO 1 BRISAS- CHICUREO	0.23	609.99	25.185
J-80	584.72	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.03	25.268

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.05	25.318
J-24	584.83	BRISAS DE CHICUREO NORTE	0.13	610.33	25.445
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.23	609.98	25.502
J-37	584.60	<None>	0.00	610.21	25.558
J-9	584.37	BRISAS DE CHICUREO NORTE	0.13	610.47	26.052
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.03	26.125
J-20	584.07	BRISAS DE CHICUREO NORTE	0.13	610.37	26.248
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.00	26.436
J-12	583.81	BRISAS DE CHICUREO NORTE	0.13	610.35	26.479
J-15	583.58	BRISAS DE CHICUREO NORTE	0.13	610.17	26.543
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.00	26.560
J-405	582.65	SAN LUIS	2.65	609.34	26.642
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.04	26.646
J-21	583.46	BRISAS DE CHICUREO NORTE	0.13	610.39	26.872
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.04	26.886
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.03	27.092
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.01	27.169
J-364	580.49	CONDOMINIO RUKAN	0.10	607.73	27.182
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.00	27.216
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	7.17	610.10	27.242
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.60	27.259
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.23	609.98	27.335
J-299	580.15	CONDOMINIO RUKAN	0.10	607.75	27.551
J-14	582.64	BRISAS DE CHICUREO NORTE	0.13	610.30	27.609
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.60	27.618
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.03	27.746
J-101	582.72	<None>	0.13	610.76	27.984
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.01	28.084
J-4	582.48	<None>	0.00	610.70	28.157
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.03	28.164

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.11	609.99	28.236
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.23	609.98	28.286
J-13	581.92	BRISAS DE CHICUREO NORTE	0.13	610.32	28.338
J-8	581.84	BRISAS DE CHICUREO NORTE	0.13	610.55	28.653
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.23	609.98	28.728
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.11	610.01	28.845
J-5	581.70	<None>	0.00	610.65	28.888
J-23	581.37	BRISAS DE CHICUREO NORTE	0.13	610.34	28.916
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.61	28.927
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.23	609.99	28.942
J-301	578.67	CONDOMINIO RUKAN	0.10	607.72	28.999
J-298	578.65	CONDOMINIO RUKAN	0.10	607.78	29.071
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.02	29.104
J-22	580.92	BRISAS DE CHICUREO NORTE	0.13	610.37	29.387
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.61	29.496
J-85	581.00	<None>	0.13	610.65	29.583
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.62	29.585
J-88	580.83	<None>	0.13	610.66	29.769
J-304	577.89	CONDOMINIO RUKAN	0.10	607.75	29.804
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.06	606.04	29.976
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.06	606.04	29.979
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.06	606.04	29.984
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.23	610.01	29.992
J-89	580.51	<None>	0.13	610.66	30.090
J-84	580.42	<None>	0.13	610.64	30.166
J-253	576.00	CONDOMINIO LA SIEMBRA	0.21	606.23	30.168
J-87	580.27	<None>	0.13	610.65	30.318
J-97	580.31	<None>	0.13	610.74	30.372
J-39	580.14	<None>	0.13	610.59	30.386
J-242	575.72	CONDOMINIO LA SIEMBRA	0.21	606.23	30.443
J-291	576.00	CONDOMINIO LA TRILLA	0.20	606.54	30.474
J-81	580.00	<None>	0.13	610.60	30.538
J-82	580.00	<None>	0.13	610.62	30.554
J-86	580.00	<None>	0.13	610.65	30.585

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-94	580.00	<None>	0.13	610.68	30.621
J-93	580.00	<None>	0.13	610.68	30.621
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.06	606.03	30.648
J-91	579.93	<None>	0.13	610.67	30.674
J-277	575.74	CONDOMINIO LA TRILLA	0.20	606.54	30.738
J-83	579.67	<None>	0.13	610.64	30.910
J-98	579.66	<None>	0.13	610.74	31.025
J-29	579.64	<None>	0.13	610.75	31.049
J-54	578.81	CONDOMINIO 1 BRISAS- CHICUREO	0.23	609.99	31.120
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.06	605.95	31.151
J-72	578.80	CONDOMINIO 2BRISAS- CHICUREO	0.11	610.01	31.152
J-68	578.71	CONDOMINIO 2BRISAS- CHICUREO	0.11	609.99	31.222
J-90	579.31	<None>	0.13	610.66	31.286
J-92	579.33	<None>	0.13	610.68	31.291
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.62	31.384
J-112	579.30	<None>	0.13	610.78	31.420
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.06	606.03	31.571
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.06	606.04	31.574
J-6	578.90	BRISAS DE CHICUREO NORTE	0.13	610.64	31.677
J-267	574.77	CONDOMINIO LA TRILLA	0.20	606.53	31.699
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.06	606.03	31.726
J-102	578.94	<None>	0.13	610.76	31.752
J-173	575.06	<None>	0.82	606.88	31.760
J-287	574.68	CONDOMINIO LA TRILLA	0.20	606.54	31.795
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.62	31.804
J-303	575.85	CONDOMINIO RUKAN	0.10	607.72	31.810
J-258	574.89	<None>	0.00	606.81	31.856
J-245	574.28	CONDOMINIO LA SIEMBRA	0.21	606.23	31.882
J-305	575.80	CONDOMINIO RUKAN	0.10	607.75	31.889
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.06	605.96	31.891
J-254	574.24	CONDOMINIO LA SIEMBRA	0.21	606.23	31.929
J-109	578.73	<None>	0.13	610.73	31.938
J-292	574.50	CONDOMINIO LA TRILLA	0.20	606.53	31.963
J-363	575.69	CONDOMINIO RUKAN	0.10	607.73	31.966
J-297	575.70	CONDOMINIO RUKAN	0.10	607.80	32.036
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	610.61	32.050
J-7	578.48	BRISAS DE CHICUREO NORTE	0.13	610.64	32.089

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-259	574.54	<None>	0.82	606.74	32.132
J-233	574.00	CONDOMINIO LA SIEMBRA	0.21	606.24	32.175
J-232	574.00	CONDOMINIO LA SIEMBRA	0.21	606.24	32.176
J-231	574.00	CONDOMINIO LA SIEMBRA	0.21	606.24	32.177
J-257	574.00	CONDOMINIO LA SIEMBRA	0.21	606.24	32.179
J-264	574.31	CONDOMINIO LA TRILLA	0.20	606.55	32.181
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.06	606.05	32.252
J-95	578.40	<None>	0.13	610.72	32.254
J-289	574.20	CONDOMINIO LA TRILLA	0.20	606.55	32.289
J-290	574.15	CONDOMINIO LA TRILLA	0.20	606.53	32.317
J-268	574.09	CONDOMINIO LA TRILLA	0.20	606.53	32.372
J-283	574.00	CONDOMINIO LA TRILLA	0.20	606.53	32.466
J-111	578.22	<None>	0.13	610.78	32.494
J-104	578.17	<None>	0.13	610.78	32.551
J-274	573.93	CONDOMINIO LA TRILLA	0.20	606.56	32.565
J-284	573.82	CONDOMINIO LA TRILLA	0.20	606.53	32.646
J-237	573.42	CONDOMINIO LA SIEMBRA	0.21	606.24	32.750
J-256	573.36	CONDOMINIO LA SIEMBRA	0.21	606.24	32.822
J-263	573.68	CONDOMINIO LA TRILLA	0.20	606.57	32.824
J-96	577.74	<None>	0.13	610.74	32.939
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.06	606.03	33.073
J-100	577.57	<None>	0.13	610.76	33.117
J-230	573.06	CONDOMINIO LA SIEMBRA	0.21	606.25	33.117
J-236	572.96	CONDOMINIO LA SIEMBRA	0.21	606.24	33.212
J-273	573.20	CONDOMINIO LA TRILLA	0.20	606.55	33.278
J-105	577.42	<None>	0.13	610.78	33.293
J-35	576.93	<None>	1.49	610.30	33.306
J-99	577.36	<None>	0.13	610.75	33.321
J-235	572.84	CONDOMINIO LA SIEMBRA	0.21	606.24	33.333
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.06	606.04	33.513
J-266	572.94	CONDOMINIO LA TRILLA	0.20	606.53	33.527
J-269	572.92	CONDOMINIO LA TRILLA	0.20	606.53	33.547
J-339	574.08	CONDOMINIO RUKAN	0.10	607.71	33.560
J-286	572.84	CONDOMINIO LA TRILLA	0.20	606.53	33.622
J-255	572.50	CONDOMINIO LA SIEMBRA	0.21	606.25	33.676
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.06	605.96	33.712
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.14	607.28	33.740
J-285	572.69	CONDOMINIO LA TRILLA	0.20	606.53	33.771

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.06	606.04	33.789
J-307	573.85	CONDOMINIO RUKAN	0.10	607.71	33.796
J-234	572.29	CONDOMINIO LA SIEMBRA	0.21	606.24	33.889
J-238	572.25	CONDOMINIO LA SIEMBRA	0.21	606.24	33.929
J-275	572.54	CONDOMINIO LA TRILLA	0.20	606.55	33.941
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.06	606.04	33.999
J-229	572.00	CONDOMINIO LA SIEMBRA	0.21	606.25	34.185
J-239	571.97	CONDOMINIO LA SIEMBRA	0.21	606.23	34.196
J-262	572.35	<None>	0.00	606.62	34.203
J-365	573.40	CONDOMINIO RUKAN	0.10	607.71	34.238
J-240	571.92	CONDOMINIO LA SIEMBRA	0.21	606.23	34.243
J-249	571.94	CONDOMINIO LA SIEMBRA	0.21	606.25	34.246
J-347	573.38	CONDOMINIO RUKAN	0.10	607.70	34.254
J-349	573.30	CONDOMINIO RUKAN	0.10	607.70	34.331
J-293	572.06	<None>	0.82	606.61	34.487
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.06	606.07	34.548
J-250	571.58	CONDOMINIO LA SIEMBRA	0.21	606.23	34.582
J-174	571.62	<None>	0.82	606.35	34.657
J-228	571.51	CONDOMINIO LA SIEMBRA	0.21	606.26	34.685
J-272	571.78	CONDOMINIO LA TRILLA	0.20	606.55	34.695
J-34	575.78	<None>	0.13	610.57	34.721
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.06	606.03	34.731
J-265	571.65	CONDOMINIO LA TRILLA	0.20	606.53	34.810
J-106	575.90	<None>	0.13	610.79	34.816
J-244	571.26	CONDOMINIO LA SIEMBRA	0.21	606.23	34.897
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.06	605.95	34.930
J-33	575.65	<None>	0.13	610.66	34.943
J-103	575.79	<None>	0.13	610.80	34.947
J-260	571.62	<None>	0.00	606.66	34.970
J-247	571.03	CONDOMINIO LA SIEMBRA	0.21	606.23	35.135
J-251	570.94	CONDOMINIO LA SIEMBRA	0.21	606.24	35.229
J-246	570.92	CONDOMINIO LA SIEMBRA	0.21	606.23	35.239
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.06	606.09	35.256
J-261	571.29	<None>	0.82	606.66	35.301

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-120	572.00	CONDOMINIO LAS BRISAS 3	1.43	607.43	35.357
J-276	571.05	CONDOMINIO LA TRILLA	0.20	606.53	35.414
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.06	606.03	35.534
J-118	571.88	CONDOMINIO LAS BRISAS 3	1.43	607.49	35.538
J-241	570.57	CONDOMINIO LA SIEMBRA	0.21	606.23	35.592
J-175	570.44	<None>	0.00	606.12	35.602
J-163	571.57	CONDOMINIO LAS BRISAS 3	1.50	607.33	35.687
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.14	607.27	35.760
J-279	570.60	CONDOMINIO LA TRILLA	0.20	606.53	35.864
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.06	605.95	35.979
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.06	605.95	36.005
J-30	574.69	<None>	0.13	610.80	36.036
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.14	607.28	36.064
J-271	570.38	CONDOMINIO LA TRILLA	0.20	606.53	36.086
J-243	570.00	CONDOMINIO LA SIEMBRA	0.21	606.23	36.158
J-248	570.00	CONDOMINIO LA SIEMBRA	0.21	606.24	36.168
J-252	570.00	CONDOMINIO LA SIEMBRA	0.21	606.25	36.175
J-162	571.04	CONDOMINIO LAS BRISAS 3	1.50	607.33	36.219
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.06	605.95	36.254
J-107	574.43	<None>	0.13	610.79	36.286
J-270	570.00	CONDOMINIO LA TRILLA	0.20	606.53	36.461
J-119	570.91	CONDOMINIO LAS BRISAS 3	1.43	607.46	36.478
J-278	569.90	CONDOMINIO LA TRILLA	0.20	606.54	36.561
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.14	607.33	36.608
J-348	570.98	CONDOMINIO RUKAN	0.10	607.70	36.650
J-407	574.27	<None>	0.00	611.01	36.665
J-282	569.56	CONDOMINIO LA TRILLA	0.20	606.53	36.896
J-161	570.30	CONDOMINIO LAS BRISAS 3	1.50	607.34	36.960
J-113	571.08	<None>	4.35	608.13	36.983
J-308	570.59	CONDOMINIO RUKAN	0.10	607.70	37.037
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.06	605.96	37.042
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.06	606.11	37.087
J-360	570.45	CONDOMINIO RUKAN	0.10	607.72	37.187

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.06	606.06	37.248
J-160	569.98	CONDOMINIO LAS BRISAS 3	1.50	607.35	37.295
J-281	569.04	CONDOMINIO LA TRILLA	0.20	606.53	37.414
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.06	606.07	37.437
J-302	570.02	CONDOMINIO RUKAN	0.10	607.72	37.622
J-296	570.00	<None>	0.00	607.81	37.733
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.14	607.30	37.830
J-32	572.86	<None>	0.13	610.78	37.836
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.06	606.10	37.859
J-406	572.89	<None>	0.00	610.84	37.874
J-31	572.85	<None>	0.13	610.83	37.903
J-306	569.69	CONDOMINIO RUKAN	0.10	607.73	37.955
J-280	568.45	CONDOMINIO LA TRILLA	0.20	606.53	38.002
J-294	569.53	<None>	2.17	607.81	38.200
J-343	569.39	CONDOMINIO RUKAN	0.10	607.68	38.211
J-295	569.50	<None>	0.00	607.81	38.232
J-404	567.81	REMANSO DE CHICUREO	0.24	606.20	38.307
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.14	607.28	38.317
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.06	605.95	38.325
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.06	605.95	38.356
J-366	569.22	CONDOMINIO RUKAN	0.10	607.71	38.411
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.14	607.26	38.603
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.06	605.95	38.605
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.14	607.26	38.696
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.14	607.27	38.718
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.06	606.03	38.738
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.06	605.95	38.760
J-117	568.69	CONDOMINIO LAS BRISAS 3	1.43	607.54	38.767
J-338	568.83	CONDOMINIO RUKAN	0.10	607.68	38.768
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.06	606.09	38.776
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.14	607.27	38.821
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.14	607.26	38.884
J-341	568.69	CONDOMINIO RUKAN	0.10	607.66	38.889
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.06	605.96	38.996

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-340	568.30	CONDOMINIO RUKAN	0.10	607.66	39.278
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.14	607.31	39.288
J-115	568.13	CONDOMINIO LAS BRISAS 3	1.50	607.55	39.340
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.14	607.26	39.361
J-121	568.03	CONDOMINIO LAS BRISAS 3	1.50	607.48	39.366
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.14	607.33	39.391
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.06	606.03	39.515
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.14	607.30	39.529
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.14	607.28	39.591
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.14	607.26	39.720
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.06	605.99	39.855
J-323	567.67	CONDOMINIO RUKAN	0.10	607.66	39.914
J-370	567.56	<None>	1.29	607.61	39.973
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.14	607.27	40.003
J-123	567.29	CONDOMINIO LAS BRISAS 3	1.50	607.38	40.009
J-359	567.58	CONDOMINIO RUKAN	0.10	607.72	40.055
J-367	567.48	<None>	3.46	607.65	40.087
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.06	606.05	40.106
J-345	567.47	CONDOMINIO RUKAN	0.10	607.68	40.121
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.06	606.03	40.206
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.06	605.98	40.255
J-335	567.32	CONDOMINIO RUKAN	0.10	607.65	40.256
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.14	607.26	40.290
J-350	567.29	<None>	0.00	607.70	40.329
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.14	607.29	40.388
J-344	567.16	CONDOMINIO RUKAN	0.10	607.68	40.434
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.06	605.95	40.448
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.14	607.30	40.454
J-114	567.04	CONDOMINIO LAS BRISAS 3	2.79	607.63	40.509
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.14	607.63	40.525
J-334	566.99	CONDOMINIO RUKAN	0.10	607.65	40.578

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.14	607.26	40.601
J-333	566.93	CONDOMINIO RUKAN	0.10	607.65	40.639
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.14	607.34	40.682
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.14	607.06	40.723
J-352	566.81	CONDOMINIO RUKAN	0.10	607.70	40.810
J-122	566.51	CONDOMINIO LAS BRISAS 3	1.50	607.42	40.822
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.14	607.28	40.872
J-336	566.58	CONDOMINIO RUKAN	0.10	607.65	40.993
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.14	607.27	41.057
J-332	566.49	CONDOMINIO RUKAN	0.10	607.65	41.081
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.14	607.26	41.101
J-322	566.48	CONDOMINIO RUKAN	0.10	607.67	41.109
J-357	566.51	CONDOMINIO RUKAN	0.10	607.71	41.117
J-325	566.45	CONDOMINIO RUKAN	0.10	607.66	41.125
J-358	566.38	CONDOMINIO RUKAN	0.10	607.71	41.245
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.14	607.26	41.257
J-351	566.23	CONDOMINIO RUKAN	0.10	607.70	41.387
J-331	566.08	CONDOMINIO RUKAN	0.10	607.65	41.484
J-337	566.06	CONDOMINIO RUKAN	0.10	607.66	41.518
J-342	566.03	CONDOMINIO RUKAN	0.10	607.66	41.547
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.06	606.03	41.644
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.14	607.26	41.645
J-377	565.35	CONDOMINIO BORDE BLANCO 2	3.37	607.28	41.845
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.06	605.95	41.856
J-361	565.53	CONDOMINIO RUKAN	0.10	607.71	42.092
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.14	607.26	42.199
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.14	607.26	42.222
J-330	565.13	CONDOMINIO RUKAN	0.10	607.65	42.441
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.14	607.26	42.483
J-375	564.57	<None>	1.09	607.33	42.677
J-346	564.90	<None>	0.00	607.68	42.687
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.14	607.26	42.758
J-373	564.55	<None>	1.09	607.40	42.765
J-329	564.22	CONDOMINIO RUKAN	0.10	607.65	43.343
J-371	564.00	<None>	1.09	607.49	43.406
J-362	564.16	CONDOMINIO RUKAN	0.10	607.71	43.465


FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.06	606.01	43.669
J-324	563.73	CONDOMINIO RUKAN	0.10	607.66	43.840
J-356	563.68	CONDOMINIO RUKAN	0.10	607.71	43.937
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.06	605.96	44.011
J-355	563.53	CONDOMINIO RUKAN	0.10	607.70	44.082
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.14	607.05	44.198
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.14	607.26	44.223
J-353	563.38	CONDOMINIO RUKAN	0.10	607.70	44.228
J-354	563.26	CONDOMINIO RUKAN	0.10	607.70	44.347
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.06	606.03	44.396
J-321	563.15	CONDOMINIO RUKAN	0.10	607.69	44.449
J-309	563.07	CONDOMINIO RUKAN	0.10	607.70	44.533
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.06	606.03	44.628
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.06	606.03	44.684
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.14	607.26	44.688
J-319	562.88	CONDOMINIO RUKAN	0.10	607.70	44.723
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.14	607.37	44.891
J-328	562.51	CONDOMINIO RUKAN	0.10	607.65	45.053
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.14	607.27	45.224
J-327	562.22	CONDOMINIO RUKAN	0.10	607.65	45.338
J-326	562.20	CONDOMINIO RUKAN	0.10	607.66	45.364
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.14	607.03	45.424
J-312	562.17	CONDOMINIO RUKAN	0.10	607.70	45.436
J-310	561.96	CONDOMINIO RUKAN	0.10	607.70	45.645
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.06	605.96	45.733
J-320	561.76	CONDOMINIO RUKAN	0.10	607.69	45.834
J-313	561.70	CONDOMINIO RUKAN	0.10	607.69	45.899
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.06	606.03	45.936
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.14	607.04	45.950
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.14	607.04	46.066
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.14	607.36	46.167
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.14	607.03	46.209
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.14	607.34	46.393
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.14	607.05	46.394

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.14	607.05	46.636
J-311	560.78	CONDOMINIO RUKAN	0.10	607.70	46.823
J-314	560.46	CONDOMINIO RUKAN	0.10	607.69	47.139
J-315	560.12	CONDOMINIO RUKAN	0.10	607.69	47.472
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.14	607.05	48.163
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.14	607.04	48.187
J-317	558.84	CONDOMINIO RUKAN	0.10	607.69	48.754
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.14	607.03	48.924
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.14	607.27	49.076
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.14	607.03	49.373
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.14	607.26	49.425
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.14	607.03	50.231
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.14	607.35	50.242
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.14	607.03	50.308
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.14	607.05	50.519
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.14	607.26	50.601
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.14	607.03	50.652
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.14	607.34	50.764
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.14	607.08	51.013
J-316	556.36	CONDOMINIO RUKAN	0.10	607.69	51.230
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.14	607.15	51.239
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.14	607.35	51.244
J-318	555.89	CONDOMINIO RUKAN	0.10	607.69	51.700
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.14	607.25	52.281
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.14	607.25	52.481

New Graph



T-1 - Caudales maximos horarios año 10 - Level (Calculated)

FlexTable: Hydrant Table

Label	Hydrant Status	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
H-5	Open	587.66	0.00	619.00	31.271
H-1	Open	587.58	0.00	618.43	30.781
H-48	Open	586.10	0.00	619.05	32.886
H-52	Open	584.86	0.00	618.19	33.259
H-13	Open	583.85	0.00	618.98	35.056
H-50	Open	583.79	0.00	618.86	35.002
H-2	Open	583.53	0.00	618.73	35.127
H-4	Open	581.61	0.00	619.17	37.478
H-3	Open	581.53	0.00	618.93	37.328
H-12	Open	579.64	0.00	619.15	39.434
H-49	Open	579.63	0.15	618.86	39.147
H-51	Open	579.07	0.00	619.19	40.038
H-14	Open	578.50	0.00	618.16	39.577
H-10	Open	578.19	0.00	618.81	40.536
H-6	Open	576.17	0.00	619.22	42.963
H-9	Open	575.57	0.00	619.12	43.458
H-16	Open	575.02	0.00	617.38	42.278
H-19	Open	574.00	0.00	617.09	43.008
H-18	Open	573.71	0.00	617.11	43.312
H-40	Open	573.54	0.00	617.78	44.156
H-44	Open	573.25	0.00	617.22	43.884
H-38	Open	572.44	0.00	617.78	45.244
H-22	Open	572.25	0.00	617.27	44.930
H-20	Open	572.24	0.00	617.03	44.706
H-17	Open	572.06	0.00	617.13	44.979
H-15	Open	572.00	0.00	617.67	45.580
H-45	Open	570.59	0.00	617.09	46.407
H-26	Open	569.69	0.00	617.79	47.999
H-43	Open	569.30	0.00	617.59	48.193
H-21	Open	568.77	0.00	616.99	48.122
H-47	Open	568.48	0.00	616.95	48.378
H-25	Open	567.49	0.00	617.76	50.168
H-41	Open	567.06	0.00	617.76	50.603
H-27	Open	566.67	0.00	617.72	50.948
H-35	Open	565.34	0.00	617.94	52.492
H-29	Open	564.78	0.00	617.59	52.706
H-28	Open	564.00	0.00	617.66	53.549
H-42	Open	563.62	0.00	617.75	54.024
H-30	Open	563.44	0.00	617.57	54.027
H-39	Open	563.31	0.00	617.78	54.352
H-34	Open	562.75	0.00	617.48	54.618
H-46	Open	561.45	0.00	616.99	55.421
H-37	Open	560.40	0.00	617.46	56.950
H-36	Open	560.34	0.00	617.47	57.009
H-53	Open	560.06	0.00	617.57	57.393
H-24	Open	560.03	0.00	617.77	57.623
H-33	Open	556.11	0.00	617.48	61.247
H-32	Open	555.48	0.00	617.56	61.956
H-31	Open	554.18	0.00	617.57	63.259

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-25	589.08	BRISAS DE CHICUREO NORTE	0.09	619.01	29.867
J-26	588.78	BRISAS DE CHICUREO NORTE	0.09	619.00	30.164
J-28	588.57	BRISAS DE CHICUREO NORTE	2.04	618.99	30.352
J-18	588.00	BRISAS DE CHICUREO NORTE	0.09	619.04	30.973
J-19	587.16	BRISAS DE CHICUREO NORTE	0.09	619.04	31.808
J-17	587.03	BRISAS DE CHICUREO NORTE	0.09	619.02	31.930
J-11	586.98	BRISAS DE CHICUREO NORTE	0.09	619.05	32.000
J-27	586.55	BRISAS DE CHICUREO NORTE	0.09	618.99	32.375
J-48	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.87	32.808
J-47	586.00	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.87	32.809
J-76	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	32.816
J-79	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.89	32.821
J-43	586.00	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.89	32.829
J-36	585.36	<None>	1.45	618.26	32.835
J-42	586.00	<None>	0.00	618.92	32.850
J-46	585.94	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.88	32.865
J-62	585.86	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.85	32.928
J-65	585.66	<None>	0.00	618.86	33.126
J-41	585.68	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.93	33.188
J-16	585.62	BRISAS DE CHICUREO NORTE	2.04	618.91	33.221
J-61	585.46	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.85	33.330
J-10	585.63	BRISAS DE CHICUREO NORTE	0.09	619.06	33.360
J-1	584.67	<None>	4.67	618.15	33.421
J-2	584.49	<None>	1.28	618.15	33.601
J-40	585.05	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.95	33.833
J-66	584.89	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.86	33.905
J-3	584.18	<None>	1.28	618.15	33.910
J-56	584.75	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.86	34.037
J-80	584.72	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	34.094
J-24	584.83	BRISAS DE CHICUREO NORTE	0.09	619.02	34.117
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.89	34.136

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-37	584.60	<None>	0.00	618.96	34.292
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.85	34.357
J-300	583.11	CONDOMINIO RUKAN	0.07	617.79	34.610
J-9	584.37	BRISAS DE CHICUREO NORTE	0.09	619.09	34.647
J-20	584.07	BRISAS DE CHICUREO NORTE	0.09	619.04	34.899
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	34.955
J-12	583.81	BRISAS DE CHICUREO NORTE	0.09	619.03	35.141
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.86	35.278
J-15	583.58	BRISAS DE CHICUREO NORTE	0.09	618.94	35.296
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.86	35.403
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	35.469
J-21	583.46	BRISAS DE CHICUREO NORTE	0.09	619.05	35.511
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	35.709
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	35.785
J-405	582.65	SAN LUIS	1.77	618.55	35.834
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.88	35.919
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.87	36.007
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	4.78	618.91	36.033
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.86	36.058
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	36.144
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.85	36.190
J-14	582.64	BRISAS DE CHICUREO NORTE	0.09	619.01	36.294
J-101	582.72	<None>	0.09	619.22	36.430
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	36.576
J-4	582.48	<None>	0.00	619.19	36.633
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.86	36.926
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.88	36.994
J-13	581.92	BRISAS DE CHICUREO NORTE	0.09	619.01	37.016
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.86	37.085
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.15	618.85	37.141

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-8	581.84	BRISAS DE CHICUREO NORTE	0.09	619.12	37.209
J-364	580.49	CONDOMINIO RUKAN	0.07	617.79	37.225
J-5	581.70	<None>	0.00	619.17	37.391
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	37.452
J-299	580.15	CONDOMINIO RUKAN	0.07	617.80	37.578
J-23	581.37	BRISAS DE CHICUREO NORTE	0.09	619.02	37.581
J-59	581.20	CONDOMINIO 1 BRISAS- CHICUREO	0.15	618.85	37.581
J-71	581.11	CONDOMINIO 2BRISAS- CHICUREO	0.08	618.87	37.683
J-55	580.99	CONDOMINIO 1 BRISAS- CHICUREO	0.15	618.86	37.793
J-49	580.86	CONDOMINIO 1 BRISAS- CHICUREO	0.15	618.87	37.939
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	38.021
J-22	580.92	BRISAS DE CHICUREO NORTE	0.09	619.04	38.037
J-85	581.00	<None>	0.09	619.17	38.087
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	38.105
J-88	580.83	<None>	0.09	619.17	38.268
J-89	580.51	<None>	0.09	619.17	38.589
J-84	580.42	<None>	0.09	619.17	38.671
J-87	580.27	<None>	0.09	619.17	38.822
J-97	580.31	<None>	0.09	619.21	38.825
J-50	579.96	CONDOMINIO 1 BRISAS- CHICUREO	0.15	618.87	38.832
J-39	580.14	<None>	0.09	619.14	38.920
J-301	578.67	CONDOMINIO RUKAN	0.07	617.79	39.043
J-81	580.00	<None>	0.09	619.15	39.067
J-82	580.00	<None>	0.09	619.15	39.074
J-298	578.65	CONDOMINIO RUKAN	0.07	617.81	39.085
J-86	580.00	<None>	0.09	619.17	39.089
J-94	580.00	<None>	0.09	619.18	39.106
J-93	580.00	<None>	0.09	619.18	39.106
J-91	579.93	<None>	0.09	619.18	39.166
J-83	579.67	<None>	0.09	619.17	39.416
J-98	579.66	<None>	0.09	619.21	39.478
J-29	579.64	<None>	0.09	619.22	39.499
J-92	579.33	<None>	0.09	619.19	39.775
J-90	579.31	<None>	0.09	619.17	39.785
J-304	577.89	CONDOMINIO RUKAN	0.07	617.80	39.832
J-112	579.30	<None>	0.09	619.23	39.852
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	39.904
J-54	578.81	CONDOMINIO 1 BRISAS- CHICUREO	0.15	618.86	39.970
J-72	578.80	CONDOMINIO 2BRISAS- CHICUREO	0.08	618.87	39.990

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.08	618.86	40.071
J-6	578.90	BRISAS DE CHICUREO NORTE	0.09	619.16	40.186
J-102	578.94	<None>	0.09	619.22	40.198
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	40.323
J-109	578.73	<None>	0.09	619.21	40.399
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	619.15	40.573
J-7	578.48	BRISAS DE CHICUREO NORTE	0.09	619.16	40.597
J-95	578.40	<None>	0.09	619.20	40.721
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.04	616.99	40.908
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.04	616.99	40.910
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.04	616.99	40.912
J-111	578.22	<None>	0.09	619.23	40.926
J-104	578.17	<None>	0.09	619.23	40.983
J-253	576.00	CONDOMINIO LA SIEMBRA	0.14	617.08	40.999
J-291	576.00	CONDOMINIO LA TRILLA	0.13	617.23	41.143
J-242	575.72	CONDOMINIO LA SIEMBRA	0.14	617.08	41.274
J-96	577.74	<None>	0.09	619.21	41.392
J-277	575.74	CONDOMINIO LA TRILLA	0.13	617.23	41.404
J-100	577.57	<None>	0.09	619.22	41.562
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.04	616.99	41.582
J-105	577.42	<None>	0.09	619.23	41.724
J-99	577.36	<None>	0.09	619.22	41.769
J-303	575.85	CONDOMINIO RUKAN	0.07	617.79	41.854
J-305	575.80	CONDOMINIO RUKAN	0.07	617.80	41.919
J-35	576.93	<None>	0.99	619.01	41.992
J-363	575.69	CONDOMINIO RUKAN	0.07	617.79	42.009
J-297	575.70	CONDOMINIO RUKAN	0.07	617.82	42.039
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.04	616.95	42.128
J-173	575.06	<None>	0.55	617.39	42.248
J-267	574.77	CONDOMINIO LA TRILLA	0.13	617.22	42.371
J-258	574.89	<None>	0.00	617.35	42.383
J-287	574.68	CONDOMINIO LA TRILLA	0.13	617.23	42.464
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.04	616.99	42.507
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.04	616.99	42.507
J-292	574.50	CONDOMINIO LA TRILLA	0.13	617.22	42.637
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.04	616.99	42.659
J-259	574.54	<None>	0.55	617.32	42.696
J-245	574.28	CONDOMINIO LA SIEMBRA	0.14	617.08	42.712

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-254	574.24	CONDOMINIO LA SIEMBRA	0.14	617.08	42.758
J-264	574.31	CONDOMINIO LA TRILLA	0.13	617.23	42.842
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.04	616.95	42.866
J-289	574.20	CONDOMINIO LA TRILLA	0.13	617.23	42.950
J-290	574.15	CONDOMINIO LA TRILLA	0.13	617.22	42.990
J-233	574.00	CONDOMINIO LA SIEMBRA	0.14	617.09	43.000
J-232	574.00	CONDOMINIO LA SIEMBRA	0.14	617.09	43.000
J-231	574.00	CONDOMINIO LA SIEMBRA	0.14	617.09	43.001
J-257	574.00	CONDOMINIO LA SIEMBRA	0.14	617.09	43.002
J-268	574.09	CONDOMINIO LA TRILLA	0.13	617.22	43.044
J-283	574.00	CONDOMINIO LA TRILLA	0.13	617.22	43.140
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.04	617.00	43.178
J-274	573.93	CONDOMINIO LA TRILLA	0.13	617.24	43.223
J-106	575.90	<None>	0.09	619.23	43.246
J-34	575.78	<None>	0.09	619.13	43.267
J-284	573.82	CONDOMINIO LA TRILLA	0.13	617.22	43.319
J-103	575.79	<None>	0.09	619.24	43.367
J-33	575.65	<None>	0.09	619.17	43.440
J-263	573.68	CONDOMINIO LA TRILLA	0.13	617.24	43.474
J-237	573.42	CONDOMINIO LA SIEMBRA	0.14	617.09	43.575
J-339	574.08	CONDOMINIO RUKAN	0.07	617.78	43.613
J-256	573.36	CONDOMINIO LA SIEMBRA	0.14	617.09	43.645
J-307	573.85	CONDOMINIO RUKAN	0.07	617.78	43.846
J-230	573.06	CONDOMINIO LA SIEMBRA	0.14	617.09	43.939
J-273	573.20	CONDOMINIO LA TRILLA	0.13	617.23	43.940
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.04	616.99	44.009
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.09	617.58	44.015
J-236	572.96	CONDOMINIO LA SIEMBRA	0.14	617.09	44.037
J-235	572.84	CONDOMINIO LA SIEMBRA	0.14	617.09	44.157
J-266	572.94	CONDOMINIO LA TRILLA	0.13	617.22	44.198
J-269	572.92	CONDOMINIO LA TRILLA	0.13	617.22	44.219
J-365	573.40	CONDOMINIO RUKAN	0.07	617.78	44.288
J-286	572.84	CONDOMINIO LA TRILLA	0.13	617.22	44.294
J-347	573.38	CONDOMINIO RUKAN	0.07	617.78	44.308
J-349	573.30	CONDOMINIO RUKAN	0.07	617.78	44.385
J-285	572.69	CONDOMINIO LA TRILLA	0.13	617.22	44.444
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.04	616.99	44.445
J-30	574.69	<None>	0.09	619.24	44.459
J-255	572.50	CONDOMINIO LA SIEMBRA	0.14	617.09	44.498

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-275	572.54	CONDOMINIO LA TRILLA	0.13	617.23	44.605
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.04	616.95	44.687
J-234	572.29	CONDOMINIO LA SIEMBRA	0.14	617.09	44.712
J-107	574.43	<None>	0.09	619.24	44.713
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.04	616.99	44.722
J-238	572.25	CONDOMINIO LA SIEMBRA	0.14	617.09	44.752
J-262	572.35	<None>	0.00	617.27	44.830
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.04	616.99	44.928
J-407	574.27	<None>	0.00	619.34	44.976
J-229	572.00	CONDOMINIO LA SIEMBRA	0.14	617.09	45.003
J-239	571.97	CONDOMINIO LA SIEMBRA	0.14	617.08	45.025
J-249	571.94	CONDOMINIO LA SIEMBRA	0.14	617.09	45.065
J-240	571.92	CONDOMINIO LA SIEMBRA	0.14	617.08	45.074
J-293	572.06	<None>	0.55	617.26	45.115
J-272	571.78	CONDOMINIO LA TRILLA	0.13	617.23	45.359
J-250	571.58	CONDOMINIO LA SIEMBRA	0.14	617.08	45.410
J-174	571.62	<None>	0.55	617.14	45.426
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.04	617.01	45.462
J-265	571.65	CONDOMINIO LA TRILLA	0.13	617.23	45.480
J-228	571.51	CONDOMINIO LA SIEMBRA	0.14	617.10	45.499
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.96	617.65	45.554
J-260	571.62	<None>	0.00	617.29	45.573
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.04	616.99	45.668
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.96	617.68	45.707
J-244	571.26	CONDOMINIO LA SIEMBRA	0.14	617.08	45.727
J-261	571.29	<None>	0.55	617.29	45.904
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.04	616.95	45.906
J-163	571.57	CONDOMINIO LAS BRISAS 3	1.00	617.60	45.937
J-247	571.03	CONDOMINIO LA SIEMBRA	0.14	617.08	45.963
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.09	617.57	46.042
J-251	570.94	CONDOMINIO LA SIEMBRA	0.14	617.09	46.054
J-246	570.92	CONDOMINIO LA SIEMBRA	0.14	617.08	46.069
J-276	571.05	CONDOMINIO LA TRILLA	0.13	617.23	46.083

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.04	617.02	46.160
J-32	572.86	<None>	0.09	619.23	46.272
J-406	572.89	<None>	0.00	619.26	46.275
J-31	572.85	<None>	0.09	619.25	46.313
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.09	617.58	46.339
J-241	570.57	CONDOMINIO LA SIEMBRA	0.14	617.08	46.423
J-162	571.04	CONDOMINIO LAS BRISAS 3	1.00	617.60	46.470
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.04	616.99	46.471
J-175	570.44	<None>	0.00	617.03	46.491
J-279	570.60	CONDOMINIO LA TRILLA	0.13	617.23	46.535
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.96	617.66	46.662
J-348	570.98	CONDOMINIO RUKAN	0.07	617.78	46.704
J-271	570.38	CONDOMINIO LA TRILLA	0.13	617.23	46.756
J-113	571.08	<None>	2.90	617.98	46.811
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.09	617.60	46.857
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.04	616.95	46.956
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.04	616.95	46.981
J-243	570.00	CONDOMINIO LA SIEMBRA	0.14	617.08	46.988
J-248	570.00	CONDOMINIO LA SIEMBRA	0.14	617.09	46.992
J-252	570.00	CONDOMINIO LA SIEMBRA	0.14	617.09	46.996
J-308	570.59	CONDOMINIO RUKAN	0.07	617.78	47.092
J-270	570.00	CONDOMINIO LA TRILLA	0.13	617.23	47.131
J-161	570.30	CONDOMINIO LAS BRISAS 3	1.00	617.60	47.207
J-278	569.90	CONDOMINIO LA TRILLA	0.13	617.23	47.230
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.04	616.95	47.231
J-360	570.45	CONDOMINIO RUKAN	0.07	617.78	47.235
J-160	569.98	CONDOMINIO LAS BRISAS 3	1.00	617.61	47.536
J-282	569.56	CONDOMINIO LA TRILLA	0.13	617.22	47.570
J-302	570.02	CONDOMINIO RUKAN	0.07	617.79	47.666
J-296	570.00	<None>	0.00	617.83	47.733
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.04	617.03	47.981
J-306	569.69	CONDOMINIO RUKAN	0.07	617.79	47.998
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.04	616.95	48.017
J-281	569.04	CONDOMINIO LA TRILLA	0.13	617.22	48.088
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.09	617.59	48.097
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.04	617.00	48.169

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-294	569.53	<None>	1.45	617.83	48.199
J-295	569.50	<None>	0.00	617.83	48.232
J-343	569.39	CONDOMINIO RUKAN	0.07	617.76	48.280
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.04	617.01	48.350
J-366	569.22	CONDOMINIO RUKAN	0.07	617.78	48.462
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.09	617.58	48.592
J-280	568.45	CONDOMINIO LA TRILLA	0.13	617.22	48.675
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.04	617.02	48.756
J-338	568.83	CONDOMINIO RUKAN	0.07	617.77	48.836
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.09	617.57	48.890
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.96	617.70	48.909
J-341	568.69	CONDOMINIO RUKAN	0.07	617.76	48.966
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.09	617.57	48.983
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.09	617.57	49.002
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.09	617.57	49.102
J-404	567.81	REMANSO DE CHICUREO	0.16	617.07	49.155
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.09	617.57	49.169
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.04	616.95	49.301
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.04	616.95	49.332
J-340	568.30	CONDOMINIO RUKAN	0.07	617.76	49.356
J-115	568.13	CONDOMINIO LAS BRISAS 3	1.00	617.70	49.476
J-121	568.03	CONDOMINIO LAS BRISAS 3	1.00	617.67	49.539
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.09	617.59	49.548
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.04	616.95	49.582
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.09	617.60	49.641
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.09	617.57	49.648
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.04	616.99	49.672
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.04	617.01	49.682
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.04	616.95	49.736
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.09	617.59	49.798
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.09	617.58	49.869
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.04	616.95	49.969

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-323	567.67	CONDOMINIO RUKAN	0.07	617.76	49.989
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.09	617.57	50.007
J-370	567.56	<None>	0.86	617.73	50.076
J-359	567.58	CONDOMINIO RUKAN	0.07	617.78	50.102
J-367	567.48	<None>	2.31	617.75	50.168
J-345	567.47	CONDOMINIO RUKAN	0.07	617.76	50.190
J-123	567.29	CONDOMINIO LAS BRISAS 3	1.00	617.62	50.234
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.09	617.57	50.285
J-335	567.32	CONDOMINIO RUKAN	0.07	617.75	50.337
J-350	567.29	<None>	0.00	617.78	50.383
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.04	616.99	50.451
J-344	567.16	CONDOMINIO RUKAN	0.07	617.76	50.503
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.09	617.57	50.576
J-114	567.04	CONDOMINIO LAS BRISAS 3	1.86	617.75	50.600
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.09	617.74	50.617
J-334	566.99	CONDOMINIO RUKAN	0.07	617.75	50.659
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.09	617.58	50.661
J-333	566.93	CONDOMINIO RUKAN	0.07	617.75	50.720
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.09	617.59	50.723
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.04	616.97	50.810
J-352	566.81	CONDOMINIO RUKAN	0.07	617.78	50.865
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.09	617.57	50.887
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.09	617.60	50.930
J-122	566.51	CONDOMINIO LAS BRISAS 3	1.00	617.64	51.027
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.04	617.00	51.033
J-336	566.58	CONDOMINIO RUKAN	0.07	617.75	51.074
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.09	617.48	51.114
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.04	616.99	51.142
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.09	617.58	51.150
J-332	566.49	CONDOMINIO RUKAN	0.07	617.75	51.162
J-357	566.51	CONDOMINIO RUKAN	0.07	617.78	51.169
J-322	566.48	CONDOMINIO RUKAN	0.07	617.76	51.179
J-325	566.45	CONDOMINIO RUKAN	0.07	617.76	51.203
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.04	616.96	51.216
J-358	566.38	CONDOMINIO RUKAN	0.07	617.78	51.297
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.09	617.57	51.341

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.09	617.57	51.387
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.04	616.95	51.425
J-351	566.23	CONDOMINIO RUKAN	0.07	617.78	51.442
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.09	617.57	51.544
J-331	566.08	CONDOMINIO RUKAN	0.07	617.75	51.565
J-337	566.06	CONDOMINIO RUKAN	0.07	617.76	51.595
J-342	566.03	CONDOMINIO RUKAN	0.07	617.76	51.624
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.09	617.57	51.931
J-377	565.35	CONDOMINIO BORDE BLANCO 2	2.25	617.58	52.122
J-361	565.53	CONDOMINIO RUKAN	0.07	617.78	52.142
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.09	617.57	52.486
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.09	617.57	52.509
J-330	565.13	CONDOMINIO RUKAN	0.07	617.76	52.520
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.04	616.99	52.580
J-346	564.90	<None>	0.00	617.76	52.756
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.09	617.57	52.770
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.04	616.95	52.833
J-375	564.57	<None>	0.73	617.60	52.927
J-373	564.55	<None>	0.73	617.64	52.978
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.09	617.57	53.045
J-329	564.22	CONDOMINIO RUKAN	0.07	617.75	53.423
J-362	564.16	CONDOMINIO RUKAN	0.07	617.78	53.517
J-371	564.00	<None>	0.73	617.68	53.571
J-324	563.73	CONDOMINIO RUKAN	0.07	617.76	53.918
J-356	563.68	CONDOMINIO RUKAN	0.07	617.78	53.989
J-355	563.53	CONDOMINIO RUKAN	0.07	617.78	54.136
J-353	563.38	CONDOMINIO RUKAN	0.07	617.78	54.284
J-354	563.26	CONDOMINIO RUKAN	0.07	617.78	54.405
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.09	617.57	54.509
J-321	563.15	CONDOMINIO RUKAN	0.07	617.77	54.512
J-309	563.07	CONDOMINIO RUKAN	0.07	617.78	54.591
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.09	617.47	54.594
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.04	616.98	54.614
J-319	562.88	CONDOMINIO RUKAN	0.07	617.77	54.782
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.09	617.57	54.975
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.04	616.96	54.982
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.09	617.62	55.120
J-328	562.51	CONDOMINIO RUKAN	0.07	617.75	55.134

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.04	616.99	55.331
J-327	562.22	CONDOMINIO RUKAN	0.07	617.75	55.418
J-326	562.20	CONDOMINIO RUKAN	0.07	617.76	55.443
J-312	562.17	CONDOMINIO RUKAN	0.07	617.77	55.494
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.09	617.57	55.505
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.04	616.99	55.565
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.04	616.99	55.620
J-310	561.96	CONDOMINIO RUKAN	0.07	617.77	55.703
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.09	617.46	55.831
J-320	561.76	CONDOMINIO RUKAN	0.07	617.77	55.897
J-313	561.70	CONDOMINIO RUKAN	0.07	617.77	55.959
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.09	617.46	56.354
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.09	617.62	56.403
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.09	617.46	56.472
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.09	617.46	56.616
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.09	617.61	56.639
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.04	616.96	56.705
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.09	617.47	56.792
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.04	616.99	56.872
J-311	560.78	CONDOMINIO RUKAN	0.07	617.77	56.881
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.09	617.47	57.036
J-314	560.46	CONDOMINIO RUKAN	0.07	617.77	57.200
J-315	560.12	CONDOMINIO RUKAN	0.07	617.77	57.533
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.09	617.47	58.563
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.09	617.47	58.590
J-317	558.84	CONDOMINIO RUKAN	0.07	617.77	58.814
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.09	617.46	59.335
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.09	617.57	59.360
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.09	617.57	59.712
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.09	617.46	59.783
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.09	617.61	60.481
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.09	617.46	60.642

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.09	617.46	60.719
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.09	617.57	60.887
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.09	617.47	60.918
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.09	617.61	61.008
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.09	617.46	61.063
J-316	556.36	CONDOMINIO RUKAN	0.07	617.77	61.290
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.09	617.48	61.397
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.09	617.61	61.486
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.09	617.52	61.586
J-318	555.89	CONDOMINIO RUKAN	0.07	617.77	61.759
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.09	617.56	62.573
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.09	617.56	62.773

AÑO 15

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-1	584.67	<None>	14.32	596.79	12.102
J-2	584.49	<None>	9.32	596.81	12.294
J-3	584.18	<None>	9.32	596.79	12.591
J-25	589.08	BRISAS DE CHICUREO NORTE	0.13	613.68	24.552
J-26	588.78	BRISAS DE CHICUREO NORTE	0.13	613.67	24.841
J-28	588.57	BRISAS DE CHICUREO NORTE	3.01	613.64	25.014
J-18	588.00	BRISAS DE CHICUREO NORTE	0.13	613.74	25.686
J-19	587.16	BRISAS DE CHICUREO NORTE	0.13	613.74	26.521
J-17	587.03	BRISAS DE CHICUREO NORTE	0.13	613.71	26.626
J-11	586.98	BRISAS DE CHICUREO NORTE	0.13	613.76	26.723
J-36	585.36	<None>	2.14	612.44	27.027
J-27	586.55	BRISAS DE CHICUREO NORTE	0.13	613.65	27.043
J-76	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.33	27.278
J-48	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.34	27.283
J-47	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.34	27.283
J-79	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.36	27.301
J-43	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.39	27.333
J-46	585.94	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.34	27.341
J-62	585.86	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.27	27.351
J-42	586.00	<None>	0.00	613.46	27.401
J-65	585.66	<None>	0.00	613.27	27.548
J-61	585.46	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.26	27.753
J-41	585.68	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.50	27.771
J-16	585.62	BRISAS DE CHICUREO NORTE	3.01	613.48	27.802
J-10	585.63	BRISAS DE CHICUREO NORTE	0.13	613.79	28.097
J-300	583.11	CONDOMINIO RUKAN	0.10	611.47	28.303
J-66	584.89	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.27	28.326
J-40	585.05	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.56	28.453
J-56	584.75	CONDOMINIO 1 BRISAS- CHICUREO	0.22	613.28	28.472
J-80	584.72	CONDOMINIO 2BRISAS- CHICUREO	0.22	613.32	28.546

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-44	584.68	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.36	28.626
J-63	584.43	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.26	28.779
J-24	584.83	BRISAS DE CHICUREO NORTE	0.13	613.70	28.810
J-37	584.60	<None>	0.00	613.61	28.950
J-75	583.85	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.31	29.400
J-9	584.37	BRISAS DE CHICUREO NORTE	0.13	613.84	29.413
J-20	584.07	BRISAS DE CHICUREO NORTE	0.13	613.74	29.612
J-69	583.51	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.28	29.703
J-12	583.81	BRISAS DE CHICUREO NORTE	0.13	613.72	29.844
PCP- 11	583.39	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.31	29.858
J-15	583.58	BRISAS DE CHICUREO NORTE	0.13	613.55	29.913
J-77	583.34	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.33	29.928
J-78	583.10	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.33	30.168
J-21	583.46	BRISAS DE CHICUREO NORTE	0.13	613.76	30.235
J-405	582.65	SAN LUIS	2.61	613.04	30.332
J-45	582.89	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.34	30.397
J-70	582.79	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.29	30.436
J-52	582.73	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.31	30.513
J-60	582.59	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.27	30.613
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.97	30.616
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	7.06	613.50	30.636
J-364	580.49	CONDOMINIO RUKAN	0.10	611.47	30.919
J-14	582.64	BRISAS DE CHICUREO NORTE	0.13	613.68	30.975
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.97	30.975
J-73	582.23	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.31	31.019
J-299	580.15	CONDOMINIO RUKAN	0.10	611.50	31.286
J-51	581.86	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.31	31.382
J-74	581.81	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.31	31.436
J-67	581.70	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.27	31.504

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-4	582.48	<None>	0.00	614.06	31.511
J-64	581.64	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.26	31.563
J-101	582.72	<None>	0.13	614.40	31.623
J-13	581.92	BRISAS DE CHICUREO NORTE	0.13	613.69	31.704
J-59	581.20	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.27	32.006
J-8	581.84	BRISAS DE CHICUREO NORTE	0.13	613.91	32.011
J-71	581.11	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.28	32.110
J-55	580.99	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.28	32.228
J-5	581.70	<None>	0.00	614.01	32.244
J-23	581.37	BRISAS DE CHICUREO NORTE	0.13	613.71	32.281
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.97	32.284
J-49	580.86	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.33	32.405
J-301	578.67	CONDOMINIO RUKAN	0.10	611.47	32.736
J-22	580.92	BRISAS DE CHICUREO NORTE	0.13	613.74	32.751
J-298	578.65	CONDOMINIO RUKAN	0.10	611.52	32.807
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.97	32.853
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.98	32.942
J-85	581.00	<None>	0.13	614.20	33.131
J-50	579.96	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.31	33.290
J-88	580.83	<None>	0.13	614.23	33.332
J-304	577.89	CONDOMINIO RUKAN	0.10	611.50	33.540
J-89	580.51	<None>	0.13	614.23	33.652
J-84	580.42	<None>	0.13	614.19	33.706
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.06	609.83	33.762
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.06	609.83	33.765
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.06	609.84	33.770
J-87	580.27	<None>	0.13	614.20	33.866
J-39	580.14	<None>	0.13	614.08	33.872
J-253	576.00	CONDOMINIO LA SIEMBRA	0.21	610.02	33.948
J-97	580.31	<None>	0.13	614.38	34.004
J-81	580.00	<None>	0.13	614.10	34.035
J-82	580.00	<None>	0.13	614.13	34.065
J-86	580.00	<None>	0.13	614.20	34.133
J-94	580.00	<None>	0.13	614.28	34.211
J-93	580.00	<None>	0.13	614.28	34.211

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-242	575.72	CONDOMINIO LA SIEMBRA	0.21	610.02	34.223
J-291	576.00	CONDOMINIO LA TRILLA	0.20	610.31	34.245
J-91	579.93	<None>	0.13	614.25	34.251
J-54	578.81	CONDOMINIO 1 BRISAS-CHICUREO	0.22	613.28	34.407
J-72	578.80	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.28	34.416
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.06	609.83	34.434
J-83	579.67	<None>	0.13	614.18	34.441
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.22	613.27	34.489
J-277	575.74	CONDOMINIO LA TRILLA	0.20	610.32	34.509
J-29	579.64	<None>	0.13	614.25	34.544
J-98	579.66	<None>	0.13	614.38	34.657
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.98	34.740
J-90	579.31	<None>	0.13	614.23	34.848
J-92	579.33	<None>	0.13	614.28	34.881
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.06	609.75	34.940
J-112	579.30	<None>	0.13	614.38	35.011
J-6	578.90	BRISAS DE CHICUREO NORTE	0.13	614.00	35.033
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.98	35.161
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.06	609.82	35.357
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.06	609.83	35.360
J-102	578.94	<None>	0.13	614.40	35.392
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.17	613.97	35.407
J-7	578.48	BRISAS DE CHICUREO NORTE	0.13	614.00	35.444
J-267	574.77	CONDOMINIO LA TRILLA	0.20	610.31	35.470
J-109	578.73	<None>	0.13	614.30	35.507
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.06	609.83	35.512
J-173	575.06	<None>	0.81	610.65	35.521
J-303	575.85	CONDOMINIO RUKAN	0.10	611.47	35.547
J-287	574.68	CONDOMINIO LA TRILLA	0.20	610.32	35.567
J-258	574.89	<None>	0.00	610.58	35.619
J-305	575.80	CONDOMINIO RUKAN	0.10	611.49	35.624
J-245	574.28	CONDOMINIO LA SIEMBRA	0.21	610.02	35.662
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.06	609.75	35.679
J-363	575.69	CONDOMINIO RUKAN	0.10	611.47	35.703
J-254	574.24	CONDOMINIO LA SIEMBRA	0.21	610.02	35.709
J-292	574.50	CONDOMINIO LA TRILLA	0.20	610.31	35.735

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-297	575.70	CONDOMINIO RUKAN	0.10	611.54	35.771
J-95	578.40	<None>	0.13	614.34	35.866
J-259	574.54	<None>	0.81	610.51	35.898
J-264	574.31	CONDOMINIO LA TRILLA	0.20	610.33	35.952
J-233	574.00	CONDOMINIO LA SIEMBRA	0.21	610.03	35.955
J-232	574.00	CONDOMINIO LA SIEMBRA	0.21	610.03	35.956
J-231	574.00	CONDOMINIO LA SIEMBRA	0.21	610.03	35.957
J-257	574.00	CONDOMINIO LA SIEMBRA	0.21	610.03	35.959
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.06	609.84	36.038
J-289	574.20	CONDOMINIO LA TRILLA	0.20	610.33	36.060
J-111	578.22	<None>	0.13	614.38	36.085
J-290	574.15	CONDOMINIO LA TRILLA	0.20	610.31	36.089
J-104	578.17	<None>	0.13	614.38	36.143
J-268	574.09	CONDOMINIO LA TRILLA	0.20	610.31	36.143
J-283	574.00	CONDOMINIO LA TRILLA	0.20	610.31	36.237
J-274	573.93	CONDOMINIO LA TRILLA	0.20	610.34	36.335
J-284	573.82	CONDOMINIO LA TRILLA	0.20	610.31	36.417
J-237	573.42	CONDOMINIO LA SIEMBRA	0.21	610.03	36.530
J-96	577.74	<None>	0.13	614.38	36.571
J-263	573.68	CONDOMINIO LA TRILLA	0.20	610.35	36.594
J-256	573.36	CONDOMINIO LA SIEMBRA	0.21	610.03	36.602
J-100	577.57	<None>	0.13	614.40	36.756
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.06	609.82	36.859
J-105	577.42	<None>	0.13	614.38	36.884
J-230	573.06	CONDOMINIO LA SIEMBRA	0.21	610.03	36.897
J-99	577.36	<None>	0.13	614.40	36.957
J-35	576.93	<None>	1.47	613.97	36.968
J-236	572.96	CONDOMINIO LA SIEMBRA	0.21	610.03	36.992
J-273	573.20	CONDOMINIO LA TRILLA	0.20	610.33	37.049
J-235	572.84	CONDOMINIO LA SIEMBRA	0.21	610.03	37.113
J-339	574.08	CONDOMINIO RUKAN	0.10	611.45	37.297
J-266	572.94	CONDOMINIO LA TRILLA	0.20	610.31	37.298
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.06	609.83	37.299
J-269	572.92	CONDOMINIO LA TRILLA	0.20	610.31	37.319
J-286	572.84	CONDOMINIO LA TRILLA	0.20	610.31	37.394
J-255	572.50	CONDOMINIO LA SIEMBRA	0.21	610.03	37.456
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.14	611.04	37.489
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.06	609.75	37.500

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-307	573.85	CONDOMINIO RUKAN	0.10	611.46	37.533
J-285	572.69	CONDOMINIO LA TRILLA	0.20	610.31	37.543
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.06	609.83	37.575
J-234	572.29	CONDOMINIO LA SIEMBRA	0.21	610.03	37.669
J-238	572.25	CONDOMINIO LA SIEMBRA	0.21	610.03	37.709
J-275	572.54	CONDOMINIO LA TRILLA	0.20	610.33	37.713
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.06	609.84	37.785
J-229	572.00	CONDOMINIO LA SIEMBRA	0.21	610.04	37.964
J-262	572.35	<None>	0.00	610.39	37.972
J-365	573.40	CONDOMINIO RUKAN	0.10	611.46	37.975
J-239	571.97	CONDOMINIO LA SIEMBRA	0.21	610.02	37.976
J-347	573.38	CONDOMINIO RUKAN	0.10	611.45	37.991
J-240	571.92	CONDOMINIO LA SIEMBRA	0.21	610.02	38.023
J-249	571.94	CONDOMINIO LA SIEMBRA	0.21	610.04	38.026
J-349	573.30	CONDOMINIO RUKAN	0.10	611.45	38.068
J-293	572.06	<None>	0.81	610.39	38.256
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.06	609.86	38.333
J-250	571.58	CONDOMINIO LA SIEMBRA	0.21	610.02	38.362
J-34	575.78	<None>	0.13	614.23	38.375
J-106	575.90	<None>	0.13	614.38	38.404
J-174	571.62	<None>	0.81	610.13	38.434
J-228	571.51	CONDOMINIO LA SIEMBRA	0.21	610.05	38.465
J-272	571.78	CONDOMINIO LA TRILLA	0.20	610.32	38.466
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.06	609.82	38.518
J-103	575.79	<None>	0.13	614.42	38.554
J-265	571.65	CONDOMINIO LA TRILLA	0.20	610.31	38.582
J-33	575.65	<None>	0.13	614.32	38.594
J-244	571.26	CONDOMINIO LA SIEMBRA	0.21	610.02	38.678
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.06	609.75	38.718
J-260	571.62	<None>	0.00	610.44	38.738
J-247	571.03	CONDOMINIO LA SIEMBRA	0.21	610.02	38.915
J-251	570.94	CONDOMINIO LA SIEMBRA	0.21	610.03	39.009
J-246	570.92	CONDOMINIO LA SIEMBRA	0.21	610.02	39.019
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.06	609.88	39.040
J-261	571.29	<None>	0.81	610.44	39.068

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-120	572.00	CONDOMINIO LAS BRISAS 3	1.41	611.19	39.102
J-276	571.05	CONDOMINIO LA TRILLA	0.20	610.31	39.185
J-118	571.88	CONDOMINIO LAS BRISAS 3	1.41	611.24	39.282
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.06	609.82	39.321
J-241	570.57	CONDOMINIO LA SIEMBRA	0.21	610.02	39.373
J-175	570.44	<None>	0.00	609.91	39.385
J-163	571.57	CONDOMINIO LAS BRISAS 3	1.47	611.09	39.435
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.14	611.03	39.510
J-30	574.69	<None>	0.13	614.39	39.615
J-279	570.60	CONDOMINIO LA TRILLA	0.20	610.31	39.636
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.06	609.75	39.767
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.06	609.75	39.793
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.14	611.04	39.813
J-271	570.38	CONDOMINIO LA TRILLA	0.20	610.31	39.857
J-107	574.43	<None>	0.13	614.38	39.870
J-243	570.00	CONDOMINIO LA SIEMBRA	0.21	610.02	39.938
J-248	570.00	CONDOMINIO LA SIEMBRA	0.21	610.03	39.948
J-252	570.00	CONDOMINIO LA SIEMBRA	0.21	610.04	39.955
J-162	571.04	CONDOMINIO LAS BRISAS 3	1.47	611.09	39.967
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.06	609.75	40.043
J-119	570.91	CONDOMINIO LAS BRISAS 3	1.41	611.21	40.223
J-270	570.00	CONDOMINIO LA TRILLA	0.20	610.31	40.232
J-278	569.90	CONDOMINIO LA TRILLA	0.20	610.31	40.332
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.14	611.09	40.356
J-407	574.27	<None>	0.00	614.73	40.375
J-348	570.98	CONDOMINIO RUKAN	0.10	611.45	40.387
J-282	569.56	CONDOMINIO LA TRILLA	0.20	610.31	40.668
J-161	570.30	CONDOMINIO LAS BRISAS 3	1.47	611.09	40.708
J-113	571.08	<None>	4.28	611.87	40.708
J-308	570.59	CONDOMINIO RUKAN	0.10	611.45	40.775
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.06	609.75	40.830
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.06	609.90	40.871
J-360	570.45	CONDOMINIO RUKAN	0.10	611.46	40.924

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.06	609.85	41.034
J-160	569.98	CONDOMINIO LAS BRISAS 3	1.47	611.10	41.043
J-281	569.04	CONDOMINIO LA TRILLA	0.20	610.31	41.185
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.06	609.86	41.222
J-302	570.02	CONDOMINIO RUKAN	0.10	611.47	41.359
J-296	570.00	<None>	0.00	611.55	41.467
J-32	572.86	<None>	0.13	614.43	41.484
J-406	572.89	<None>	0.00	614.50	41.521
J-31	572.85	<None>	0.13	614.45	41.524
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.14	611.06	41.579
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.06	609.89	41.643
J-306	569.69	CONDOMINIO RUKAN	0.10	611.47	41.692
J-280	568.45	CONDOMINIO LA TRILLA	0.20	610.31	41.773
J-294	569.53	<None>	2.14	611.55	41.934
J-343	569.39	CONDOMINIO RUKAN	0.10	611.42	41.949
J-295	569.50	<None>	0.00	611.55	41.967
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.14	611.04	42.066
J-404	567.81	REMANSO DE CHICUREO	0.23	609.98	42.088
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.06	609.75	42.113
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.06	609.75	42.144
J-366	569.22	CONDOMINIO RUKAN	0.10	611.46	42.148
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.14	611.02	42.353
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.06	609.75	42.394
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.14	611.02	42.447
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.14	611.03	42.468
J-338	568.83	CONDOMINIO RUKAN	0.10	611.42	42.506
J-117	568.69	CONDOMINIO LAS BRISAS 3	1.41	611.29	42.509
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.06	609.83	42.524
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.06	609.75	42.549
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.06	609.88	42.561
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.14	611.03	42.571
J-341	568.69	CONDOMINIO RUKAN	0.10	611.41	42.627
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.14	611.02	42.634
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.06	609.76	42.784

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-340	568.30	CONDOMINIO RUKAN	0.10	611.41	43.017
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.14	611.07	43.037
J-115	568.13	CONDOMINIO LAS BRISAS 3	1.47	611.30	43.082
J-121	568.03	CONDOMINIO LAS BRISAS 3	1.47	611.23	43.110
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.14	611.02	43.111
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.14	611.09	43.139
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.14	611.05	43.278
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.06	609.82	43.301
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.14	611.04	43.340
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.14	611.02	43.470
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.06	609.79	43.642
J-323	567.67	CONDOMINIO RUKAN	0.10	611.41	43.653
J-370	567.56	<None>	1.27	611.36	43.713
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.14	611.03	43.753
J-123	567.29	CONDOMINIO LAS BRISAS 3	1.47	611.13	43.755
J-359	567.58	CONDOMINIO RUKAN	0.10	611.46	43.792
J-367	567.48	<None>	3.41	611.40	43.826
J-345	567.47	CONDOMINIO RUKAN	0.10	611.42	43.859
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.06	609.84	43.891
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.06	609.82	43.992
J-335	567.32	CONDOMINIO RUKAN	0.10	611.40	43.995
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.14	611.02	44.040
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.06	609.78	44.042
J-350	567.29	<None>	0.00	611.45	44.066
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.14	611.04	44.138
J-344	567.16	CONDOMINIO RUKAN	0.10	611.42	44.172
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.14	611.05	44.203
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.06	609.75	44.237
J-114	567.04	CONDOMINIO LAS BRISAS 3	2.74	611.38	44.248
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.14	611.38	44.265
J-334	566.99	CONDOMINIO RUKAN	0.10	611.40	44.317

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.14	611.02	44.351
J-333	566.93	CONDOMINIO RUKAN	0.10	611.40	44.377
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.14	611.09	44.430
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.14	610.83	44.479
J-352	566.81	CONDOMINIO RUKAN	0.10	611.45	44.547
J-122	566.51	CONDOMINIO LAS BRISAS 3	1.47	611.17	44.568
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.14	611.04	44.622
J-336	566.58	CONDOMINIO RUKAN	0.10	611.40	44.732
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.14	611.02	44.807
J-332	566.49	CONDOMINIO RUKAN	0.10	611.40	44.820
J-322	566.48	CONDOMINIO RUKAN	0.10	611.42	44.847
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.14	611.02	44.851
J-357	566.51	CONDOMINIO RUKAN	0.10	611.45	44.854
J-325	566.45	CONDOMINIO RUKAN	0.10	611.40	44.863
J-358	566.38	CONDOMINIO RUKAN	0.10	611.45	44.982
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.14	611.02	45.008
J-351	566.23	CONDOMINIO RUKAN	0.10	611.45	45.124
J-331	566.08	CONDOMINIO RUKAN	0.10	611.40	45.223
J-337	566.06	CONDOMINIO RUKAN	0.10	611.41	45.257
J-342	566.03	CONDOMINIO RUKAN	0.10	611.41	45.285
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.14	611.02	45.395
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.06	609.82	45.430
J-377	565.35	CONDOMINIO BORDE BLANCO 2	3.32	611.04	45.595
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.06	609.75	45.645
J-361	565.53	CONDOMINIO RUKAN	0.10	611.46	45.829
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.14	611.02	45.949
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.14	611.02	45.972
J-330	565.13	CONDOMINIO RUKAN	0.10	611.40	46.179
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.14	611.02	46.233
J-346	564.90	<None>	0.00	611.42	46.425
J-375	564.57	<None>	1.07	611.09	46.426
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.14	611.02	46.508
J-373	564.55	<None>	1.07	611.16	46.511
J-329	564.22	CONDOMINIO RUKAN	0.10	611.40	47.082
J-371	564.00	<None>	1.07	611.24	47.150
J-362	564.16	CONDOMINIO RUKAN	0.10	611.45	47.202


FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.06	609.81	47.455
J-324	563.73	CONDOMINIO RUKAN	0.10	611.40	47.578
J-356	563.68	CONDOMINIO RUKAN	0.10	611.45	47.674
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.06	609.76	47.799
J-355	563.53	CONDOMINIO RUKAN	0.10	611.45	47.819
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.14	610.82	47.955
J-353	563.38	CONDOMINIO RUKAN	0.10	611.45	47.965
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.14	611.02	47.973
J-354	563.26	CONDOMINIO RUKAN	0.10	611.44	48.085
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.06	609.82	48.182
J-321	563.15	CONDOMINIO RUKAN	0.10	611.43	48.187
J-309	563.07	CONDOMINIO RUKAN	0.10	611.44	48.271
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.06	609.82	48.414
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.14	611.02	48.438
J-319	562.88	CONDOMINIO RUKAN	0.10	611.44	48.461
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.06	609.82	48.470
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.14	611.13	48.638
J-328	562.51	CONDOMINIO RUKAN	0.10	611.40	48.792
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.14	611.03	48.973
J-327	562.22	CONDOMINIO RUKAN	0.10	611.40	49.077
J-326	562.20	CONDOMINIO RUKAN	0.10	611.40	49.103
J-312	562.17	CONDOMINIO RUKAN	0.10	611.44	49.173
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.14	610.80	49.181
J-310	561.96	CONDOMINIO RUKAN	0.10	611.44	49.382
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.06	609.76	49.521
J-320	561.76	CONDOMINIO RUKAN	0.10	611.43	49.572
J-313	561.70	CONDOMINIO RUKAN	0.10	611.44	49.637
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.14	610.80	49.707
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.06	609.82	49.722
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.14	610.80	49.822
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.14	611.11	49.914
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.14	610.80	49.966
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.14	611.09	50.141
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.14	610.81	50.150

FlexTable: Junction Table
Current Time: 14.000 hours

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.14	610.81	50.393
J-311	560.78	CONDOMINIO RUKAN	0.10	611.44	50.560
J-314	560.46	CONDOMINIO RUKAN	0.10	611.44	50.877
J-315	560.12	CONDOMINIO RUKAN	0.10	611.44	51.210
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.14	610.81	51.920
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.14	610.80	51.943
J-317	558.84	CONDOMINIO RUKAN	0.10	611.44	52.492
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.14	610.79	52.681
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.14	611.02	52.826
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.14	610.79	53.130
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.14	611.02	53.176
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.14	610.79	53.988
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.14	611.11	53.989
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.14	610.79	54.065
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.14	610.81	54.276
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.14	611.02	54.352
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.14	610.79	54.409
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.14	611.10	54.511
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.14	610.84	54.769
J-316	556.36	CONDOMINIO RUKAN	0.10	611.44	54.967
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.14	611.10	54.992
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.14	610.91	54.993
J-318	555.89	CONDOMINIO RUKAN	0.10	611.44	55.437
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.14	611.01	56.031
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.14	611.01	56.232

New Graph



T-1 - Caudales maximos horarios año 15 - Level (Calculated)

FlexTable: Hydrant Table

Label	Hydrant Status	Elevation (m)	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
H-5	Open	587.66	0.00	620.59	32.863
H-1	Open	587.58	0.00	614.76	27.123
H-48	Open	586.10	0.00	620.65	34.477
H-52	Open	584.86	0.00	612.89	27.975
H-13	Open	583.85	0.00	620.59	36.665
H-50	Open	583.79	0.00	620.41	36.548
H-2	Open	583.53	0.00	617.12	33.522
H-4	Open	581.61	0.00	620.76	39.066
H-3	Open	581.53	0.00	618.73	37.130
H-12	Open	579.64	0.00	620.81	41.084
H-49	Open	579.63	0.15	620.41	40.700
H-51	Open	579.07	0.00	620.88	41.720
H-14	Open	578.50	0.00	619.92	41.334
H-10	Open	578.19	0.00	620.55	42.274
H-6	Open	576.17	0.00	620.89	44.629
H-9	Open	575.57	0.00	620.85	45.187
H-16	Open	575.02	0.00	619.17	44.058
H-19	Open	574.00	0.00	618.88	44.796
H-18	Open	573.71	0.00	618.90	45.099
H-40	Open	573.54	0.00	619.55	45.924
H-44	Open	573.25	0.00	619.01	45.668
H-38	Open	572.44	0.00	619.55	47.012
H-22	Open	572.25	0.00	619.05	46.713
H-20	Open	572.24	0.00	618.83	46.495
H-17	Open	572.06	0.00	618.92	46.766
H-15	Open	572.00	0.00	619.45	47.351
H-45	Open	570.59	0.00	618.88	48.195
H-26	Open	569.69	0.00	619.56	49.767
H-43	Open	569.30	0.00	619.36	49.967
H-21	Open	568.77	0.00	618.78	49.913
H-47	Open	568.48	0.00	618.75	50.170
H-25	Open	567.49	0.00	619.53	51.936
H-41	Open	567.06	0.00	619.53	52.371
H-27	Open	566.67	0.00	619.50	52.718
H-35	Open	565.34	0.00	619.71	54.256
H-29	Open	564.78	0.00	619.37	54.479
H-28	Open	564.00	0.00	619.43	55.321
H-42	Open	563.62	0.00	619.53	55.793
H-30	Open	563.44	0.00	619.35	55.801
H-39	Open	563.31	0.00	619.55	56.120
H-34	Open	562.75	0.00	619.26	56.395
H-46	Open	561.45	0.00	618.78	57.212
H-37	Open	560.40	0.00	619.24	58.728
H-36	Open	560.34	0.00	619.25	58.787
H-53	Open	560.06	0.00	619.35	59.167
H-24	Open	560.03	0.00	619.54	59.391
H-33	Open	556.11	0.00	619.26	63.024
H-32	Open	555.48	0.00	619.33	63.730
H-31	Open	554.18	0.00	619.34	65.033

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-1	584.67	<None>	9.55	612.63	27.908
J-2	584.49	<None>	6.21	612.64	28.093
J-3	584.18	<None>	6.21	612.63	28.396
J-25	589.08	BRISAS DE CHICUREO NORTE	0.08	620.61	31.460
J-26	588.78	BRISAS DE CHICUREO NORTE	0.08	620.60	31.757
J-28	588.57	BRISAS DE CHICUREO NORTE	2.01	620.58	31.945
J-18	588.00	BRISAS DE CHICUREO NORTE	0.08	620.63	32.565
J-19	587.16	BRISAS DE CHICUREO NORTE	0.08	620.63	33.400
J-17	587.03	BRISAS DE CHICUREO NORTE	0.08	620.62	33.522
J-11	586.98	BRISAS DE CHICUREO NORTE	0.08	620.64	33.592
J-27	586.55	BRISAS DE CHICUREO NORTE	0.08	620.59	33.968
J-76	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.44	34.370
J-48	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.44	34.372
J-47	586.00	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.44	34.373
J-79	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.45	34.381
J-43	586.00	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.47	34.396
J-42	586.00	<None>	0.00	620.50	34.428
J-46	585.94	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.44	34.429
J-62	585.86	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	34.479
J-36	585.36	<None>	1.43	620.02	34.589
J-65	585.66	<None>	0.00	620.41	34.675
J-41	585.68	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.52	34.774
J-16	585.62	BRISAS DE CHICUREO NORTE	2.01	620.51	34.816
J-61	585.46	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	34.881
J-10	585.63	BRISAS DE CHICUREO NORTE	0.08	620.65	34.951
J-40	585.05	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.54	35.428
J-66	584.89	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.41	35.452
J-56	584.75	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	35.592
J-80	584.72	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.43	35.645
J-44	584.68	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.45	35.701
J-24	584.83	BRISAS DE CHICUREO NORTE	0.08	620.61	35.709

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-37	584.60	<None>	0.00	620.57	35.896
J-63	584.43	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	35.907
J-9	584.37	BRISAS DE CHICUREO NORTE	0.08	620.68	36.237
J-300	583.11	CONDOMINIO RUKAN	0.07	619.56	36.377
J-20	584.07	BRISAS DE CHICUREO NORTE	0.08	620.63	36.491
J-75	583.85	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.43	36.504
J-12	583.81	BRISAS DE CHICUREO NORTE	0.08	620.62	36.733
J-69	583.51	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.41	36.825
J-15	583.58	BRISAS DE CHICUREO NORTE	0.08	620.54	36.891
PCP- 11	583.39	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.43	36.963
J-77	583.34	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.44	37.022
J-21	583.46	BRISAS DE CHICUREO NORTE	0.08	620.64	37.103
J-78	583.10	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.44	37.262
J-403	583.29	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	37.373
J-45	582.89	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.44	37.483
J-70	582.79	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.42	37.553
J-405	582.65	SAN LUIS	1.74	620.30	37.579
J-52	582.73	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.43	37.619
J-38	582.80	CONDOMINIO REMANSO DE CHICUREO	4.71	620.52	37.640
J-402	582.93	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	37.733
J-60	582.59	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	37.741
J-14	582.64	BRISAS DE CHICUREO NORTE	0.08	620.60	37.887
J-73	582.23	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.43	38.125
J-101	582.72	<None>	0.09	620.94	38.152
J-4	582.48	<None>	0.00	620.78	38.221
J-51	581.86	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.43	38.486
J-74	581.81	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.43	38.543
J-13	581.92	BRISAS DE CHICUREO NORTE	0.08	620.61	38.609
J-67	581.70	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.41	38.631
J-64	581.64	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	38.692

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-8	581.84	BRISAS DE CHICUREO NORTE	0.08	620.71	38.798
J-5	581.70	<None>	0.00	620.76	38.979
J-364	580.49	CONDOMINIO RUKAN	0.07	619.56	38.993
J-400	581.62	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	39.041
J-59	581.20	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	39.132
J-23	581.37	BRISAS DE CHICUREO NORTE	0.08	620.62	39.173
J-71	581.11	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.42	39.229
J-299	580.15	CONDOMINIO RUKAN	0.07	619.57	39.346
J-55	580.99	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.41	39.348
J-49	580.86	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.44	39.501
J-401	581.05	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	39.610
J-22	580.92	BRISAS DE CHICUREO NORTE	0.08	620.63	39.629
J-398	580.97	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	39.694
J-85	581.00	<None>	0.09	620.85	39.765
J-88	580.83	<None>	0.09	620.86	39.953
J-89	580.51	<None>	0.09	620.86	40.274
J-84	580.42	<None>	0.09	620.84	40.346
J-50	579.96	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.43	40.393
J-87	580.27	<None>	0.09	620.85	40.501
J-97	580.31	<None>	0.09	620.94	40.544
J-39	580.14	<None>	0.09	620.79	40.570
J-81	580.00	<None>	0.09	620.80	40.721
J-82	580.00	<None>	0.09	620.82	40.735
J-86	580.00	<None>	0.09	620.85	40.767
J-94	580.00	<None>	0.09	620.89	40.804
J-93	580.00	<None>	0.09	620.89	40.804
J-301	578.67	CONDOMINIO RUKAN	0.07	619.56	40.811
J-298	578.65	CONDOMINIO RUKAN	0.07	619.59	40.852
J-91	579.93	<None>	0.09	620.87	40.858
J-83	579.67	<None>	0.09	620.84	41.087
J-29	579.64	<None>	0.09	620.87	41.152
J-98	579.66	<None>	0.09	620.94	41.196
J-90	579.31	<None>	0.09	620.86	41.470
J-92	579.33	<None>	0.09	620.89	41.473
J-397	579.17	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	41.492
J-54	578.81	CONDOMINIO 1 BRISAS- CHICUREO	0.15	620.42	41.525
J-72	578.80	CONDOMINIO 2BRISAS- CHICUREO	0.15	620.42	41.535
J-112	579.30	<None>	0.09	620.93	41.551
J-304	577.89	CONDOMINIO RUKAN	0.07	619.57	41.599

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-68	578.71	CONDOMINIO 2BRISAS-CHICUREO	0.15	620.41	41.617
J-6	578.90	BRISAS DE CHICUREO NORTE	0.08	620.75	41.774
J-396	578.75	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.75	41.912
J-102	578.94	<None>	0.09	620.94	41.920
J-109	578.73	<None>	0.09	620.90	42.087
J-399	578.50	CONDOMINIO JARDINES DE SANTA FILOMENA	0.11	620.74	42.161
J-7	578.48	BRISAS DE CHICUREO NORTE	0.08	620.75	42.185
J-95	578.40	<None>	0.09	620.91	42.430
J-111	578.22	<None>	0.09	620.93	42.625
J-104	578.17	<None>	0.09	620.93	42.683
J-215	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.79	42.699
J-214	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.79	42.701
J-213	576.00	CONDOMINIO LAS CALANDRIAS	0.04	618.79	42.703
J-253	576.00	CONDOMINIO LA SIEMBRA	0.14	618.87	42.787
J-291	576.00	CONDOMINIO LA TRILLA	0.13	619.01	42.927
J-242	575.72	CONDOMINIO LA SIEMBRA	0.14	618.87	43.062
J-96	577.74	<None>	0.09	620.94	43.110
J-277	575.74	CONDOMINIO LA TRILLA	0.13	619.02	43.188
J-100	577.57	<None>	0.09	620.95	43.284
J-216	575.32	CONDOMINIO LAS CALANDRIAS	0.04	618.78	43.373
J-105	577.42	<None>	0.09	620.93	43.423
J-99	577.36	<None>	0.09	620.94	43.490
J-303	575.85	CONDOMINIO RUKAN	0.07	619.56	43.622
J-305	575.80	CONDOMINIO RUKAN	0.07	619.57	43.686
J-35	576.93	<None>	0.98	620.74	43.724
J-363	575.69	CONDOMINIO RUKAN	0.07	619.56	43.777
J-297	575.70	CONDOMINIO RUKAN	0.07	619.59	43.805
J-191	574.74	CONDOMINIO LAS CALANDRIAS	0.04	618.75	43.921
J-173	575.06	<None>	0.54	619.17	44.028
J-267	574.77	CONDOMINIO LA TRILLA	0.13	619.01	44.156
J-258	574.89	<None>	0.00	619.14	44.163
J-287	574.68	CONDOMINIO LA TRILLA	0.13	619.02	44.248
J-217	574.40	CONDOMINIO LAS CALANDRIAS	0.04	618.78	44.298
J-223	574.40	CONDOMINIO LAS CALANDRIAS	0.04	618.79	44.298
J-292	574.50	CONDOMINIO LA TRILLA	0.13	619.01	44.422
J-222	574.24	CONDOMINIO LAS CALANDRIAS	0.04	618.78	44.450
J-259	574.54	<None>	0.54	619.11	44.478
J-245	574.28	CONDOMINIO LA SIEMBRA	0.14	618.87	44.501

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-254	574.24	CONDOMINIO LA SIEMBRA	0.14	618.88	44.546
J-264	574.31	CONDOMINIO LA TRILLA	0.13	619.02	44.626
J-188	574.00	CONDOMINIO LAS CALANDRIAS	0.04	618.75	44.658
J-289	574.20	CONDOMINIO LA TRILLA	0.13	619.02	44.734
J-290	574.15	CONDOMINIO LA TRILLA	0.13	619.01	44.774
J-233	574.00	CONDOMINIO LA SIEMBRA	0.14	618.88	44.788
J-232	574.00	CONDOMINIO LA SIEMBRA	0.14	618.88	44.789
J-231	574.00	CONDOMINIO LA SIEMBRA	0.14	618.88	44.789
J-257	574.00	CONDOMINIO LA SIEMBRA	0.14	618.88	44.790
J-268	574.09	CONDOMINIO LA TRILLA	0.13	619.01	44.829
J-283	574.00	CONDOMINIO LA TRILLA	0.13	619.01	44.924
J-106	575.90	<None>	0.09	620.94	44.943
J-209	573.73	CONDOMINIO LAS CALANDRIAS	0.04	618.79	44.969
J-34	575.78	<None>	0.09	620.86	44.996
J-274	573.93	CONDOMINIO LA TRILLA	0.13	619.02	45.007
J-103	575.79	<None>	0.09	620.95	45.074
J-284	573.82	CONDOMINIO LA TRILLA	0.13	619.01	45.103
J-33	575.65	<None>	0.09	620.90	45.167
J-263	573.68	CONDOMINIO LA TRILLA	0.13	619.03	45.258
J-237	573.42	CONDOMINIO LA SIEMBRA	0.14	618.88	45.363
J-339	574.08	CONDOMINIO RUKAN	0.07	619.55	45.381
J-256	573.36	CONDOMINIO LA SIEMBRA	0.14	618.88	45.433
J-307	573.85	CONDOMINIO RUKAN	0.07	619.55	45.614
J-273	573.20	CONDOMINIO LA TRILLA	0.13	619.02	45.724
J-230	573.06	CONDOMINIO LA SIEMBRA	0.14	618.88	45.727
J-148	573.48	CONDOMINIO LAS BRISAS 3	0.09	619.36	45.789
J-218	572.89	CONDOMINIO LAS CALANDRIAS	0.04	618.78	45.800
J-236	572.96	CONDOMINIO LA SIEMBRA	0.14	618.88	45.826
J-235	572.84	CONDOMINIO LA SIEMBRA	0.14	618.88	45.945
J-266	572.94	CONDOMINIO LA TRILLA	0.13	619.01	45.982
J-269	572.92	CONDOMINIO LA TRILLA	0.13	619.01	46.003
J-365	573.40	CONDOMINIO RUKAN	0.07	619.55	46.056
J-347	573.38	CONDOMINIO RUKAN	0.07	619.55	46.076
J-286	572.84	CONDOMINIO LA TRILLA	0.13	619.01	46.079
J-30	574.69	<None>	0.09	620.94	46.153
J-349	573.30	CONDOMINIO RUKAN	0.07	619.55	46.153
J-285	572.69	CONDOMINIO LA TRILLA	0.13	619.01	46.228
J-207	572.46	CONDOMINIO LAS CALANDRIAS	0.04	618.79	46.236
J-255	572.50	CONDOMINIO LA SIEMBRA	0.14	618.88	46.286

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-275	572.54	CONDOMINIO LA TRILLA	0.13	619.02	46.389
J-107	574.43	<None>	0.09	620.94	46.408
J-197	572.18	CONDOMINIO LAS CALANDRIAS	0.04	618.75	46.479
J-234	572.29	CONDOMINIO LA SIEMBRA	0.14	618.88	46.500
J-206	572.18	CONDOMINIO LAS CALANDRIAS	0.04	618.78	46.513
J-238	572.25	CONDOMINIO LA SIEMBRA	0.14	618.88	46.540
J-262	572.35	<None>	0.00	619.05	46.613
J-208	571.98	CONDOMINIO LAS CALANDRIAS	0.04	618.79	46.719
J-407	574.27	<None>	0.00	621.10	46.731
J-229	572.00	CONDOMINIO LA SIEMBRA	0.14	618.88	46.791
J-239	571.97	CONDOMINIO LA SIEMBRA	0.14	618.88	46.813
J-249	571.94	CONDOMINIO LA SIEMBRA	0.14	618.88	46.853
J-240	571.92	CONDOMINIO LA SIEMBRA	0.14	618.87	46.862
J-293	572.06	<None>	0.54	619.05	46.898
J-272	571.78	CONDOMINIO LA TRILLA	0.13	619.02	47.143
J-250	571.58	CONDOMINIO LA SIEMBRA	0.14	618.88	47.199
J-174	571.62	<None>	0.54	618.93	47.213
J-210	571.45	CONDOMINIO LAS CALANDRIAS	0.04	618.80	47.253
J-265	571.65	CONDOMINIO LA TRILLA	0.13	619.01	47.264
J-228	571.51	CONDOMINIO LA SIEMBRA	0.14	618.89	47.286
J-120	572.00	CONDOMINIO LAS BRISAS 3	0.94	619.43	47.326
J-260	571.62	<None>	0.00	619.07	47.355
J-225	571.23	CONDOMINIO LAS CALANDRIAS	0.04	618.78	47.459
J-118	571.88	CONDOMINIO LAS BRISAS 3	0.94	619.45	47.478
J-244	571.26	CONDOMINIO LA SIEMBRA	0.14	618.87	47.516
J-261	571.29	<None>	0.54	619.07	47.686
J-190	570.95	CONDOMINIO LAS CALANDRIAS	0.04	618.75	47.699
J-163	571.57	CONDOMINIO LAS BRISAS 3	0.98	619.38	47.710
J-247	571.03	CONDOMINIO LA SIEMBRA	0.14	618.88	47.751
J-144	571.44	CONDOMINIO LAS BRISAS 3	0.09	619.35	47.816
J-251	570.94	CONDOMINIO LA SIEMBRA	0.14	618.88	47.842
J-246	570.92	CONDOMINIO LA SIEMBRA	0.14	618.87	47.857
J-276	571.05	CONDOMINIO LA TRILLA	0.13	619.01	47.868

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-211	570.76	CONDOMINIO LAS CALANDRIAS	0.04	618.81	47.951
J-32	572.86	<None>	0.09	620.96	47.998
J-406	572.89	<None>	0.00	620.99	48.000
J-31	572.85	<None>	0.09	620.97	48.026
J-147	571.15	CONDOMINIO LAS BRISAS 3	0.09	619.36	48.113
J-241	570.57	CONDOMINIO LA SIEMBRA	0.14	618.87	48.211
J-162	571.04	CONDOMINIO LAS BRISAS 3	0.98	619.38	48.243
J-219	570.42	CONDOMINIO LAS CALANDRIAS	0.04	618.78	48.262
J-175	570.44	<None>	0.00	618.82	48.281
J-279	570.60	CONDOMINIO LA TRILLA	0.13	619.01	48.319
J-119	570.91	CONDOMINIO LAS BRISAS 3	0.94	619.44	48.433
J-348	570.98	CONDOMINIO RUKAN	0.07	619.55	48.472
J-271	570.38	CONDOMINIO LA TRILLA	0.13	619.01	48.540
J-113	571.08	<None>	2.85	619.75	48.573
J-164	570.65	CONDOMINIO LAS BRISAS 3	0.09	619.38	48.630
J-192	569.90	CONDOMINIO LAS CALANDRIAS	0.04	618.75	48.748
J-189	569.88	CONDOMINIO LAS CALANDRIAS	0.04	618.75	48.773
J-243	570.00	CONDOMINIO LA SIEMBRA	0.14	618.87	48.776
J-248	570.00	CONDOMINIO LA SIEMBRA	0.14	618.88	48.781
J-252	570.00	CONDOMINIO LA SIEMBRA	0.14	618.88	48.784
J-308	570.59	CONDOMINIO RUKAN	0.07	619.55	48.860
J-270	570.00	CONDOMINIO LA TRILLA	0.13	619.01	48.915
J-161	570.30	CONDOMINIO LAS BRISAS 3	0.98	619.38	48.980
J-360	570.45	CONDOMINIO RUKAN	0.07	619.56	49.003
J-278	569.90	CONDOMINIO LA TRILLA	0.13	619.01	49.014
J-201	569.62	CONDOMINIO LAS CALANDRIAS	0.04	618.75	49.023
J-160	569.98	CONDOMINIO LAS BRISAS 3	0.98	619.39	49.309
J-282	569.56	CONDOMINIO LA TRILLA	0.13	619.01	49.355
J-302	570.02	CONDOMINIO RUKAN	0.07	619.56	49.434
J-296	570.00	<None>	0.00	619.60	49.499
J-306	569.69	CONDOMINIO RUKAN	0.07	619.56	49.766
J-212	568.95	CONDOMINIO LAS CALANDRIAS	0.04	618.82	49.771
J-196	568.84	CONDOMINIO LAS CALANDRIAS	0.04	618.75	49.809
J-149	569.39	CONDOMINIO LAS BRISAS 3	0.09	619.36	49.871
J-281	569.04	CONDOMINIO LA TRILLA	0.13	619.01	49.872
J-179	568.74	CONDOMINIO LAS CALANDRIAS	0.04	618.80	49.960

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-294	569.53	<None>	1.43	619.60	49.966
J-295	569.50	<None>	0.00	619.60	49.999
J-343	569.39	CONDOMINIO RUKAN	0.07	619.54	50.048
J-178	568.56	CONDOMINIO LAS CALANDRIAS	0.04	618.80	50.141
J-366	569.22	CONDOMINIO RUKAN	0.07	619.55	50.229
J-146	568.89	CONDOMINIO LAS BRISAS 3	0.09	619.36	50.365
J-280	568.45	CONDOMINIO LA TRILLA	0.13	619.01	50.459
J-176	568.17	CONDOMINIO LAS CALANDRIAS	0.04	618.82	50.546
J-338	568.83	CONDOMINIO RUKAN	0.07	619.54	50.605
J-154	568.58	CONDOMINIO LAS BRISAS 3	0.09	619.35	50.664
J-117	568.69	CONDOMINIO LAS BRISAS 3	0.94	619.47	50.679
J-341	568.69	CONDOMINIO RUKAN	0.07	619.53	50.735
J-153	568.49	CONDOMINIO LAS BRISAS 3	0.09	619.35	50.758
J-131	568.47	CONDOMINIO LAS BRISAS 3	0.09	619.35	50.776
J-130	568.37	CONDOMINIO LAS BRISAS 3	0.09	619.35	50.876
J-132	568.30	CONDOMINIO LAS BRISAS 3	0.09	619.35	50.943
J-404	567.81	REMANSO DE CHICUREO	0.16	618.86	50.944
J-199	567.55	CONDOMINIO LAS CALANDRIAS	0.04	618.75	51.093
J-198	567.52	CONDOMINIO LAS CALANDRIAS	0.04	618.75	51.124
J-340	568.30	CONDOMINIO RUKAN	0.07	619.53	51.125
J-115	568.13	CONDOMINIO LAS BRISAS 3	0.98	619.48	51.246
J-121	568.03	CONDOMINIO LAS BRISAS 3	0.98	619.45	51.310
J-125	567.95	CONDOMINIO LAS BRISAS 3	0.09	619.37	51.321
J-200	567.27	CONDOMINIO LAS CALANDRIAS	0.04	618.75	51.375
J-124	567.86	CONDOMINIO LAS BRISAS 3	0.09	619.38	51.414
J-152	567.82	CONDOMINIO LAS BRISAS 3	0.09	619.35	51.422
J-205	567.22	CONDOMINIO LAS CALANDRIAS	0.04	618.78	51.463
J-177	567.23	CONDOMINIO LAS CALANDRIAS	0.04	618.81	51.472
J-195	567.12	CONDOMINIO LAS CALANDRIAS	0.04	618.75	51.528
J-127	567.69	CONDOMINIO LAS BRISAS 3	0.09	619.36	51.572
J-129	567.61	CONDOMINIO LAS BRISAS 3	0.09	619.36	51.642
J-323	567.67	CONDOMINIO RUKAN	0.07	619.53	51.758

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-187	566.88	CONDOMINIO LAS CALANDRIAS	0.04	618.75	51.761
J-158	567.46	CONDOMINIO LAS BRISAS 3	0.09	619.35	51.782
J-370	567.56	<None>	0.85	619.51	51.845
J-359	567.58	CONDOMINIO RUKAN	0.07	619.56	51.870
J-367	567.48	<None>	2.27	619.53	51.937
J-345	567.47	CONDOMINIO RUKAN	0.07	619.54	51.958
J-123	567.29	CONDOMINIO LAS BRISAS 3	0.98	619.40	52.006
J-143	567.19	CONDOMINIO LAS BRISAS 3	0.09	619.35	52.059
J-335	567.32	CONDOMINIO RUKAN	0.07	619.53	52.106
J-350	567.29	<None>	0.00	619.55	52.151
J-224	566.43	CONDOMINIO LAS CALANDRIAS	0.04	618.78	52.243
J-344	567.16	CONDOMINIO RUKAN	0.07	619.54	52.271
J-151	566.89	CONDOMINIO LAS BRISAS 3	0.09	619.35	52.350
J-114	567.04	CONDOMINIO LAS BRISAS 3	1.83	619.52	52.369
J-116	567.02	CONDOMINIO LAS BRISAS 3	0.09	619.52	52.387
J-334	566.99	CONDOMINIO RUKAN	0.07	619.53	52.428
J-128	566.82	CONDOMINIO LAS BRISAS 3	0.09	619.36	52.435
J-333	566.93	CONDOMINIO RUKAN	0.07	619.53	52.488
J-126	566.76	CONDOMINIO LAS BRISAS 3	0.09	619.36	52.497
J-183	566.06	CONDOMINIO LAS CALANDRIAS	0.04	618.77	52.601
J-352	566.81	CONDOMINIO RUKAN	0.07	619.55	52.633
J-155	566.58	CONDOMINIO LAS BRISAS 3	0.09	619.35	52.662
J-165	566.57	CONDOMINIO LAS BRISAS 3	0.09	619.38	52.703
J-122	566.51	CONDOMINIO LAS BRISAS 3	0.98	619.42	52.799
J-180	565.86	CONDOMINIO LAS CALANDRIAS	0.04	618.79	52.824
J-336	566.58	CONDOMINIO RUKAN	0.07	619.53	52.842
J-380	566.26	CONDOMINIO BORDE BLANCO 1	0.09	619.26	52.891
J-145	566.32	CONDOMINIO LAS BRISAS 3	0.09	619.35	52.924
J-332	566.49	CONDOMINIO RUKAN	0.07	619.53	52.931
J-220	565.74	CONDOMINIO LAS CALANDRIAS	0.04	618.78	52.933
J-357	566.51	CONDOMINIO RUKAN	0.07	619.55	52.937
J-322	566.48	CONDOMINIO RUKAN	0.07	619.54	52.948
J-325	566.45	CONDOMINIO RUKAN	0.07	619.53	52.972
J-184	565.64	CONDOMINIO LAS CALANDRIAS	0.04	618.76	53.008
J-358	566.38	CONDOMINIO RUKAN	0.07	619.55	53.065

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-150	566.13	CONDOMINIO LAS BRISAS 3	0.09	619.35	53.115
J-157	566.08	CONDOMINIO LAS BRISAS 3	0.09	619.35	53.161
J-351	566.23	CONDOMINIO RUKAN	0.07	619.55	53.210
J-193	565.42	CONDOMINIO LAS CALANDRIAS	0.04	618.75	53.217
J-133	565.92	CONDOMINIO LAS BRISAS 3	0.09	619.35	53.318
J-331	566.08	CONDOMINIO RUKAN	0.07	619.53	53.334
J-337	566.06	CONDOMINIO RUKAN	0.07	619.53	53.363
J-342	566.03	CONDOMINIO RUKAN	0.07	619.53	53.393
J-134	565.53	CONDOMINIO LAS BRISAS 3	0.09	619.35	53.706
J-377	565.35	CONDOMINIO BORDE BLANCO 2	2.21	619.36	53.896
J-361	565.53	CONDOMINIO RUKAN	0.07	619.55	53.910
J-135	564.98	CONDOMINIO LAS BRISAS 3	0.09	619.35	54.260
J-137	564.95	CONDOMINIO LAS BRISAS 3	0.09	619.35	54.283
J-330	565.13	CONDOMINIO RUKAN	0.07	619.53	54.289
J-221	564.30	CONDOMINIO LAS CALANDRIAS	0.04	618.78	54.372
J-346	564.90	<None>	0.00	619.54	54.525
J-136	564.69	CONDOMINIO LAS BRISAS 3	0.09	619.35	54.544
J-194	564.01	CONDOMINIO LAS CALANDRIAS	0.04	618.75	54.625
J-375	564.57	<None>	0.72	619.38	54.701
J-373	564.55	<None>	0.72	619.41	54.751
J-159	564.42	CONDOMINIO LAS BRISAS 3	0.09	619.35	54.819
J-329	564.22	CONDOMINIO RUKAN	0.07	619.53	55.192
J-362	564.16	CONDOMINIO RUKAN	0.07	619.55	55.285
J-371	564.00	<None>	0.72	619.45	55.342
J-324	563.73	CONDOMINIO RUKAN	0.07	619.53	55.686
J-356	563.68	CONDOMINIO RUKAN	0.07	619.55	55.757
J-355	563.53	CONDOMINIO RUKAN	0.07	619.55	55.904
J-353	563.38	CONDOMINIO RUKAN	0.07	619.55	56.052
J-354	563.26	CONDOMINIO RUKAN	0.07	619.55	56.173
J-321	563.15	CONDOMINIO RUKAN	0.07	619.54	56.280
J-156	562.95	CONDOMINIO LAS BRISAS 3	0.09	619.35	56.283
J-309	563.07	CONDOMINIO RUKAN	0.07	619.55	56.359
J-381	562.77	CONDOMINIO BORDE BLANCO 1	0.09	619.25	56.371
J-182	562.26	CONDOMINIO LAS CALANDRIAS	0.04	618.77	56.405
J-319	562.88	CONDOMINIO RUKAN	0.07	619.55	56.550
J-138	562.48	CONDOMINIO LAS BRISAS 3	0.09	619.35	56.749
J-185	561.86	CONDOMINIO LAS CALANDRIAS	0.04	618.75	56.774

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-171	562.39	CONDOMINIO LAS BRISAS 3	0.09	619.40	56.893
J-328	562.51	CONDOMINIO RUKAN	0.07	619.53	56.902
J-181	561.54	CONDOMINIO LAS CALANDRIAS	0.04	618.78	57.122
J-327	562.22	CONDOMINIO RUKAN	0.07	619.53	57.187
J-326	562.20	CONDOMINIO RUKAN	0.07	619.53	57.212
J-312	562.17	CONDOMINIO RUKAN	0.07	619.55	57.263
J-142	561.96	CONDOMINIO LAS BRISAS 3	0.09	619.35	57.279
J-204	561.31	CONDOMINIO LAS CALANDRIAS	0.04	618.78	57.356
J-202	561.26	CONDOMINIO LAS CALANDRIAS	0.04	618.78	57.411
J-310	561.96	CONDOMINIO RUKAN	0.07	619.55	57.471
J-389	561.52	CONDOMINIO BORDE BLANCO 1	0.09	619.24	57.608
J-320	561.76	CONDOMINIO RUKAN	0.07	619.54	57.665
J-313	561.70	CONDOMINIO RUKAN	0.07	619.54	57.727
J-384	561.00	CONDOMINIO BORDE BLANCO 1	0.09	619.25	58.132
J-170	561.10	CONDOMINIO LAS BRISAS 3	0.09	619.39	58.176
J-385	560.88	CONDOMINIO BORDE BLANCO 1	0.09	619.24	58.249
J-390	560.73	CONDOMINIO BORDE BLANCO 1	0.09	619.24	58.393
J-166	560.85	CONDOMINIO LAS BRISAS 3	0.09	619.38	58.412
J-186	560.14	CONDOMINIO LAS CALANDRIAS	0.04	618.75	58.497
J-382	560.56	CONDOMINIO BORDE BLANCO 1	0.09	619.25	58.569
J-311	560.78	CONDOMINIO RUKAN	0.07	619.55	58.649
J-203	560.00	CONDOMINIO LAS CALANDRIAS	0.04	618.78	58.663
J-383	560.32	CONDOMINIO BORDE BLANCO 1	0.09	619.25	58.813
J-314	560.46	CONDOMINIO RUKAN	0.07	619.54	58.968
J-315	560.12	CONDOMINIO RUKAN	0.07	619.54	59.301
J-393	558.79	CONDOMINIO BORDE BLANCO 1	0.09	619.25	60.340
J-391	558.76	CONDOMINIO BORDE BLANCO 1	0.09	619.25	60.367
J-317	558.84	CONDOMINIO RUKAN	0.07	619.54	60.582
J-394	558.00	CONDOMINIO BORDE BLANCO 1	0.09	619.24	61.112
J-141	558.09	CONDOMINIO LAS BRISAS 3	0.09	619.35	61.134
J-139	557.74	CONDOMINIO LAS BRISAS 3	0.09	619.35	61.486
J-386	557.56	CONDOMINIO BORDE BLANCO 1	0.09	619.24	61.560
J-169	557.01	CONDOMINIO LAS BRISAS 3	0.09	619.39	62.254

FlexTable: Junction Table

Label	Elevation (m)	Zone	Demand (L/s)	Hydraulic Grade (m)	Pressure (m H2O)
J-387	556.69	CONDOMINIO BORDE BLANCO 1	0.09	619.24	62.419
J-388	556.62	CONDOMINIO BORDE BLANCO 1	0.09	619.24	62.496
J-140	556.56	CONDOMINIO LAS BRISAS 3	0.09	619.35	62.661
J-392	556.43	CONDOMINIO BORDE BLANCO 1	0.09	619.25	62.695
J-167	556.48	CONDOMINIO LAS BRISAS 3	0.09	619.38	62.781
J-395	556.27	CONDOMINIO BORDE BLANCO 1	0.09	619.24	62.840
J-316	556.36	CONDOMINIO RUKAN	0.07	619.54	63.058
J-379	555.96	CONDOMINIO BORDE BLANCO 1	0.09	619.26	63.174
J-168	556.00	CONDOMINIO LAS BRISAS 3	0.09	619.39	63.259
J-378	555.81	CONDOMINIO BORDE BLANCO 1	0.09	619.30	63.362
J-318	555.89	CONDOMINIO RUKAN	0.07	619.55	63.527
J-369	554.87	CONDOMINIO BORDE BLANCO 1	0.09	619.34	64.347
J-368	554.66	CONDOMINIO BORDE BLANCO 1	0.09	619.34	64.548